

Month : Apr-2012 Day : Tuesday Date : 17-Apr-12

Probable Maximum Generation :		(a) At Day Peak Hour :				(b) At Evening Peak Hour :				4850 MW				
Water Level of Kaptai Lake at 06:00 AM		Yesterday 76.27 ft				Today 76.33 ft				Rule Curve: 85.00 ft				
Sl.	Name of the Power Station	Fuel	Producer	Installed Capacity		Derailed/ Present Capacity	Actual Generation		Available Generation		Ev. Peak Gen.Shortfall		Plants under Shut down (Date) / Remarks	Probable Start up Date
				MW	MW		On 16-Apr-12		On 17-Apr-12		for Fuel Limitation	for Plants S/D or MIC prob.		
							Day Peak	Ev. Peak	Day Peak	Ev. Peak				
1a	Ghorasal ST 1 & 2	Gas	PDB	2x55	110	78	45	45	45	45	30	190	#2(26/04/10)	Unknown
1b	Ghorasal ST 3,4,5& 6	Gas	PDB	4x210	840	740	530	530	350	530	20	190	#6(18/07/10)	Unknown
2	Ghorashal 100 MW	Gas	ORPP 3yrs	128x0.85	100	100	102	103	100	100				
3	Ghorashal 45 MW	Gas	ORPP 3yrs	50x0.85	45	45	44	47	45	45				Synchronized at 33KV
4	Ghorashal MAX	Gas	RPP	4x19.6	78	78	20	0	78	0	78	0		4 MIC
5	Haripur SBU GT 1, 2 & 3	Gas	SBU,PDB	3x32	96	84	40	40	40	40		44	#3(18/08/09)	Unknown
6	Haripur NEPC	HFO	IPP	8x15	110	85	0	0	50	0	85	0		8 MIC
7	Haripur P. Ltd CCPP	Gas	IPP	235+125	360	360	357	347	350	347	13			
8	Meghnaghat P.Ltd CCPP	Gas	IPP	3x150	450	450	452	451	450	450				
9	Meghnaghat IEL	HFO	RPP	12x8.9	100	100	0	100	0	100				
10	Madanganj 102 MW	HFO	ORPP 3yrs	6x17.08	102	102	0	60	0	60	42			3 MIC
11	Keraniganj	HFO	RPP	8x14.4	100	100	0	59	0	100	41			3 MIC
12	Narsingdi	Gas	SIPP,REB	8x2.90	22	22	13	22	19	22				Synchronized at 33KV
11a	Siddhirgonj ST	Gas	EGCB	1x210	210	150	0	0	0	0		150	8/1/2011	Unknown
11b	Siddhirgonj GT-1, 2	Gas	EGCB	2x120	210	210	95	102	84	102		105		1 MIC
12	Siddhirgonj 100MW	HSD	ORPP 3yrs	96x1.2	100	96	0	0	0	0	96			96 MIC
13	Dutch Bangla 100 MW	HFO	RPP	12x8.9	100	100	0	103	0	100				
14	DPA Power 50MW	HSD	ORPP 3yrs	100x0.5	49	49	0	0	0	49	49			Synchronized at 33KV, 100 MIC
15	Summit Power (Dhaka)	Gas	SIPP,REB	146	146	146	68	108	107	108				Synchronized at 33KV
16	Gazipur RPCL	HFO	IPP	6x8.9	52	105	0	0	0	0				On test
17	Tongi GT	Gas	PDB	1x105	105	105	75	90	75	90	15			
Dhaka Area Total				3485	3200	1841	2207	1793	2288	439	519			
1	Chittagong Raozan ST 1 & 2	Gas	PDB	1x210,1x180	420	380	100	100	100	100	80	180	#1(14/4/12)	4/18/1912
2	Kaptai Hydro unit 1,2,3,4&5	PDB		2x40+3x50	230	220	0	65	0	65		50	#3(1/12/10)	Unknown
3a	Sikalbaha ST	Gas	PDB	1x60	60	40	38	39	39	39				
3b	Sikalbaha GT	Gas	PDB	1x150	150	150	150	150	150	150				
4	Sikalbaha	HFO	RPP 3yrs	4x125+2x11+1x3+1	55	53	0	0	0	0	53			8 MIC
5	Halthazari	HFO	PDB	11x8.9	100	100	0	0	0	0	100			11 MIC
6	Dohazari	HFO	PDB	6x17	100	100	0	0	0	0	100			6 MIC
7	Juldah	HFO	RPP	8x13.45	100	100	0	0	0	0	100			6 MIC
8	Barabkunda	Gas	SIPP,PDB	8x2.90	22	22	20	17	18	17				Synchronized at 33KV, 2 MIC
9	Malancha Ctg EPZ	Gas					2	21	2	21				Synchronized at 33KV
Chittagong area Total				1237	1165	310	392	309	392	433	230			
1a	Ashuganj ST 1,2	Gas	APSCL	2x64	128	128	55	55	55	55		64	#1(9/11/10)	Unknown
1b	Ashuganj ST 3,4,5	Gas	APSCL	3x150	450	390	432	432	432	432				
1c	Ashuganj CCPP	Gas	APSCL	2x56+34	146	91	73	73	73	73		15	ST(9/4/12)	Unknown
1d	Ashuganj 50 MW	Gas	APSCL	16x3.35	53	53	43	46	40	46		7		2 MIC
2	Ashuganj	Gas	RPP 3yrs	15x4	55	55	44	50	45	50		5		1 MIC
3	Ashuganj Aggrekko	Gas	RPP	8x21.1	80	80	80	82	80	80				
4	Ashuganj UP-53 MW	Gas	RPP	14x4	53	53	53	53	53	53				
5	Brahmanbaria 70MW	Gas	ORPP 3yrs	72x1	68	68	51	70	70	68				
6	Daudkandi 50 MW	FO	PDB	6x8.92	52	52	0	0	0	0	52			6 MIC
7	Chandpur GT	Gas	PDB	1x100+1x50	106	106	0	44	45	45				1 MIC
8	Feni	Gas	SIPP,PDB	8x2.90	22	22	22	22	22	22				
9	Mahipal,Feni	Gas	SIPP,REB	4x2.90	11	11	8	0	5	8		11		Synchronized at 33KV, 1 MIC
10	Jangalia	Gas	SIPP,PDB	4x8.73	33	33	23	31	31	31				Synchronized at 33KV
11	Summit Power (Comilla)	Gas	SIPP,REB	3x3.67+2x6.97	25	25	16	21	17	21		4		Synchronized at 33KV, 1 MIC
Comilla Area Total				1282	1167	900	979	968	984	52	106			
1	RPCL CCPP,Mymensing	Gas	IPP	4x35+1x70	210	197	70	106	106	106				132KV line problem
2	Tangal	Gas	SIPP,PDB	8x2.90	22	22	17	20	20	20		2		Synchronized at 33KV, 1 MIC
Mymensing Area Total				232	219	87	126	126	126	0	2			
1a	Fenchugonj CCPP (old)	Gas	PDB	2x32+1x33	97	90	72	81	80	81				
1b	Fenchugonj CCPP (new)	Gas	PDB	2x35+1x35	104	104	40	40	60	60		64		1 MIC
2	Fenchugonj	Gas	RPP 15yrs	19x2.90	51	51	11	50	30	50				
3	Fenchugonj Prima 50 MW	Gas	RPP	12x3.3+5x2	51	51	16	16	16	16		35		11 MIC
4	Hobiganj	Gas	SIPP,REB	4x2.90	11	11	0	8	0	8				Synchronized at 33KV
5	Shahjibazar GT 8,9	Gas	PDB	2x35	70	66	63	62	60	62				
6	Shahjibazar 86 MW	Gas	RPP 15yrs	32x2.90	86	86	30	83	83	83				1 MIC
7	Shahjibazar 50 MW	Gas	RPP 3yrs	27x2.0	50	50	28	46	20	46				2 MIC
8	Sylhet 150 MW	Gas	PDB	1x100+1x50	150	150	0	0	0	0				On test
9	Sylhet GT	Gas	PDB	1x20	20	20	0	0	0	0		20		1 MIC
10	Sylhet 50MW	Gas	RPP 3yrs	29x1.95	50	50	23	40	32	40		10		5 MIC
11	Sylhet 11 MW	Gas	RPP 15yrs	6x1.95	10	10	0	8	0	8				Synchronized at 33KV, 1 MIC
Sylhet Area Total				750	589	283	434	381	454	0	129			
1	Bheramara GT 1, 2 & 3	HSD	PDB	3x20	60	46	0	0	0	0		46		3 MIC
2	Bheramara	HSD	RPP 3yrs	12x8.5+2x6+2x11	105	105	0	30	0	30	75			12 MIC
3a	Khulna ST 110MW	FO	PDB	1x110	110	55	0	0	0	0		55	11/7/2011	Unknown
3b	Khulna ST 60MW	FO	PDB	1x60	60	30	0	0	0	0		30	1/24/1912	Unknown
4	KPCL, Khulna	HFO	IPP	19x6.5	110	110	0	84	0	0	26			4 MIC
5	KPCL, Khulna (new)	HFO	IPP	7x17	115	115	0	68	0	115				3 MIC
6	Faridpur	FO	PDB	8x6.89	54	54	0	0	0	0	54			8 MIC
7	Gopalganj 110 MW	HFO	PDB	16x6.98	109	109	0	0	0	0	109			16 MIC
8	Noapara (105 MW) Quantam	HFO	RPP	9.9x5+9.5x6+9.2x2	101	101	0	0	0	0		101		13 MIC
9	Noapara (40 MW) KZA	HFO	RPP	5x8	40	40	0	43	0	40				Synchronized at 33KV
10	Khulna 40 MW	HSD	RPP 3yrs	50x0.80	40	40	0	0	0	40		40		50 MIC
11	Khulna 55 MW	HSD	ORPP 3yrs	71x0.85	55	55	0	0	0	0	55			Synchronized at 33KV, 71 MIC
Khulna Area Total				959	860	0	225	0	225	405	186			
1	Barisal Diesel	HSD	PDB	2x1.4+2x1.35	5	2	0	0	0	0		2		4 MIC
2	Barisal GT 1 & 2	HSD	PDB	2x20	40	32	0	0	0	0		32		2 MIC
3	Bhola	Gas	RPP 3yrs	1x34.50	33	33	21	19	19	19		14		
Barisal Area Total				78	67	21	19	19	19	34	14			
1a	Baghabari GT 1	Gas	SBU,PDB	1x71	71	71	0	0	0	0		71	GT1(6/3/12)	Unknown
1b	Baghabari GT 2	Gas	SBU,PDB	1x100	100	100	100	100	100	100				
2	Baghabari 50 MW	HFO	PDB	6x8.9	52	52	0	0	0	0	52			6 MIC
3	Baghabari Westmont	Gas	IPP	2x45	90	70	35	0	35	35		35		Unknown
4	Bera 70 MW	HFO	PDB	9x8.29	71	71	0	0	0	0	71			9 MIC
5	Amnura 50 MW	HFO	RPP	7x7.79	50	50	0	0	0	0	50			7 MIC
6	Katakhali NPS 50 MW	HFO	RPP	6x8.92	50	50	0	0	0	0	50			6 MIC
7	Rajshahi PPP 50 MW				50	50	0	0	0	0				On test
8	Bogra GBB	Gas	RPP 15yrs	6x4	21	21	21	21	21	21				Synchronized at 33KV
9	Bogra 20MW	Gas	RPP 3yrs	5x3.3+5x2	20	20								