

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 24-Aug-17

Page -2

Name of Power Station	Unit	Producer	Present Generation Capacity	Peak Hour Generation	Energy Generated	Remarks
			MW	MW	KWH	
1a	Ghorasal ST: Unit-1, 2	2*55 PDB	85	35	888000	
1b	Ghorasal ST: Unit-3	1*210 PDB	170	170	4010265	
1c	Ghorasal ST: Unit-4	1*210 PDB	180	0	0	Under maint.
1d	Ghorasal ST: Unit-5	1*210 PDB	190	0	0	Under maint.
1e	Ghorasal ST: Unit-6	1*210 PDB	0	0	0	Long term maint.
2	Ghorashal 100MW(Agreko)	128*0.85 QRPP	100	100	2347870	
3	Ghorashal 45MW(Agreko)	58*0.85 QRPP	45	45	1079548	
4	Ghorashal 78.5 MW (MAX)	4*21.5 QRPP	78	0	0	
5	Ghorashal (Regent)	34*3.35 IPP	108	79	1937228	Engine problem
6	Haripur GT: Unit-1, 2	1*32 PDB	20	0	0	Under maint.
		1*32 PDB	20	0	0	Under maint.
		1*32 PDB	0	0	0	Under maint.
7	Haripur EGCB 412 MW CCPP	1*273+1*139 EGCB	412	400	9666000	Gas shortage
8	Haripur NEPCI(HFO)	8*15 IPP	110	97	1647300	Engine problem
9	Haripur Power CCPP	1*235+1*125 IPP	360	291	7247000	Gas shortage
10	Meghnaghat CCPP	2*150+1*150 IPP	450	450	9864000	
11	Meghnaghat (EL)	12*8.9 RPP	100	83	1999680	Engine problem
12	Meghnaghat CCPP(Summit)	2*110+1*110 IPP	305	200	5571520	frequency control.
13	Madanganj (Summit)	6*17 QRPP	100	81	1759872	Engine problem
14	Madanganj-55 MW	5*17.08+1*11 IPP	55	55	1056969	
15	Keraniganj (Powerpac)	8*13.45 RPP	100	93	2125152	Engine problem
16	Narsingdi (Doreen)	8 * 2.9 SIPP, REB	22	22	410832	
17	Siddhirgonj ST	1*210 PDB	150	0	0	Under maint.
18	Siddhirgonj GT : Unit-1 & 2	2*105 EGCB	210	42	1184000	Gas shortage
19	Siddhirgonj (Desh)	96*1.2 QRPP	100	100	1038720	
20	Siddhirgonj (Dutch Bangla)	12*8.9 RPP	100	90	1987200	Engine problem
	Siddhirgonj CCPP-335 MW			0	0	On test.
21	Pagla (DPA)	100*0.5 QRPP	50	49	712000	
22	Gagnagar (Orion)	12*8.924 IPP	102	92	2034576	Engine problem
23	Katpotti 52 MW	RPP	51	35	735170	Engine problem
24	Kodda Peaking	9*17.06 BPDB-RPCL	149	143	3131040	
25	Northern 55 MW	RPP	55	55	1148000	
26	Southern Power	RPP	55	55	1323000	
27	CLCPC Keraniganj 108 MW		108	90	1578240	Engine problem
28	Summit Power,(Madhabdi+Ashulab)	6*3.67+7*8.7 SIPP, REB	80	58	1369320	Engine problem
29	Summit Power, Maona	4*8.73 SIPP, REB	33	0	689800	Tripped at 20:49
30	Summit Power, Rugganj	4*8.74 SIPP, REB	33	33	831500	
31	Gazipur (RPCL)	6*8.9 IPP	52	42	974892	Engine problem
32	Tongi GT	1*105 PDB	105	0	0	Under maintenance.
	Chittagong Area Total		4293	3665	7632793	
33 a)	Chitagong ST:Unit-1	1*210 PDB	180	0	0	Gas shortage
b)	Chitagong ST:Unit-2	1*210 PDB	180	0	0	Gas shortage
34	Raozan 25 MW (RPCL)	3*8.9 IPP	25	26	531900	
35	Patenga 50 MW(Barakatulla)	8*6.89 IPP	50	40	807020	Engine problem
36	Chittagong ECPV 108 MW	IPP	108	96	1852800	Engine problem
37	Karnafuli Hydro Power Station	1*40 PDB	40	38	2746585	
		1*40 PDB	40	31		
		1*50 PDB	50	50		
		1*50 PDB	50	50	1186500	
		1*50 PDB	50	0		
		1*50 PDB	50	0		Under maint.
38	Shikalbaha ST	1*60 PDB	40	0	0	Under maint.
	Shikalbaha 225 MW			136	2493000	On test.
39	Shikalbaha peaking GT	1*150 PDB	150	135	2512155	Gas shortage
40	Hathazari peaking	11*8.9 PDB	98	86	753611	
41	Dohazari-Kalish peaking	6*17 PDB	102	102	1402960	
42	Judah (Accom)	8*13.45 QRPP	100	80	1833720	Engine problem
43	Shikalbaha (Emergis)		51	51	988320	
44	Barakunda (regent)		22	20	504048	
	* Malancha, Ctg EPZ(United)			21	343680	
	Chutugong Area Total		1336	952	18019959	
45 a)	Ashuganj ST: Unit- 2	1*64 APSCL	53	0	0	Under maint.
		1*64 APSCL		0		Under maint.
b)	Ashuganj ST: Unit- 3	1*150 APSCL	135	0	0	Under maint.
c)	Ashuganj ST: Unit- 4	1*150 APSCL	129	110	2632070	
d)	Ashuganj ST: Unit- 5	1*150 APSCL	134	115	2764968	
46	Ashuganj CCPP 225 MW	1*142+1*75 APSCL	221	184	5638870	FGMO
47	Ashuganj CCPP(North)	APSCL	360	200	5254500	Line over load
48	Ashuganj CCPP(South)	APSCL	360	210	4651400	Line over load
49	Ashuganj-Engines	14*3.968 APSCL	45	40	820584	Engine problem
50	Ashuganj (Precision)	15*4 RPP	55	53	1220640	
51	Ashuganj (Aggrekko)	82*1.1 RPP	0	0	0	Date expired
52	Ashuganj (United)	14*4 RPP	53	5	120000	Line over load
53	Ashuganj Modular 200 MW	20*9.7+1*16 IPP	195	16	434909	Line over load
54	Ashuganj (Midland)	6*9.34 IPP	51	6	201328	Line over load
55	Brahmanbaria (Aggreko)	72*1.1 QRPP	85	86	1043029	
56	Titas (Daudipandi) Peaking	6 * 8.92 PDB	52	32	307648	
57	Chandpur CCPP	1*106+1*57 PDB	163	142	3228640	Engine problem
58	Feni(Doreen)	8 *2.84 SIPP, PDB	22	22	489636	
59	Feni Mohipal (Doreen)	4*2.9 SIPP, REB	11	11	238140	
**	Tripura		100	152	3177600	
60	Jangalia (Summit)	4*8.73 SIPP, PDB	33	25	704900	
61	Lakdanavi-52 MW	IPP	52	52	855240	
62	Summit Power,Comilla	3*3.67+2*6.5 SIPP, REB	25	21	528960	
	Comilla Area Total		2334	1482	34413082	
63	RPCL CCPP	4*35+1*70 IPP	202	105	2418880	Gas shortage
64	Tangal (Doreen)	8 *2.9 SIPP,PDB	22	22	481860	
65	Jamalpur RPP	IPP	95	92	2073435	
	Myensingh Area Total		319	219	4974173	
66	Fenchugonj CCPP-1	2*32+1*33 PDB	80	70	1578000	
67	Fenchugonj CCPP-2	2*35+1*35 PDB	90	60	1437080	
	Kushira 163 MW Fenchugonj	RPP		109	2006017	On test
68	Shahjibazar CCPP 330 MW	2*110 PDB	330	217	4340916	Machine problem.
69	Fenchugonj RPP (51 MW)	2*9.19 RPP	51	44	860400	
70	Fenchuganj (Energyprima)	12*3.3+5*2 RPP	44	18	694000	Machine problem.
71	Hobiganj (Confidence-EP)	4*2.9 SIPP, REB	11	8	169104	
72	Shahjibazar GT: Unit-8.9	32*2.9 PDB	66	40	1326000	frequency control.
73	Shahjibazar (Shahjibazar)	32*2.9 RPP	86	86	1192320	
74	Shahjibazar (Energyprima)	27*2.0 RPP	50	50	959760	
75	Sylhet 150 MW GT	1*142 PDB	142	0	30920	Tripped at 20:10
76	Sylhet 20 MW GT	1*20 PDB	20	18	423000	
77	Sylhet (Energyprima)	27 * 2.0 RPP	50	0	0	Date expired
78	Shahjahanulla 25MW	3 * 9.34 CIPP,REB	25	15	355008	Engine problem
79	Summit Bibiana-2	1*222+1*115 IPP	341	250	7176470	FGMO
80	Sylhet (Desh)	6*1.95 RPP	10	7	167760	
	Sylhet Area Total		1396	952	22718753	
81	Bheramara GT: Unit-1,2,3	1*20 PDB	16	16	338432	
		1*20 PDB	14	14		
		1*20 PDB	16	0		
**	Bheramara Interconnector(HVDC)	Imported Pow	500	488	11636364	
82	Khulna (KPCL-1)	19*6.5 IPP	110	97	1932960	Engine problem
83	Khulna (KPCL-2)	7*17 QRPP	115	115	2356800	
84	Faridpur Peaking	8*6.89 PDB	54	39	427200	
85	Khulna 150 MW GT	1*150 NWZPGCL	230	238	5515200	
86	Gopalganj Peaking	16*6.98 PDB	109	62	631700	
87	Bheramara 360 MW	1*280+1*140 NWZPGCL	278	90	2097216	On test
88	Noapara (Khanjahan Ali)	5*8.5 QRPP	40	37	818625	
89	Khulna (Aggreko) 55MW	7*10.85 QRPP	55	43	914840	Engine problem
	Khulna Area Total		7537	1239	26669337	
90	Summit Barisal 110MW	7*17.076 IPP	110	110	2560320	
91	Barisal GT: Unit-1,2	1*20 PDB	16	16	477405	
		1*20 PDB	14	14		
92	Bhola (Venture)	1*34.5 RPP	33	27	466900	
93	Bhola CCPP GT-1,2,ST	2*63+1*68 PDB	194	170	4190754	
	Barisal Area Total		367	337	7695379	
94 a)	Baghabari GT	1*71 PDB	71	0	0	Under maint.
b)	Baghabari GT	1*100 PDB	100	0	0	Under maint.
95	Baghabari Peaking	6*8.9 PDB	52	32	697416	
96	Bera Peaking	9*8.29 PDB	71	48	1124925	
97	Ammura	7*7.79 QRPP	50	40	903690	Engine problem