

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 27-Sep-17

Page -2

| Name of Power Station | Unit | Producer | Present Generation Capacity | Peak Hour Generation | Energy Generated | Remarks |
|-------------------------------------|--------------|----------------|-----------------------------|----------------------|------------------|--------------------|
| | | | MW | MW | KWHR | |
| 1a Ghorasal ST: Unit-1, 2 | 2*55 | PDB | 85 | 35 | 1074000 | |
| 1b Ghorasal ST: Unit-3 | 1*210 | PDB | 170 | 0 | 0 | Under maint. |
| 1c Ghorasal ST: Unit-4 | 1*210 | PDB | 180 | 120 | 2726325 | Gas shortage |
| 1d Ghorasal ST: Unit-5 | 1*210 | PDB | 190 | 0 | 0 | Under Maint. |
| 1e) Ghorasal ST: Unit-7 | | PDB | | 200 | | On test. |
| 2 Ghorashal 100MW(Agreko) | 128*0.85 | QRPP | 100 | 12 | 301970 | Gas shortage |
| 3 Ghorashal 45MW(Agreko) | 58*0.85 | QRPP | 45 | 45 | 1100050 | |
| 4 Ghorashal 78.5 MW (MAX) | 4*21.5 | QRPP | 78 | 0 | 0 | Gas shortage |
| 5 Ghorashal (Regent) | 34*3.35 | IPP | 108 | 85 | 1859863 | Gas shortage |
| 6 Haripur GT: Unit-1, 2 | 1*32 | PDB | 20 | 0 | 0 | Under maint. |
| | 1*32 | PDB | 20 | 0 | 0 | Gas shortage |
| 7 Haripur EGCB 412 MW CCPP | 1*273+1*139 | EGCB | 412 | 412 | 9864000 | |
| 8 Haripur NEPC(HFO) | 8*15 | IPP | 110 | 68 | 1376300 | Engine problem |
| 9 Haripur Power CCPP | 1*235+1*125 | IPP | 360 | 242 | 5810000 | Gas shortage |
| 10 Meghnaghat CCPP | 2*150+1*150 | IPP | 450 | 410 | 9577202 | Gas shortage |
| 11 Meghnaghat (JEL) | 12*8.9 | RPP | 100 | 92 | 2005440 | Engine problem |
| 12 Meghnaghat CCPP(Summit) | 2*110+1*110 | IPP | 305 | 145 | 3278545 | GT-1 under maint. |
| 13 Madanganj (Summit) | 6*17 | QRPP | 100 | 101 | 1907160 | |
| 14 Madanganj-55 MW | 5*17.08+1*11 | IPP | 55 | 40 | 997353 | Engine problem |
| 15 Keraniganj (Powerpac) | 8*13.45 | RPP | 100 | 90 | 1990839 | Engine problem |
| 16 Narsingdi (Doreen) | 8 * 2.9 | SIPP, REB | 22 | 22 | 373896 | |
| 17 Siddhirgonj ST | 1*210 | PDB | 115 | 0 | 0 | Gas shortage |
| 18 Siddhirgonj GT : Unit-1 & 2 | 2*105 | EGCB | 210 | 30 | 864000 | Gas shortage |
| 19 Siddhirgonj (Desh) | 96*1.2 | QRPP | 100 | 53 | 951360 | Engine problem |
| 20 Siddhirgonj (Dutch Bangla) | 12*8.9 | RPP | 100 | 83 | 1927680 | Engine problem |
| Siddhirgonj CCPP-335 MW | | EGCB | | 0 | 0 | On test. |
| 21 Pagla (DPA) | 100*0.5 | QRPP | 50 | 51 | 862620 | |
| 22 Gagnagar (Orion) | 12*8.924 | IPP | 102 | 92 | 2032704 | Engine problem |
| 23 Katpotti 52 MW | | RPP | 51 | 38 | 727200 | Engine problem |
| 24 Kodda Peaking | 9*17.06 | BPDB-RPCL | 149 | 149 | 3429600 | |
| 25 Northern 55 MW | | RPP | 55 | 56 | 1313516 | |
| 26 Southern Power | | RPP | 55 | 55 | 1258039 | |
| 27 CLCPC Keranigonj 108 MW | | | 108 | 81 | 1821120 | Engine problem |
| 28 Summit Power, (Madhabdi+Ashulia) | 6*3.67+7*8.7 | SIPP, REB | 80 | 58 | 1354740 | Engine problem |
| 29 Summit Power, Maona | 4*8.73 | SIPP, REB | 33 | 33 | 765300 | |
| 30 Summit Power, Rugganj | 4*8.74 | SIPP, REB | 33 | 33 | 688100 | |
| 31 Gazipur (RPCL) | 6*8.9 | IPP | 52 | 42 | 896928 | Engine problem |
| 32 Tongi GT | 1*105 | PDB | 105 | 0 | 0 | Under maintenance. |
| Dhaka Area Total | | | 4408 | 2973 | 63135850 | |
| 33 a) Chitagong ST:Unit-1 | 1*210 | PDB | 180 | 0 | 0 | Gas shortage |
| b) Chitagong ST:Unit-2 | 1*210 | PDB | 180 | 0 | 0 | Gas shortage |
| 34 Raozan 25 MW (RPCL) | 3*8.9 | IPP | 25 | 26 | 540900 | |
| 35 Patenga 50 MW(Barakatulla) | 8*6.89 | IPP | 50 | 42 | 852960 | Engine problem |
| 36 Chittagong ECPV 108 MW | | IPP | 108 | 98 | 2210880 | Engine problem |
| 37 Karnafuli Hydro Power Station | 1*40 | PDB | 40 | 39 | 2696509 | |
| | 1*40 | PDB | 40 | 40 | | |
| | 1*50 | PDB | 50 | 41 | | |
| | 1*50 | PDB | 50 | 50 | 1178500 | |
| | 1*50 | PDB | 50 | 0 | | Under maint. |
| 38 Shikalbaha ST | 1*60 | PDB | 40 | 0 | 0 | Under maint. |
| Shikalbaha 225 MW | | PDB | | 169 | 4081941 | |
| 39 Shikalbaha peaking GT | 1*150 | PDB | 150 | 135 | 1797241 | |
| 40 Hathazari peaking | 11*8.9 | PDB | 98 | 85 | 893400 | |
| 41 Dohazari-Kalaish peaking | 6*17 | PDB | 102 | 85 | 1050951 | |
| 42 Juidah (Acorn) | 8*13.45 | QRPP | 100 | 68 | 1575120 | Engine problem |
| 43 Shikalbaha (Energis) | | RPP | 51 | 42 | 854880 | Engine problem |
| 44 Barabkunda (regent) | 8*2.90 | SIPP, PDB | 22 | 20 | 452400 | |
| * Malancha, Ctg EPZ(United) | | | | 5 | 255360 | |
| Chittagong Area Total | | | 1336 | 945 | 18441042 | |
| 45 a) Ashuganj ST: Unit- 2 | 1*64 | APSCl | 53 | 50 | 1222410 | |
| b) Ashuganj ST: Unit- 3 | 1*150 | APSCl | 135 | 140 | 3390898 | Under maint. |
| c) Ashuganj ST: Unit- 4 | 1*150 | APSCl | 129 | 150 | 3601780 | |
| d) Ashuganj ST: Unit- 5 | 1*150 | APSCl | 134 | 135 | 3235814 | |
| 46 Ashuganj CCPP 225 MW | 1*142+1*75 | APSCl | 221 | 0 | 0 | Under maint. |
| 47 Ashuganj CCPP(North) | | APSCl | 360 | 250 | 7448800 | Gas shortage |
| 48 Ashuganj CCPP(South) | | APSCl | 360 | 0 | 0 | Under maint. |
| 49 Ashuganj-Engines | 14*3.968 | APSCl | 45 | 43 | 933408 | |
| 50 Ashuganj (Precision) | 15*4 | RPP | 55 | 52 | 1190400 | |
| 51 Ashuganj (Aggrekko) | 82*1.1 | RPP | 0 | 0 | 0 | Date expired |
| 52 Ashuganj (United) | 14*4 | RPP | 53 | 53 | 1077000 | |
| 53 Ashuganj Modular 200 MW | 20*9.7+1*16 | IPP | 195 | 191 | 4533091 | |
| 54 Ashuganj (Midland) | 6*9.34 | IPP | 51 | 51 | 835496 | |
| 55 Brahmanbaria (Aggrekko) | 72*1.1 | QRPP | 85 | 85 | 1880177 | |
| 56 Titas (Daudkandi) Peaking | 6 * 8.92 | PDB | 52 | 48 | 775608 | |
| 57 Chandpur CCPP | 1*106+1*57 | PDB | 163 | 90 | 2155780 | Gas shortage |
| 58 Feni(Doreen) | 8 *2.94 | SIPP, PDB | 22 | 22 | 496044 | |
| 59 Feni Mohipal (Doreen) | 4*2.9 | SIPP, REB | 11 | 11 | 222660 | |
| ** Tripura | | | 100 | 138 | 2707200 | |
| 60 Jangalia (Summit) | 4*8.73 | SIPP, PDB | 33 | 33 | 812300 | |
| 61 Lakdanavi-52 MW | | IPP | 52 | 34 | 702202 | Engine problem |
| 62 Summit Power,Comilla | 3*3.67+2*6.9 | SIPP, REB | 25 | 22 | 489560 | |
| Comilla Area Total | | | 2334 | 1598 | 37710628 | |
| 63 RPCL CCPP | 4*35+1*70 | IPP | 202 | 105 | 2189280 | Gas shortage |
| 64 Tangali (Doreen) | 8 *2.9 | SIPP,PDB | 22 | 22 | 508968 | |
| 65 Jamalpur RPP | | IPP | 95 | 95 | 2282040 | |
| 66 Sarisha Solar Plant | 1*3 | IPP | 3 | 0 | 8509 | |
| Mymensingh Area Total | | | 322 | 222 | 4880288 | |
| 67 Fenchugonj CCPP-1 | 2*32+1*33 | PDB | 70 | 70 | 1583000 | |
| 68 Fenchugonj CCPP-2 | 2*35+1*35 | PDB | 90 | 61 | 1453020 | |
| 69)Kushlira 163 MW Fenchugonj | 1*109 | IPP | 109 | 109 | 2478354 | |
| 70 Shahjibazar CCPP 330 MW | 2*110 | PDB | 330 | 327 | 7604967 | |
| 71 Fenchugonj RPP (51 MW) | 2.9*19 | RPP | 51 | 47 | 991200 | |
| 72 Fenchugonj (Energyprima) | 12*3.3+5*2 | RPP | 44 | 49 | 1115000 | |
| 73 Hobiganj (Confidence-EP) | 4*2.9 | SIPP, REB | 11 | 8 | 104544 | Engine problem |
| 74 Shahjibazar GT: Unit-8,9 | 32*2.9 | PDB | 66 | 66 | 1285000 | |
| 75 Shahjibazar (Shahjibazar) | 32*2.9 | RPP | 86 | 86 | 2000040 | |
| 76 Shahjibazar (Energyprima) | 27*2.0 | RPP | 50 | 47 | 1100520 | |
| 77 Sylhet 150 MW GT | 1*142 | PDB | 142 | 109 | 2601570 | Gas shortage |
| 78 Sylhet 20 MW GT | 1*20 | PDB | 20 | 18 | 437000 | |
| 79 Sylhet (Energyprima) | 27 * 2.0 | RPP | 0 | 0 | 0 | Date expired |
| 80 Shahjahanulla 25MW | 3 * 9.34 | CIPP,REB | 25 | 8 | 527136 | |
| 81 Summit Bibiana-2 | 1*222+1*119 | IPP | 341 | 245 | 6580630 | FGMO |
| 82 Sylhet (Desh) | 6*1.95 | RPP | 10 | 7 | 168120 | Engine problem |
| Sylhet Area Total | | | 1445 | 1257 | 30030101 | |
| 83 Bheramara GT: Unit-1,2,3 | 1*20 | PDB | 16 | 16 | 483584 | |
| | 1*20 | PDB | 14 | 14 | | |
| | 1*20 | PDB | 16 | 16 | | |
| **Bheramara Interconnector(HVDC) | | Imported Power | 500 | 485 | 11509090 | |
| 84 Khulina (KPCL-1) | 19*6.5 | IPP | 110 | 94 | 2021280 | Engine problem |
| 85 Khulina (KPCL-2) | 7*17 | QRPP | 115 | 115 | 2522880 | |
| 86 Faridpur Peaking | 8*6.89 | PDB | 54 | 35 | 849440 | |
| 87 Khulina 150 MW GT | 1*150 | NWZPGCL | 230 | 235 | 5217600 | |
| 88 Gopalganj Peaking | 16*6.98 | PDB | 109 | 54 | 520400 | |
| 89 Bheramara 360 MW | 1*280+1*140 | NWZPGCL | 278 | 95 | 2151936 | On test |
| 90 Noapara (Khanjahan Ali) | 5*8.5 | QRPP | 40 | 40 | 811875 | |
| 91 Khulina (Aggreko) 55MW | 71*0.85 | QRPP | 55 | 46 | 904310 | Engine problem |
| Khulina Area Total | | | 1537 | 1245 | 28792389 | |
| 92 Summit Barisal 110MW | 7*17.076 | IPP | 110 | 110 | 2651520 | |
| 93 Barisal GT: Unit-1,2 | 1*20 | PDB | 16 | 0 | 96923 | |
| | 1*20 | PDB | 14 | 10 | | |
| 84)Bhola (Venture) | 1*34.5 | RPP | 33 | 31 | 916600 | |
| 95 Bhola CCPP GT-1,2,ST | 2*63+1*68 | PDB | 194 | 174 | 4302346 | |
| Barisal Area Total | | | 367 | 325 | 7867389 | |
| 96 a) Baghabari GT | 1*71 | PDB | 71 | 0 | 0 | Under maint. |
| b) Baghabari GT | 1*100 | PDB | 100 | 0 | 0 | Under maint. |
| 97 Baghabari Peaking | 6*8.9 | PDB | 52 | 40 | 805608 | |
| 98 Bera Peaking | 9*8.29 | PDB | 71 | 49 | 1032226 | |