

**EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

| Date :                       |                                | 25-Oct-17    |                             | Page -2              |                  |                  |                       |
|------------------------------|--------------------------------|--------------|-----------------------------|----------------------|------------------|------------------|-----------------------|
| Name of Power Station        | Unit                           | Producer     | Present Generation Capacity | Peak Hour Generation | Energy Generated | Remarks          |                       |
|                              |                                |              | MW                          | MW                   | KW-Hr            |                  |                       |
| 1a                           | Ghorasal ST: Unit-1, 2         | 2*55         | PDB                         | 85                   | 35               | 818000           |                       |
| 1b                           | Ghorasal ST: Unit-3            | 1*210        | PDB                         | 170                  | 170              | 4103820          |                       |
| 1c                           | Ghorasal ST: Unit-4            | 1*210        | PDB                         | 180                  | 0                | 0                | Under maint.          |
| 1d                           | Ghorasal ST: Unit-5            | 1*210        | PDB                         | 190                  | 0                | 0                | Under maint.          |
| 1e                           | Ghorasal ST: Unit-7            |              | PDB                         | 0                    | 0                | 0                | On test.              |
| 2                            | Ghorashal 100MW(Agreko)        | 128*0.85     | QRPP                        | 100                  | 101              | 1609280          |                       |
| 3                            | Ghorashal 45MW(Agreko)         | 58*0.85      | QRPP                        | 45                   | 46               | 996020           |                       |
| 4                            | Ghorashal 78.5 MW (MAX)        | 42*1.5       | QRPP                        | 78                   | 0                | 0                | Under maint.          |
| 5                            | Ghorashal (Regent)             | 34*3.35      | IPP                         | 108                  | 74               | 1432272          | Gas shortage          |
| 6                            |                                | 1*32         | PDB                         | 20                   | 0                | 0                | Under maint.          |
|                              | Haripur GT: Unit-1, 2          | 1*32         | PDB                         | 20                   | 0                | 0                | Gas shortage          |
| 7                            | Haripur EGCB 412 MW CCPP       | 1*273+1*135  | EGCB                        | 412                  | 420              | 9247000          |                       |
| 8                            | Haripur NEPC(HFO)              | 8*15         | IPP                         | 110                  | 83               | 356000           | Engine problem        |
| 9                            | Haripur Power CCPP             | 1*235+1*125  | IPP                         | 360                  | 333              | 7635000          | Gas shortage          |
| 10                           | Meghnaghat CCPP                | 2*150+1*155  | IPP                         | 450                  | 450              | 9470989          |                       |
| 11                           | Meghnaghat (REL)               | 1*12*8.9     | RPP                         | 100                  | 96               | 1142400          |                       |
| 12                           | Meghnaghat CCPP(Summit)        | 2*110+1*110  | IPP                         | 305                  | 230              | 5285149          | Low demand            |
| 13                           | Madanganj (Summit)             | 6*17         | QRPP                        | 100                  | 98               | 865392           |                       |
| 14                           | Madanganj-55 MW                | 5*17.08+1*11 | IPP                         | 55                   | 55               | 976069           |                       |
| 15                           | Keraniganj (Powerpac)          | 8*13.45      | RPP                         | 100                  | 100              | 1089563          |                       |
| 16                           | Narsingdi (Doreen)             | 8*2.9        | SIPP, REB                   | 22                   | 19               | 421344           | Engine problem        |
| 17                           | Siddhirgonj ST                 | 1*210        | PDB                         | 115                  | 0                | 0                | Gas shortage          |
| 18                           | Siddhirgonj GT: Unit-1 & 2     | 2*105        | EGCB                        | 210                  | 57               | 1064000          | Gas shortage          |
| 19                           | Siddhirgonj (Desh)             | 98*1.2       | QRPP                        | 100                  | 60               | 203520           | Low demand            |
| 20                           | Siddhirgonj (Dutch Bangla)     | 12*8.9       | RPP                         | 100                  | 83               | 1100160          | Engine problem        |
|                              | Siddhirgonj CCPP-335 MW        |              | EGCB                        | 0                    | 0                | 0                | On test.              |
| 21                           | Pagla (DPA)                    | 100*0.5      | QRPP                        | 50                   | 51               | 757930           |                       |
| 22                           | Gagnagar (Orion)               | 12*8.924     | IPP                         | 102                  | 92               | 1103184          | Engine problem        |
| 23                           | Katpotti 52 MW                 |              | RPP                         | 51                   | 20               | 92784            | Engine problem        |
| 24                           | Kodda Peaking                  | 9*17.06      | BPDB-RPCB                   | 149                  | 133              | 2564160          | Engine problem        |
| 25                           | Northern 55 MW                 |              | RPP                         | 55                   | 55               | 873577           |                       |
| 26                           | Southern Power                 |              | RPP                         | 55                   | 55               | 1020000          |                       |
| 27                           | CLPCP Keraniganj 108 MW        |              | RPP                         | 108                  | 50               | 549120           | Engine problem        |
| 28                           | Summit Power (Madhabdi+Ashula) | 3*3.67+7*8.7 | SIPP, REB                   | 80                   | 58               | 1329180          | Engine problem        |
| 29                           | Summit Power, Maona            | 4*8.73       | SIPP, REB                   | 33                   | 33               | 818500           |                       |
| 30                           | Summit Power, Rugganj          | 4*8.74       | SIPP, REB                   | 33                   | 33               | 839500           |                       |
| 31                           | Gazipur (RPCL)                 | 6*8.9        | IPP                         | 52                   | 42               | 932472           | Engine problem        |
| 32                           | Tongi GT                       | 1*105        | PDB                         | 105                  | 0                | 0                | Under maintenance.    |
| <b>Dhaka Area Total</b>      |                                |              |                             | <b>2468</b>          | <b>3132</b>      | <b>58095495</b>  |                       |
| 33 a)                        | Chittagong ST: Unit-1          | 1*210        | PDB                         | 180                  | 0                | 0                | Gas shortage          |
| 33 b)                        | Chittagong ST: Unit-2          | 1*210        | PDB                         | 180                  | 0                | 0                | Gas shortage          |
| 34                           | Raozan 25 MW (RPCL)            | 3*8.9        | IPP                         | 25                   | 26               | 474120           |                       |
| 35                           | Patenga 50 MW (Barakatulla)    | 8*6.89       | IPP                         | 50                   | 20               | 404640           | Engine problem        |
| 36                           | Chittagong ECPV 108 MW         |              | IPP                         | 108                  | 88               | 1561920          | Engine problem        |
| 37                           |                                | 1*40         | PDB                         | 40                   | 40               | 2842255          |                       |
|                              |                                | 1*40         | PDB                         | 40                   | 40               |                  |                       |
|                              |                                | 1*50         | PDB                         | 50                   | 44               |                  |                       |
|                              |                                | 1*50         | PDB                         | 50                   | 50               | 1186900          |                       |
|                              |                                | 1*50         | PDB                         | 50                   | 0                | 0                | Under maint.          |
| 38                           | Shikalbaha ST                  | 1*60         | PDB                         | 40                   | 0                | 0                | Under maint.          |
|                              | Shikalbaha 225 MW              |              | PDB                         | 150                  | 160              | 3335500          |                       |
| 39                           | Shikalbaha peaking GT          | 1*150        | PDB                         | 150                  | 100              | 1609821          |                       |
| 40                           | Hathazari peaking              | 1*18.9       | PDB                         | 98                   | 68               | 374632           |                       |
| 41                           | Dohazari-Kalash peaking        | 6*17         | PDB                         | 102                  | 102              | 818588           |                       |
| 42                           | Juidah (Acom)                  | 8*13.45      | QRPP                        | 100                  | 75               | 1481280          | Engine problem        |
| 43                           | Shikalbaha (Energis)           |              | RPP                         | 51                   | 51               | 504960           |                       |
| 44                           | Barakunda (regent)             | 8*2.90       | SIPP, PDB                   | 22                   | 18               | 447740           |                       |
| **                           | Melancho, Ctr EPZ (United)     |              |                             |                      |                  | 467040           |                       |
| <b>Chittagong Area Total</b> |                                |              |                             | <b>1336</b>          | <b>897</b>       | <b>15028398</b>  |                       |
| 45 a)                        | Ashuganj ST: Unit- 2           | 1*64         | APSCL                       | 53                   | 25               | 585738           |                       |
|                              |                                | 1*64         | APSCL                       | 0                    | 0                | 0                | Under maint.          |
| b)                           | Ashuganj ST: Unit- 3           | 1*150        | APSCL                       | 135                  | 100              | 2837282          | Line O/L              |
| c)                           | Ashuganj ST: Unit- 4           | 1*150        | APSCL                       | 129                  | 120              | 3077345          | Line O/L              |
| d)                           | Ashuganj ST: Unit- 5           | 1*150        | APSCL                       | 134                  | 135              | 3005400          |                       |
| 46                           | Ashuganj CCPP 225 MW           | 1*142+1*75   | APSCL                       | 221                  | 180              | 8333000          | FGMO                  |
| 47                           | Ashuganj CCPP(North)           |              | APSCL                       | 360                  | 230              | 1631300          | Synchronized at 16:03 |
| 48                           | Ashuganj CCPP(South)           |              | APSCL                       | 360                  | 361              | 4448700          |                       |
| 49                           | Ashuganj-Engines               | 14*3.968     | APSCL                       | 45                   | 43               | 990504           |                       |
| 50                           | Ashuganj (Precision)           | 15*4         | RPP                         | 55                   | 30               | 462720           | Line O/L              |
| 51                           | Ashuganj (Aggrekko)            | 82*1.1       | RPP                         | 0                    | 0                | 0                | Date expired          |
| 52                           | Ashuganj (United)              | 14*4         | RPP                         | 53                   | 5                | 185000           | Line O/L              |
| 53                           | Ashuganj Modular 200 MW        | 20*9.7+1*16  | IPP                         | 195                  | 75               | 1722909          | Line O/L              |
| 54                           | Ashuganj (Midland)             | 6*9.34       | IPP                         | 51                   | 5                | 198720           | Line O/L              |
| 55                           | Brahmanbaria (Aggreko)         | 72*1.1       | QRPP                        | 85                   | 86               | 815776           |                       |
| 56                           | Titas (Daudkandi) Peaking      | 6*8.92       | PDB                         | 52                   | 32               | 88848            |                       |
| 57                           | Chandpur CCPP                  | 1*106+1*57   | PDB                         | 163                  | 90               | 2134730          |                       |
| 58                           | Feni (Doreen)                  | 8*2.94       | SIPP, PDB                   | 22                   | 19               | 445752           |                       |
| 59                           | Feni Mohipal (Doreen)          | 4*2.9        | SIPP, REB                   | 11                   | 11               | 246240           |                       |
| **                           | Tripura                        |              |                             | 100                  | 148              | 2716800          | Low demand            |
| 60                           | Jangalia (Summit)              | 4*8.73       | SIPP, PDB                   | 33                   | 33               | 602800           |                       |
| 61                           | Lakdanavi-52 MW                |              | IPP                         | 52                   | 43               | 182160           | Engine problem        |
| 62                           | Summit Power, Comilla          | 3*3.67+2*6.5 | SIPP, REB                   | 25                   | 16               | 473880           |                       |
| <b>Comilla Area Total</b>    |                                |              |                             | <b>2334</b>          | <b>1797</b>      | <b>35125904</b>  |                       |
| 63                           | RPCL CCPP                      | 4*35+1*70    | IPP                         | 202                  | 106              | 2812520          | Gas shortage          |
| 64                           | Tangail (Doreen)               | 8*2.9        | SIPP, PDB                   | 22                   | 22               | 516024           |                       |
| 65                           | Jamalpur RPP                   |              | IPP                         | 95                   | 95               | 790536           |                       |
| 66                           | Sarisha Solar Plant            | 1*3          | IPP                         | 3                    | 0                | 8028             |                       |
| <b>Mymensingh Area Total</b> |                                |              |                             | <b>322</b>           | <b>223</b>       | <b>3519080</b>   |                       |
| 67                           | Fenchugonj CCPP-1              | 2*32+1*33    | PDB                         | 70                   | 70               | 1262000          |                       |
| 68                           | Fenchugonj CCPP-2              | 2*35+1*35    | PDB                         | 90                   | 61               | 1462960          |                       |
| 69                           | Kushiyara 163 MW Fenchugonj    | 1*109        | IPP                         | 109                  | 109              | 1704927          |                       |
| 70                           | Shahjibazar CCPP 330 MW        | 2*110        | PDB                         | 330                  | 80               | 1906992          | GT-2 S/D              |
| 71                           | Fenchugonj RPP (51 MW)         | 2*9*19       | RPP                         | 51                   | 47               | 561600           |                       |
| 72                           | Fenchugonj (Energyprima)       | 12*3.3+5*2   | RPP                         | 44                   | 49               | 632000           |                       |
| 73                           | Hobiganj (Confidence-EP)       | 4*2.9        | SIPP, REB                   | 11                   | 11               | 229488           | Frequency control.    |
| 74                           | Shahjibazar GT: Unit-8,9       | 32*2.9       | PDB                         | 66                   | 40               | 1184000          | Frequency control.    |
| 75                           | Shahjibazar (Shahjibazar)      | 32*2.9       | RPP                         | 86                   | 86               | 901440           |                       |
| 76                           | Shahjibazar (Energyprima)      | 27*2.0       | RPP                         | 50                   | 50               | 694080           |                       |
| 77                           | Sylhet 150 MW GT               | 1*142        | PDB                         | 142                  | 0                | 0                | Under maint.          |
| 78                           | Sylhet 20 MW GT                | 1*20         | PDB                         | 20                   | 19               | 446000           |                       |
| 79                           | Sylhet (Energyprima)           | 27*2.0       | RPP                         | 0                    | 0                | 0                | Date expired          |
| 80                           | Shahjahanulla 25MW             | 3*9.34       | CIPP, REB                   | 25                   | 23               | 568312           |                       |
| 81                           | Summit Bibiana-2               | 1*222+1*115  | IPP                         | 341                  | 260              | 6940300          | FGMO                  |
| 82                           | Sylhet (Desh)                  | 6*1.95       | RPP                         | 10                   | 9                | 217800           |                       |
| <b>Sylhet Area Total</b>     |                                |              |                             | <b>1445</b>          | <b>974</b>       | <b>18707859</b>  |                       |
| 83                           | Bheramara GT: Unit-1,2,3       | 1*20         | PDB                         | 16                   | 16               | 313344           |                       |
|                              |                                | 1*20         | PDB                         | 14                   | 0                | 0                |                       |
|                              |                                | 1*20         | PDB                         | 16                   | 0                | 0                |                       |
| **                           | Bheramara Interconnector(HVDC) |              | Imported Power              | 500                  | 484              | 11724363         |                       |
| 84                           | Khulna (KPCL-1)                | 19*6.5       | IPP                         | 110                  | 98               | 99312            | Engine problem        |
| 85                           | Khulna (KPCL-2)                | 7*17         | QRPP                        | 115                  | 99               | 2177280          | Engine problem        |
| 86                           | Faridpur Peaking               | 8*6.89       | PDB                         | 54                   | 41               | 252000           |                       |
| 87                           | Khulna 150 MW GT               | 1*150        | NWZPGCL                     | 230                  | 235              | 3579840          |                       |
| 88                           | Gopalganj Peaking              | 16*6.98      | PDB                         | 109                  | 52               | 68300            |                       |
| 89                           | Bheramara 360 MW               | 1*280+1*140  | NWZPGCL                     | 278                  | 102              | 2598336          | On test               |
| 90                           | Noapara (Khanjahan Ali)        | 5*8.5        | QRPP                        | 40                   | 40               | 322500           |                       |
| 91                           | Khulna (Aggreko) 55MW          | 71*0.85      | QRPP                        | 55                   | 41               | 133900           | Engine problem        |
| <b>Khulna Area Total</b>     |                                |              |                             | <b>1537</b>          | <b>1208</b>      | <b>21269175</b>  |                       |
| 92                           | Summit Barisal 110MW           | 7*17.076     | IPP                         | 110                  | 113              | 1800960          |                       |
| 93                           | Barisal GT: Unit-1,2           | 1*20         | PDB                         | 16                   | 14               | 69605            |                       |
|                              |                                | 1*20         | PDB                         | 14                   | 13               |                  |                       |
| 94                           | Bhola (Venture)                | 1*34.5       | RPP                         | 33                   | 30               | 550900           |                       |
| 95                           | Bhola CCPP GT-1,2,ST           | 2*63+1*68    | PDB                         | 194                  | 177              | 4577780          |                       |
| <b>Barisal Area Total</b>    |                                |              |                             | <b>367</b>           | <b>347</b>       | <b>6999245</b>   |                       |
| 96 a)                        | Baghabari GT                   | 1*71         | PDB                         | 71                   | 0                | 0                | Under maint.          |
| b)                           | Baghabari GT                   | 1*100        | PDB                         | 100                  | 0                | 0                | Under maint.          |
| 97                           | Baghabari Peaking              | 6*8.9        | PDB                         | 52                   | 32               | 355184           |                       |
| 98                           | Bera Peaking                   | 9*8.29       | PDB                         | 71                   | 48               | 587824           |                       |
| 99                           | Ammura                         | 7*7.79       | QRPP                        | 50                   | 50               | 875310           |                       |
| ##                           | Katakhal (Northern)            | 6*8.92       | QRPP                        | 50                   | 43               | 734992           | Engine problem        |
| ##                           | Katakhal Peaking               | 6*8.7        | PDB                         | 50                   | 32               | 434996           |                       |
| ##                           | Sirajganj CCPP                 | 1*50+1*75    | NWZPGCL                     | 210                  | 170              | 4389764          | Gas shortage          |
| ##                           | Santihar Peaking               | 6*8.9        | PDB                         | 50                   | 39               | 352906           |                       |
| ##                           | Bogra (GBB)                    | 6*4          | RPP                         | 22                   | 22               | 518160           |                       |
| ##                           | Bogra (Energyprima)            | 5*3.3+5*2    | RPP                         | 10                   | 14               | 331164           |                       |
| ##                           | Ullapara (Summit)              | 4*2.90       | SIPP, REB                   | 11                   | 11               | 207684           |                       |
| ##                           | Rajlanka 52 MW                 | 6*8.92       | IPP                         | 52                   | 43               | 729120           | Engine problem        |
| ##                           | Chapainawabganj-100 MW         | 12*8.942     | PDB                         | 104                  | 102              | 1122786          |                       |
| <b>Rajshahi Area Total</b>   |                                |              |                             | <b>803</b>           | <b>606</b>       | <b>10639850</b>  |                       |
| ##                           | a) Barapukuria ST: Unit-1      | 1*125        | PDB                         | 85                   | 0                | 0                | Under maint.          |
| ##                           | b) Barapukuria ST: Unit-2      | 1*125        | PDB                         | 85                   | 74               | 1776436          |                       |
| ##                           | Rangpur GT                     | 1*20         | PDB                         | 20                   | 15               | 84000            |                       |
| ##                           | Saidpur GT                     | 1*20         | PDB                         | 20                   | 19               | 123000           |                       |
| <b>Rangpur Area Total</b>    |                                |              |                             | <b>210</b>           | <b>108</b>       | <b>1983436</b>   |                       |
| <b>Total</b>                 |                                |              |                             | <b>12862</b>         | <b>9222</b>      | <b>172904120</b> |                       |
| <b>Eastern Grid Total</b>    |                                |              |                             | <b>8488</b>          | <b>6953</b>      | <b>132012374</b> |                       |
| <b>Western Grid Total</b>    |                                |              |                             | <b>2600</b>          | <b>2269</b>      | <b>40891746</b>  |                       |
| <b>National Grid Total</b>   |                                |              |                             | <b>11088</b>         | <b>9222</b>      | <b>172904120</b> |                       |