

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	67	1403000	
	Ghorasal ST: Unit-3	PDB	1*210	170	120	935550	Gas shortage
	Ghorasal ST: Unit-4	PDB	1*210	180	0	0	Gas shortage
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Gas shortage
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	365	8716863	
	Ghorasal 78MW (MAX)	QRPP	2*40	78	60	1248128	Gas shortage
4	Ghorasal (Regent)	IPP	3*43.35	108	64	1320409	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	350	8891610	Gas shortage
7	Haripur NEPC 110MW	IPP	8*15	110	110	1016700	
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	227	6236000	Gas shortage
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	340	7572188	Gas shortage
10	Meghnaghat (IEL)	QRPP	12*9	100	100	1504320	
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	200	5460451	Low demand
12	Madanganj 102MW	QRPP	6*17	100	81	1660944	Engine problem
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	1120755	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	50	1114303	Low demand
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	356076	Engine problem
16	Siddhirganj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirganj GT Unit-1 & 2	EGCB	2*105	210	190	4298000	Gas shortage
18	Siddhirganj (Desh)	QRPP	96*1.2	100	100	700800	
19	Siddhirganj (Dutch Bangla)	QRPP	12*8.9	100	100	1640842	
20	Siddhirganj CCPP-335 MW	EGCB	1*217	217	0	0	Machine problem.
21	Pagla (DPA)	QRPP	100*0.5	50	20	347820	Low demand
22	Gagnagar (Orion)	IPP	12*8.924	102	102	1285344	
23	Katpotti 51 MW	IPP	7*7.9	51	41	951840	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	966240	
25	Kodda 149 MW	BPDB-RPCL	9*17.06	149	149	2293920	
26	Northern 55 MW	IPP	3*19.3	55	55	1160419	
27	Southern 55MW	IPP	3*19.3	55	55	1177000	
28	Bosila 108MW	IPP	12*9.75+1*3.5	108	8	174720	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*8.67+4*8.73	80	57	1270720	Engine problem
30	Summit Maona	SIPP, REB	4*8.73	33	25	590595	Engine problem
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	836000	
32	Gazipur (RPCL)	IPP	6*8.9	52	51	976632	
33	Tongi GT	PDB	1* 105	105	0	0	Under maint.
34	Summit Gazipur	IPP	18*17.076	300	150	3822850	Machine problem.
	APR Energy, Keraniganj	IPP	236*1.4	0	0	0	On test
35	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	11	50438	Low demand
36	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	12	54970	Low demand
	Summit Gazipur-1. 150MW	IPP	149 MW	0	135	2594880	Engine problem
Dhaka area Total				5399	3557	73751327	
37	Chittagong ST-1 (Raozan)	PDB	1*210	180	0	0	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
38	Raozan 25 MW (RPCL)	IPP	3*8.9	25	16	315000	Engine problem
39	Patenga 50MW	IPP	8*6.98	50	44	945600	Engine problem
40	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	160	3771225	#3 Under maint.
41	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Gas shortage
42	Sikalbaha 225MW	PDB	1*150+1*175	225	200	4825445	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	100	1611270	
44	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	50	1054560	
45	Hathazari peaking	PDB	11*8.9	98	67	666736	
46	Dohazari Peaking	PDB	6*17	102	47	372585	
47	Juidah (Acom)	QRPP	8*13.45	100	80	1832400	Engine problem
48	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	19	442320	
*	Malancha, Ctg. EPZ (Uniled)		5*8.73+3*9.34	0	16	431520	
49	Chittagong ECPV 108 MW	IPP	16*7	108	106	1820160	
Chittagong area Total				1561	905	18088821	
50	Ashuganj ST: Unit- 3	APSCl	1*150	135	100	2600018	Gas shortage
	Ashuganj ST: Unit- 4	APSCl	1*150	129	100	1860260	Gas shortage
	Ashuganj ST: Unit- 5	APSCl	1*150	134	100	2394302	Gas shortage
51	Ashuganj CCPP 225 MW	APSCl	1*142+1*75	221	168	4537000	FGMO
52	Ashuganj CCPP(North)	APSCl	1*360	360	360	8917500	
53	Ashuganj CCPP(South)	APSCl	1*360	360	0	0	Under maint.
54	Ashuganj Engines TSK	APSCl	14*3.968	45	43	941040	
55	Ashuganj (Precision) 55MW	RPP	15*4	55	0	0	Under maint.
56	Ashuganj (Uniled) 53MW	QRPP	14*4	53	8	417000	Gas shortage
57	Ashuganj 195MW Modular	IPP	20*9.73+1*116	195	165	3629818	Gas shortage
58	Ashuganj (Midland) 51MW	IPP	6*9.34	51	47	967568	
59	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	1660944	
60	Daudkandi Peaking 52MW	PDB	6*8.92	52	50	286280	
61	Chandpur CCPP	PDB	1*106+1*57	163	100	2364510	
62	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	502524	
63	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	210420	Engine problem
**	Tripura	Imported power	0	160	166	3391680	
64	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	33	678200	
65	Lakdhanvi 52 MW	IPP	6*8.92	52	8	231878	Line load high
66	Summit Comilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	21	465100	Engine problem
67	Daudkandi bangla trak	IPP	15*1.4	200	10	53760	Low demand
Comilla Area Total				2541	1594	36109802	
68	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	71	1784640	Gas shortage
69	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	515916	
70	Jamalpur 95MW	IPP	12*8.924	95	95	1655040	
71	Sarishabari (Solar)	IPP	1*3	3	0	7350	
72	Uniled Mymensingh PPL	IPP	200	200	161	1636800	
Mymensingh Area Total				522	349	5599746	
73	Fenchugonj CCPP-1	PDB	2*32+1*33	70	70	1588000	
74	Fenchugonj CCPP-2	PDB	2*35+1*35	90	60	1441000	
75	Kushiarra 163 MW CCPP GT	IPP	1*109+1*54	163	163	3605187	
76	Shajibazar 330 MW	PDB	3*110	330	300	4748661	FGMO
77	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	1134600	
78	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	47	1072000	
79	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	238992	
80	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	58	1400000	FGMO
81	Shajibazar 86MW	RPP	32*2.90	86	86	1896000	
82	Shajibazar (EPL) 50MW	PDB	2*25	50	45	890280	Engine problem
83	Sylhet GT 150 MW	PDB	1*142	142	99	2597100	
84	Sylhet GT 20 MW	PDB	1*20	20	19	468000	
85	Sylhet (EPL) 50MW	RPP	27*2	50	47	1065160	
86	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	23	451800	
87	Summit Bibiana- 2	IPP	1*222+1*119	341	280	7499200	FGMO
88	Sylhet (Desh) 10MW	RPP	6*1.95	10	8	189180	Engine problem
Sylhet Area Total				1549	1369	30285160	
89	Bheramara GT-1,2,3	PDB	3*20	46	16	75600	Low demand
	Bheramara (HVDC)	Imported power	1*500	500	473	11452363	
90	Khulna (KPCL-1 & 3)	IPP	19*6.5	110	97	1064640	Engine problem
91	Khulna (KPCL-2)	QRPP	7*17	115	89	1343040	Engine problem
92	Faridpur Peaking	PDB	8*6.89	54	42	298080	
93	Khulna CCPP 225MW	NWPGL	1*150+1*75	230	220	3369600	
94	Gopalganj Peaking	PDB	16*6.98	109	63	417152	
95	Bheramara 360 MW	NWPGL	1*278+1*132	410	416	9907776	
96	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	735750	
97	Khulna (Aggreko) 55MW	QRPP	71*0.85	55	54	278770	
98	Bangla Trak Noapara	IPP	70*1.4	100	96	473280	
Khulna Area Total				1769	1606	29416051	
99	Summit Barisal 110 MW	IPP	7*17.076	110	110	1684800	
100	Barisal GT: Unit-1, 2	PDB	2*20	30	0	0	Reserve.
101	Bhola (Venture) 33MW	RPP	1*34.50	33	34	612123	
102	Bhola CCPP 194MW	PDB	2*63+1*68	194	158	4422127	
103	Bhola Aggreko 95MW	QRPP	96*1.10	95	95	2301239	
Barisal Area Total				462	397	9020289	
104	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
105	Baghabari Peaking 50MW	PDB	6*8.9	52	43	318336	
106	Bera Peaking	PDB	9*8.29	71	31	215542	
107	Amnura 50MW	QRPP	7*7.9	50	40	971850	Engine problem
108	Katakhal (Northern)	QRPP	6*8.9	50	43	929344	Engine problem
109	Katakhal Peaking	PDB	6*8.7	50	38	395414	
110	Sirajgonj Unit-1 225MW	NWPGL	1*150+1*75	210	0	0	
111	Sirajgonj Unit-2 225MW	NWPGL	1*150+1*75	220	0	0	
112	Sirajgonj Unit-3 225MW	NWPGL	1*150+1*75	0	0	0	On test
113	Santalaha Peaking	PDB	6*8.7	60	28	337084	
114	Boogra (GBB)	RPP	6*4	22	22	516240	
115	Boogra (EPL)	RPP	5*3.3+5*2	10	9	217872	
116	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	197784	
117	Rajlanka 52 MW	IPP	6*8.92	52	52	710880	
118	Chapainawabganj-100 MW	PDB	12*8.924	104	100	1381250	
Rajshahi Area Total				1123	417	6191596	
118	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling
	Barapukuria Unit-2	PDB	1*125	85	0	0	Coal shortage
119	Barapukuria Unit-3	PDB	1*275	274	0	0	Coal shortage
120	Rangpur GT	PDB	1*20	20	8	106500	Machine problem.
121	Saidpur GT	PDB	1*20	20	10	142000	
Rangpur Area Total				484	18	248500	
Total				15410	10		