

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	37	924000	Unit-2 under maint.
	Ghorasal ST: Unit-3	PDB	1*210	170	125	2801295	Gas shortage
	Ghorasal ST: Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal ST: Unit-5	PDB	1*210	190	100	2299500	Gas shortage
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	120	2875000	Machine problem
3	Ghorasal 78MW (MAX)	IPDB	2*40	78	75	1611904	
4	Ghorasal (Regent)	IPDB	3*43.35	108	104	2157818	
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	20	486400	Unit-1 under maint.
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	345	8362630	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	353	8118000	
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	450	9701500	
10	Meghnaghat (IEL)	QRPP	12*9	100	100	595200	
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	64	477744	Engine problem
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	47	472573	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	50	303529	Low demand
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	464832	
16	Siddhirgonj ST 210MW	PDB	1*210	115	100	2428650	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	180	3416000	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	100	611360	
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	217	4907784	
21	Pagla (DPA )	QRPP	100*0.5	50	0	0	Reserve
22	Gagnagar (Orion)	IPP	12*8.924	102	32	278928	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	40	774576	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	577800	
25	Kodda 149 MW	BPDB-RPCL	9*17.06	149	0	20640	Reserve
26	Northern 55 MW	IPP	3*19.3	55	56	807142	
27	Southern 55MW	IPP	3*19.3	55	55	997000	
28	Bosila 108MW	IPP	12*8.775+1*3.5	108	0	0	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP REB	3*8.67+4*8.73	80	43	1050900	Engine problem
30	Summit Maona	SIPP REB	4*8.73	33	33	784200	
31	Summit Rugganj	SIPP REB	4*8.73	33	28	740800	Engine problem
32	Gazipur (RPCL)	IPP	6*8.9	52	8	201300	Low demand
33	Tongi GT	PDB	1* 105	105	0	0	Under maint.
34	Summit Gazipur	IPP	18*17.076	300	258	3763635	Low demand
	APR Energy , Keraniganj	IPP	236*1.4	300	0	0	Reserve
35	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
36	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
	Summit Gazipur-1. 150MW	IPP	149 MW	149	139	2315520	Engine problem
<b>Dhaka area Total</b>				<b>5848</b>	<b>3355</b>	<b>65328160</b>	
37	Chittagong ST-1 (Raozan)	PDB	1*210	180	0	0	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
38	Raozan 25 MW (RPCL)	IPP	3*8.9	25	16	306540	Engine problem
39	Patenga 50MW	IPP	8*6.98	50	50	1079040	
40	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	202	4511418	
41	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
42	Sikalbaha 225MW	PDB	1*150+1*175	225	204	4815885	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	50	1376192	Low demand
44	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	42	1033920	
45	Hathazari peaking	PDB	11*8.9	98	67	502566	
46	Dohazari Peaking	PDB	6*17	102	49	582825	
47	Juidah (Acom)	QRPP	8*13.45	100	80	1770120	Engine problem
48	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	19	460027	
*	Malancha, Ctg. EPZ (Uniled)		5*8.73+3*9.34	0	36	584160	
49	Chittagong ECPV 108 MW	IPP	16*7	108	93	1745280	Engine problem
<b>Chittagong area Total</b>				<b>1561</b>	<b>908</b>	<b>18815663</b>	
50	Ashuganj ST: Unit- 3	APSCl	1*150	135	100	2451728	Gas shortage
	Ashuganj ST: Unit- 4	APSCl	1*150	129	90	2305535	Gas shortage
	Ashuganj ST: Unit- 5	APSCl	1*150	134	0	0	Under maint.
51	Ashuganj CAPP 225 MW	APSCl	1*142+1*75	221	190	4506000	FGMO
52	Ashuganj CAPP(North)	APSCl	1*360	360	360	8966100	
53	Ashuganj CAPP(South)	APSCl	1*360	360	261	6849000	FGMO
54	Ashuganj Engines TSK	APSCl	14*3.968	45	30	793844	
55	Ashuganj (Precision) 55MW	RPP	15*4	55	10	272640	Gas shortage
56	Ashuganj (Uniled) 53MW	QRPP	14*4	53	5	120000	Gas shortage
57	Ashuganj 195MW Modular	IPP	20*9.73+1*116	195	78	1890182	Gas shortage
58	Ashuganj (Midland) 51MW	IPP	6*9.34	51	45	814440	Engine problem
59	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	477744	
60	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	0	Reserve
61	Chandpur CAPP	PDB	1*106+1*57	163	100	2331330	
62	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	457848	
63	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	238500	
**	Tripura	Imported power	0	160	150	3013440	
64	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	33	698800	
65	Lakdhanvi 52 MW	IPP	6*8.92	52	16	129202	Low demand
66	Summit Comilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	21	514190	
67	Daudkandi bangla trak	IPP	15*1.4	200	0	0	Reserve
<b>Comilla Area Total</b>				<b>2541</b>	<b>1607</b>	<b>36830623</b>	
68	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	156	3474800	
69	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	499068	
70	Jamalpur 95MW	IPP	12*8.924	95	90	757440	Engine problem
71	Sarishabari (Solar)	IPP	1*3	3	0	12550	
72	Uniled Mymensingh PPL	IPP	200	200	175	3444400	Engine problem
<b>Mymensingh Area Total</b>				<b>522</b>	<b>443</b>	<b>8188258</b>	
73	Fenchugonj CAPP-1	PDB	2*32+1*33	70	58	1342000	
74	Fenchugonj CAPP-2	PDB	2*35+1*35	90	62	1116120	
75	Kushiar 163 MW CAPP GT	IPP	1*109+1*54	163	163	3255921	
76	Shajibazar 330 MW	PDB	3*110	330	191	4570926	ST Under maint.
77	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	31	456000	Engine problem
78	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	47	775000	
79	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	264000	
80	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	57	1353000	
81	Shajibazar 86MW	RPP	32*2.90	86	86	1448440	
82	Shajibazar (EPL) 50MW	PDB	27*2.0	50	44	875180	
83	Sylhet GT 150 MW	PDB	1*142	142	80	2192670	frequency control.
84	Sylhet GT 20 MW	PDB	1*20	20	19	275000	
85	Sylhet (EPL) 50MW	RPP	27*2	50	48	954600	
86	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	16	531528	
87	Summit Bibiana- 2	IPP	1*222+1*119	341	290	69152500	FGMO
88	Sylhet (Desh) 10MW	RPP	6*1.95	10	9	215640	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>1212</b>	<b>88775505</b>	
89	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
	Bheramara (HVDC)	Imported power	1*500	500	490	11574545	
90	Khulna (KPCL-1 & 3)	IPP	19*6.5	110	92	981600	Engine problem
91	Khulna (KPCL-2)	QRPP	7*17	115	99	1895040	Engine problem
92	Faridpur Peaking	PDB	8*6.89	54	38	411360	
93	Khulna CAPP 225MW	NWPGL	1*150+1*75	230	0	0	Reserve
94	Gopalganj Peaking	PDB	16*6.98	109	74	537984	
95	Bheramara 360 MW	NWPGL	1*278+1*132	410	414	9546912	
96	Noapara (KZA) 40MW	QRPP	5*8.5	40	0	327000	Engine problem
97	Khulna (Aggreko) 55MW	QRPP	71*0.85	55	0	0	Contract Expired
98	Bangla Trak Noapara	IPP	70*1.4	100	96	792960	Engine problem
<b>Khulna Area Total</b>				<b>1769</b>	<b>1303</b>	<b>26067401</b>	
99	Summit Barisal 110 MW	IPP	7*17.076	110	96	1896000	
100	Barisal GT: Unit-1, 2	PDB	2*20	30	24	141284	
101	Bhola (Venture) 33MW	RPP	1*34.50	33	39	701993	
102	Bhola CAPP 194MW	PDB	2*63+1*68	194	120	2859000	ST Under maint.
103	Bhola Aggreko 95MW	QRPP	96*1.10	95	96	2256694	
<b>Barisal Area Total</b>				<b>462</b>	<b>375</b>	<b>7854971</b>	
104	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
105	Baghabari Peaking 50MW	PDB	6*8.9	52	50	393536	
106	Bera Peaking	PDB	9*8.29	71	42	320771	
107	Amnura 50MW	QRPP	7*7.79	50	50	1129790	
108	Katakhal (Northern)	QRPP	6*8.9	50	50	1127896	
109	Katakhal Peaking	PDB	6*8.7	50	48	137355	
110	Sirajgonj Unit-1 225MW	NWPGL	1*150+1*75	210	218	0	
111	Sirajgonj Unit-2 225MW	NWPGL	1*150+1*75	220	220	0	
112	Sirajgonj Unit-3 225MW	NWPGL	1*150+1*75	0	0	0	On test
113	Santalaha Peaking	PDB	6*8.7	60	34	342205	
114	Bogra (GBS)	RPP	6*4	22	22	515280	
115	Ullapara (Summit)	SIPP, REB	5*3.3+5*2	10	10	238536	Engine problem
116	Rajlanka 52 MW	IPP	6*8.92	52	51	462720	
117	Chapainawabganj-100 MW	PDB	12*8.924	104	90	911184	Engine problem
<b>Rajshahi Area Total</b>				<b>1123</b>	<b>896</b>	<b>5912817</b>	
118	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling
	Barapukuria Unit-2	PDB	1*125	85	0	782836	S/D at 15:05 due to coal sho
119	Barapukuria Unit-3	PDB	1*275	274	0	0	Coal shortage
120	Rangpur GT	PDB	1*20	20	13	170000	
121	Saidpur GT	PDB	1*20	20	15	188000	
<b>Rangpur Area Total</b>				<b>484</b>	<b>28</b>	<b>1140836</b>	
<b>Total</b>				<b>15859</b>	<b>10127</b>	<b>258914234</b>	
Eastern Grid Total				12021	7525	217938209</	