

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	72	1554000	
	Ghorasal ST: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal ST: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	190	4473000	Gas shortage
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	380	8799072	
	Ghorasal 78MW (MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorashal (Regent)	IPP	3*43.35	108	0	0	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	370	8628490	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	110	868500	
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	356	8176000	
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	450	9696937	
10	Meghnaghat (IEL)	QRPP	12*9	100	100	1777920	
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	98	1920480	
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	1138313	
14	Keranganj (Powerpac) 100MW	QRPP	8*13.45	100	100	1521166	
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	415152	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Under maint.
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	0	0	Gas restriction
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	70	344640	Engine problem
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	75	1475520	Engine problem
20	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	0	0	Under maint.
21	Pagla (DPA)	QRPP	100*0.5	50	50	555300	
22	Gagnagar (Orion)	IPP	12*8.924	102	102	1603440	
23	Katpotti 51 MW	IPP	7*7.9	51	40	922992	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	598320	
25	Kodda 149 MW	BPDB-RPCL	9*17.06	149	149	1790880	
26	Northern 55 MW	IPP	3*19.3	55	55	1075283	
27	Southern 55MW	IPP	3*19.3	55	55	1224220	
28	Bosila 108MW	IPP	12*8.75+1*13.5	108	8	1057520	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*8.67+4*8.73	80	49	1057920	Engine problem
30	Summit Madona	SIPP, REB	4*8.73	33	33	828300	
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	774100	
32	Gazipur (RPCL)	IPP	6*8.9	52	49	806100	
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur	IPP	18*17.076	300	240	4952940	Engine problem
35	APR Energy , Keranigonj	IPP	236*1.4	300	234	645970	Low demand
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	50	239818	Low demand
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	101	434169	
38	Summit Gazipur-1. 150MW	IPP	149 MW	149	104	2278080	Engine problem
Dhaka area Total				5848	3854	70732542	
39	Chittagong ST-1 (Raozan)	PDB	1*210	180	120	3200000	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	130	3200000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	532620	
	Teknaf Solartech 20MW	Teknaf Solartech Ener	28MW	0	0	127290	
41	Patenga 50MW	IPP	8*6.98	50	44	1030560	Engine problem
42	Kaptal Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	143	3283553	Unit-5 under maint.
43	Sikalbaha ST 60MW	PDB	1*60	40	35	244750	
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
45	Sikalbaha Peaking GT	PDB	1*150	150	100	2699500	Gas shortage
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	50	1148160	
47	Hathazari peaking	PDB	1*8.9	98	80	1347344	
48	Hathazari Peaking	PDB	6*17	102	45	980810	
49	Juldah (Acorn)	QRPP	8*13.45	100	90	2114280	
50	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	19	465552	
*	Malancha, Ctg. EPZ (Uniled)		5*8.73+3*9.34	0	18	495840	
51	Chittagong ECPV 108 MW	IPP	16*7	108	92	2053440	Engine problem
Chittagong area Total				1561	991	22923699	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	100	2540702	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	90	2754950	Gas shortage
53	Ashuganj CCPP 225 MW	APSCL	1*142+1*75	221	165	4278000	FGMO
54	Ashuganj CCPP(North)	APSCL	1*360	360	360	7238800	
55	Ashuganj CCPP(South)	APSCL	1*360	360	301	7211000	
56	Ashuganj Engines TSK	APSCL	14*3.968	45	19	429696	Gas shortage
57	Ashuganj (Precision) 55MW	RPP	15*4	55	0	0	Under maint.
58	Ashuganj (Uniled) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	68	1756363	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	0	0	Under maint.
61	B Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	1920480	
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	41	272320	
63	Chandpur CCPP	PDB	1*106+1*57	163	126	2388890	
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	502848	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	250560	
**	Tripura	Imported power	0	160	170	3482880	
66	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	33	726500	
67	Lakdhanvi 52 MW	IPP	6*8.92	52	0	98078	Line O/L
68	Summit Cornilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	21	506580	Engine problem
69	Daudkandi bangla trak	IPP	154*1.4	200	150	238080	Low demand
Comilla Area Total				2541	1767	36716727	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	45	1114080	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	484210	
72	Jamalpur 95MW	IPP	12*8.924	95	57	993600	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	13050	
74	Uniled Mymensingh PPL	IPP	200	200	180	4099200	
Mymensingh Area Total				522	304	6704140	
75	Fenchugonj CCPP-1	PDB	2*32+1*33	70	56	1242000	
76	Fenchugonj CCPP-2	PDB	2*35+1*35	90	60	1427160	
77	Kushara 163 MW CCPP GT	IPP	1*109+1*54	163	100	3256298	Frequency Control.
78	Shajibazar 330 MW	PDB	3*110	330	300	7013214	FGMO.
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	44	1008600	
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	50	1127000	
81	Hobganj 11MW	SIPP, REB	4*2.90	11	11	251904	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	55	1490000	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	89	1781760	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	45	932040	Engine problem
85	Sylhet GT 150 MW	PDB	1*142	142	77	2126070	
86	Sylhet GT 20 MW	PDB	1*20	20	0	240000	
87	Sylhet (EPL) 50MW	RPP	27*2	50	42	980460	Engine problem
88	Shahjahanula 25 MW	SIPP, REB	3*9.34	25	16	525912	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	275	7410500	FGMO
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	9	217260	
Sylhet Area Total				1549	1229	31029178	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	770	18340364	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	110	102	1142400	Engine problem
93	Khulna (KPCL-2)	QRPP	7*17	115	98	1691520	Engine problem
94	Faridpur Peaking	PDB	8*6.89	54	37	244800	
95	Khulna CCPP 225MW	NWPQCL	1*150+1*75	230	200	3649920	Frequency Control.
96	Gopalganj Peaking	PDB	16*6.98	109	78	603392	
97	Bheramara 360 MW	NWPQCL	1*278+1*132	410	350	8212896	Gas restriction
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	32	589125	Engine problem
	Khulna (Aggreko) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	94	560640	
Khulna Area Total				2214	1761	35035057	
100	Summit Barisal 110 MW	IPP	7*17.076	110	110	2004000	
101	Barisal GT: Unit- 1, 2	PDB	2*20	30	26	98877	
102	Bhola (Venture) 33MW	RPP	1*34.50	33	35	699110	
103	Bhola CCPP 194MW	PDB	2*63+1*68	194	153	4236711	
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	96	2203259	
Barisal Area Total				462	420	9241957	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	400621	
107	Bera Peaking	PDB	9*8.29	71	53	396247	
108	Amnura 50MW	QRPP	7*7.79	50	50	852600	
109	Katakhal (Northern)	QRPP	6*8.9	50	50	1177632	
110	Katakhal Peaking	PDB	6*8.7	50	37	421665	
111	Sirajgonj Unit-1 225MW	NWPQCL	1*150+1*75	210	0	0	Gas restriction
112	Sirajgonj Unit-2 225MW	NWPQCL	1*150+1*75	220	135	0	FGMO.
113	Sirajgonj Unit-3 225MW	NWPQCL	1*150+1*75	141	0	0	On test
	Sirajgonj Unit-4 414 MW (Gas)	SNWPQCL	1*272+1*132 MW	0	298	7130000	On test
114	Santihar Peaking	PDB	6*8.7	50	0	130729	under maint.
115	Bogra (GBB)	RPP	6*4	22	22	514800	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	9	228420	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	10	219906	
118	Rajlanka 52 MW	IPP	6*8.92	52	52	809760	Engine problem
119	Chapainawabganj-100 MW	PDB	12*8.924	104	90	1103072	
Rajshahi Area Total				1264	856	13385452	
120	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling
	Barapukuria Unit-2	PDB	1*125	85	0	0	Coal shortage
121	Barapukuria Unit-3	PDB	1*275	274	184	4498500	
122	Rangpur GT	PDB	1*20	20	10	76000	
123	Saidpur GT	PDB</					