

Date : 1-Dec-18				Page -2			
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	67	1536000	
	Ghorasal GT: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal GT: Unit-4	PDB	1*210	180	0	203000	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Gas shortage
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	320	7452609	Gas shortage
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	81	1364160	
4	Ghorasal (Regent)	IPP	34*3.35	108	101	1261863	
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	355	8768510	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	321	7842000	Frequency control.
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	420	9244375	Frequency control.
10	Meghnaghat (IEL)	QRPP	12*8.9	100	7	20160	Low demand
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	70	197520	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	15	469976	Low demand
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	10	34000	
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	156096	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	102	1974000	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	7	16100	Low demand
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	228	3885750	
21	Pagla (DPA )	QRPP	100*0.5	50	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	102	439632	
23	Katpotti 51 MW	IPP	7*7.9	51	27	207552	
24	Banco Energy 54MW	IPP	3*18	54	54	469980	Low demand
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	10	26400	Low demand
26	Northern 55 MW	IPP	3*19.3	55	55	390591	
27	Southern 55MW	IPP	3*19.3	55	17	49000	Low demand
28	Bosila 108MW	IPP	12*8.775+1*3.5	108	83	359040	Engine problem
29	Summit Power,(Madhabdi+Ash)	SIPP,REB	3*3.67+4*8.73	80	40	960600	Engine problem
30	Summit Maona	SIPP,REB	4*8.73	33	33	817824	
31	Summit Rugganj	SIPP,REB	4*8.73	33	25	342100	Engine problem
32	Gazipur (RPCL)	IPP	6*8.9	52	43	487404	Engine problem
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	137	358799	Low demand
35	APR Energy . Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangoan 100 MW (Aggre)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1 150MW	IPP	149	149	47	257760	Engine problem
<b>Dhaka area Total</b>				<b>5848</b>	<b>2799</b>	<b>49592801</b>	
39	Chattoogram ST-1 (Raozan)	PDB	1*210	180	160	3800000	Gas shortage
	Chittogong ST-2 (Raozan)	PDB	1*210	180	0	100000	Gas shortage
40	Raazan 25 MW (RPCL)	IPP	3*8.9	25	25	121860	
	Teknaf Solartech 20MW	Teknaf Solartech Energ	20	20	0	1273305	Reserve
41	Patenga 50MW	IPP	8*6.98	50	12	54720	Low demand
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	40	894000	Unit-2,3,5 under maint.
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Combustion inspection.
45	Sikalbaha Peaking GT	PDB	1*150	150	130	3159942	FGMO
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*11	51	40	460800	Engine problem
47	Hathazari peaking	PDB	11*8.9	98	72	181024	
48	Dohazari Peaking	PDB	6*17	102	53	504969	
49	Julda (Acom)	QRPP	8*13.45	100	50	289200	Low demand
	Julda 100 MW Unit-3	IPP	0	0	0	0	On test
50	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	22	476256	
	* Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	25	400320	
51	Chattoogram ECPV 108 MW	IPP	16*7	108	55	380496	Low demand
<b>Chattoogram area Total</b>				<b>1581</b>	<b>684</b>	<b>12096892</b>	
52	Ashuganj ST: Unit- 3	APSCl	1*150	135	120	2679106	Gas shortage
	Ashuganj ST: Unit- 4	APSCl	1*150	129	80	2097740	Gas shortage
	Ashuganj ST: Unit- 5	APSCl	1*150	134	110	2915238	Gas shortage
53	Ashuganj CAPP 225 MW	APSCl	1*142+1*75	221	187	4953000	FGMO
54	Ashuganj CAPP(North)	APSCl	1*360	360	0	609700	Under maint.
55	Ashuganj CAPP(South)	APSCl	1*360	360	309	7803000	
56	Ashuganj Engines TSK	APSCl	14*3.968	45	40	747072	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	153120	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	25	652363	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	51	642545	
	Midland 150MW	IPP	23*7.015	0	0	0	On test
61	B Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	740218	
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	8520	Reserve
63	Chandpur CAPP	PDB	1*106+1*57	163	100	2364210	
	Chandpur Desh 200MW	IPP	0	0	172	931680	On Test
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	19	334692	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	160200	
**	Tripura	Imported power	0	160	112	1441920	
66	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	33	381700	
67	Lakdhanvi 52 MW	IPP	6*8.92	52	0	63283	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	22	317840	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2541</b>	<b>1486</b>	<b>29757147</b>	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	209	4959920	
71	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	378684	
72	Jamalpur 95MW	IPP	12*8.924	95	79	392640	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	12450	
74	United Mymensingh PPL	IPP	200	200	120	736800	Low demand
<b>Mymensingh Area Total</b>				<b>522</b>	<b>430</b>	<b>6480494</b>	
75	Fenchugonj CAPP-1	PDB	2*32+1*33	70	26	620000	
76	Fenchugonj CAPP-2	PDB	2*35+1*35	90	62	1500000	
77	Kushara 163 MW CAPP GT	IPP	1*109+1*54	163	163	3338345	
78	Shajibazar 330 MW	PDB	3*110	330	200	3101000	
79	Fenchugonj (Barakatalah) 51M	RPP	19*2.90	51	50	569400	
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	50	651000	
81	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	167184	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	66	1426000	
83	Shajibazar 86MW	RPP	32*2.90	86	50	524160	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	49	671400	
85	Sylhet GT 150 MW	PDB	1*142	142	130	2217520	
86	Sylhet GT 20 MW	PDB	1*20	20	20	313000	
87	Sylhet (EPL) 50MW	RPP	27*2	50	47	578040	
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	25	485832	
89	Summit Bibiana - 2	IPP	1*222+1*119	341	0	0	Under maint.
	Bibiyan-3 285MW	PDB	285 MW	0	0	0	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	171180	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>959</b>	<b>16340061</b>	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC )	Imported power	2*500	1000	460	9002909	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khulna (KPCL-2)	QRPP	7*17	115	16	49920	Low demand
94	Fariapur Peaking	PDB	8*6.89	54	4	69600	Low demand
95	Khulna CAPP 225MW	NWPGCL	1*150+1*75	230	0	126080	Reserve
96	Gopalganj Peaking	PDB	16*9.98	109	30	126080	Reserve
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	302	6877152	ST Under maint.
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	195750	
	Khulna (Aggreko) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	0	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	91	406080	
<b>Khulna Area Total</b>				<b>2209</b>	<b>943</b>	<b>16727491</b>	
100	Summit Barisal 110 MW	IPP	7*17.076	110	48	172800	Low demand
101	Barisal GT: Unit-1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	26	466200	Engine problem
103	Bhola CAPP 194MW	PDB	2*63+1*68	194	185	4325786	
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	76	752753	
<b>Barisal Area Total</b>				<b>462</b>	<b>335</b>	<b>5717539</b>	
105	Baghabari GT 71MW	PDB	1*71	71	70	1455000	
	Baghabari GT 100MW	PDB	1*100	100	0	0	Gas shortage
106	Baghabari Peaking 50MW	PDB	6*8.9	52	0	39808	Reserve
107	Bera Peaking	PDB	9*8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7*7.79	50	50	542100	
109	Katakhal (Northern)	QRPP	6*8.9	50	0	174462	Reserve
110	Katakhal Peaking	PDB	6*8.7	50	0	154726	Reserve
111	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	125	3318172	Gas shortage
112	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	125	3313564	Gas shortage
113	Sirajgonj Unit-3 225MW	NWPGCL	1*141	141	0	0	Gas shortage
	Sirajgonj Unit-4 414 MW(Gas)	NWPGCL	1*282	282	0	0	On test
114	Santahar Peaking	PDB	6*8.7	50	34	58131	
115	Bogra (GBB)	RPP	6*4	22	22	414960	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	5	38268	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	8	180288	
118	Rajlanka 52 MW	IPP	6*8.92	52	52	757920	
119	Chapainawabganj-100 MW	PDB	12*8.924	104	70	246168	Low demand
<b>Rajshahi Area Total</b>				<b>1546</b>	<b>561</b>	<b>10693567</b>	
120	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling