

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	38	889000	#2 under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal GT: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	120	2872800	Gas shortage
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	300	5437472	Gas shortage
3	Ghorashal 78MW (MAX)	QRPP	2*40	78	40	983136	Gas shortage
4	Ghorashal (Regent)	IPP	3*43.35	108	52	1120727	
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	348	8548360	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	367	7437000	
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	400	9076400	spinning reserve
10	Meghnaghat (IEL)	QRPP	12*9	100	0	25920	Reserve
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	30	79032	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	576437	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	0	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	258984	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	89	2636000	FGMO & Gas Shortage.
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	0	Reserve
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	120	3563328	Gas shortage
21	Pagla (DPA )	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	32	271440	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	47	194208	
24	Banco Energy 54MW	IPP	3*18	54	54	257760	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	0	136800	Reserve
26	Northern 55 MW	IPP	3*19.3	55	56	424531	
27	Southern 55MW	IPP	3*19.3	55	0	0	Reserve
28	Bosila 108MW	IPP	12*8.775+1*3.5	108	47	308160	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*9.73	80	47	1327380	Engine problem
30	Summit Masana	SIPP, REB	4*8.73	33	33	804520	
31	Summit Rugganj	SIPP, REB	4*8.73	33	25	613000	Engine problem
32	Gazipur (RPCL)	IPP	6*8.9	52	10	562308	Engine problem
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	55	114000	Low demand
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	48	784800	Low demand
<b>Dhaka area Total</b>				<b>5798</b>	<b>2432</b>	<b>49303503</b>	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	0	0	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	150	4200000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	230220	
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	58040	
41	Patenga 50MW	IPP	8*6.98	50	50	362880	
42	Kaptal Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	33	753000	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
45	Sikalbaha Peaking GT	PDB	1*150	150	120	2965542	Gas shortage
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	45	790080	Engine problem
47	Hathazari peaking	PDB	1*8.9	98	0	0	Reserve
48	Dohazari Peaking	PDB	6*17	102	68	319342	
49	Juidah (Acorn)	QRPP	8*13.45	100	46	230880	Low demand
	Juidah 100 MW Unit-3	IPP	0	100	100	1623360	
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	22	518976	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	24	264960	
51	Chattogram ECPV 108 MW	IPP	16*7	108	45	154560	Low demand
<b>Chattogram area Total</b>				<b>1681</b>	<b>728</b>	<b>12471840</b>	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	100	2275850	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	120	2364248	Gas shortage
53	Ashuganj CAPP 225 MW	APSCL	1*142+1*75	221	184	4581900	FGMO
54	Ashuganj CAPP(North)	APSCL	1*360	360	260	6238100	ST Under maint.
55	Ashuganj CAPP(South)	APSCL	1*360	360	305	7397500	FGMO
56	Ashuganj Engines TSK	APSCL	14*3.968	45	37	604944	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	153120	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	200727	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	51	680255	
	Midland 150MW	IPP	23*7.015	150	51	167270	On Test
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	79032	
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	6152	Reserve
63	Chandpur CAPP	PDB	1*106+1*57	163	95	2334370	ST Under maint.
	Chandpur Desh 200MW	IPP	0	200	70	953760	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	424548	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	203220	
**	Tripura	Imported power	0	160	116	2099520	
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	33	247500	
67	Lakdhanvi 52 MW	IPP	6*8.92	52	0	30768	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	22	467010	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1580</b>	<b>31628894</b>	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	158	3424400	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	318132	
72	Jamalpur 95MW	IPP	12*8.924	95	79	373440	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	11500	
74	United Mymensingh PPL	IPP	200	200	40	340800	Low demand
<b>Mymensingh Area Total</b>				<b>522</b>	<b>297</b>	<b>4468272</b>	
75	Fenchugonj CAPP-1	PDB	2*32+1*33	70	54	1305000	
76	Fenchugonj CAPP-2	PDB	2*35+1*35	90	68	1551960	
77	Kushara 163 MW CAPP GT	IPP	1*109+1*54	163	100	2835147	Machine problem
78	Shajibazar 330 MW	PDB	3*110	330	283	5732000	FGMO
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	609000	
80	Fenchugonj (EPL) 44MW	RPP	12*3.5+5*2	44	21	366000	Engine problem
81	Hobiganj 110MW	SIPP, REB	4*2.90	11	8	199344	Engine problem
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	50	1188000	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	86	730560	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	48	731880	
85	Sylhet GT 150 MW	PDB	1*142	142	80	2003730	Frequency Control.
86	Sylhet GT 20 MW	PDB	1*20	20	0	0	Under maint.
87	Sylhet (EPL) 50MW	RPP	27*2	50	47	651640	
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	25	423000	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	0	0	Under maint.
	Bibiyana-3 285MW	PDB	285 MW	0	0	0	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	9	34740	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>932</b>	<b>18362001</b>	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	658	11840727	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khulna (KPCL-2)	QRPP	7*17	115	49	235760	Low demand
94	Faridpur Peaking	PDB	8*6.89	54	36	145440	Low demand
95	Khulna CAPP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*6.98	109	40	251392	Low demand
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	312	6523776	ST Under maint.
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	456000	
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	0	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	91	447840	Low demand
<b>Khulna Area Total</b>				<b>2209</b>	<b>1226</b>	<b>19909935</b>	
100	Summit Barisal 110 MW	IPP	7*17.076	110	24	97920	Low demand
101	Barisal GT: Unit-1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	25	462000	Engine problem
103	Bhola CAPP 194MW	PDB	2*63+1*68	194	198	4453055	FGMO
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	98	843891	
<b>Barisal Area Total</b>				<b>462</b>	<b>345</b>	<b>5858866</b>	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Gas shortage
106	Baghabari Peaking 50MW	PDB	6*8.9	52	26	109536	Reserve
107	Bera Peaking	PDB	9*8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7*7.9	50	50	269940	
109	Katakhal (Northern)	QRPP	6*8.9	50	0	0	Reserve
110	Katakhal Peaking	PDB	6*8.7	50	0	0	Reserve
111	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
112	Sirajgonj Unit-3 225MW	NWPGCL	1*150+1*75	220	178	4149845	FGMO
113	Sirajgonj Unit-4 414 MW (Gas)	SNWPGCL	1*282	282	0	0	Gas shortage
114	Santahar Peaking	PDB	6*8.7	50	39	130604	
115	Bogra (GBB)	RPP	6*4	22	22	417360	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	5	90288	Engine problem
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	146952	
118	Rajlanka 52 MW	IPP	6*8.92	52	52	566880	
119	Chapainawabganj-100 MW	PDB	12*8.924	104	60	157504	Low demand
<b>Rajshahi Area Total</b>				<b>1546</b>	<b>443</b>	<b>6037109</b>	
120	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling</