

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
				Generation	Generation	Generated	
				MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	734000	#2 under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal GT: Unit-4	PDB	1*210	180	150	2820920	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	300	5786463	Frequency control
3	Ghorashal 78MW (MAX)	QRPP	2*40	78	20	360640	Gas shortage
4	Ghorashal (Regent)	IPP	34*3.35	108	12	368000	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	345	8130630	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CCGP 360MW	IPP	1*235+1*125	360	242	6014000	Frequency control
9	Meghnaghat CCGP 450MW	IPP	2*150+1*150	450	370	8600750	Frequency control
10	Meghnaghat (IEL)	QRPP	12*8.9	100	7	17280	Low demand
11	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	0	209760	Reserve
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	30	205940	Low demand
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	0	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	193176	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	150	2458000	FGMO
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	0	Reserve
20	Siddhirgonj CCGP-335 MW	EGCB	1*217	217	150	3235474	Gas shortage
21	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	7	164736	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	45	178704	
24	Banco Energy 54MW	IPP	3*18	54	55	254520	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	0	0	Reserve
26	Northern 55 MW	IPP	3*19.3	55	18	67127	Low demand
27	Southern 55MW	IPP	3*19.3	55	17	83783	Low demand
28	Bosila 108MW	IPP	12*8.775+1*3.5	108	47	163200	
29	Summit Power,(Madhabdi+Ashu)	SIPP,REB	3*3.67+4*8.73	80	57	1340880	
30	Summit Maona	SIPP,REB	4*8.73	33	25	734400	
31	Summit Rugganj	SIPP,REB	4*8.73	33	29	627700	
32	Gazipur (RPCL)	IPP	6*8.9	52	42	130908	Engine problem
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	45	100364	Low demand
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggre)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1 150MW	IPP	149	149	15	53930	Low demand
Dhaka area Total				5798	2235	43035285	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	0	0	Gas shortage
	Chittong ST-2 (Raozan)	PDB	1*210	180	120	2900000	Gas shortage
40	Raazan 25 MW (RPCL)	IPP	3*8.9	25	25	73260	
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	122580	
41	Patenga 50MW	IPP	8*6.98	50	27	68640	Low demand
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	40	768000	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
45	Sikalbaha Peaking GT	PDB	1*150	150	130	2677534	Gas shortage
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1	51	30	304800	Low demand
47	Hathazari peaking	PDB	11*8.9	98	0	0	Reserve
48	Dohazari Peaking	PDB	6*17	102	0	46344	Reserve
49	Juldah (Acom)	QRPP	8*13.45	100	25	46440	Low demand
	Juldah 100 MW Unit-3	IPP	0	100	80	407040	Engine problem
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	22	356112	
	* Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	42	630720	
51	Chattogram ECPV 108 MW	IPP	16*7	108	0	25920	Reserve
Chattogram area Total				1681	541	8427390	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	80	2068055	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	80	2244032	Gas shortage
53	Ashuganj CCGP 225 MW	APSCL	1*142+1*75	221	158	4498000	FGMO
54	Ashuganj CCGP(North)	APSCL	1*360	360	260	2165100	ST Under maint.
55	Ashuganj CCGP(South)	APSCL	1*360	360	300	6716000	FGMO
56	Ashuganj Engines TSK	APSCL	14*3.968	45	20	561672	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	7	183840	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	200727	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	7	232206	Engine problem
	Midland 150MW	IPP	23*7.015	150	6	23410	Low demand
61	B.Baria (Aggreko) 85MW	QRPP	86*1.10	85	50	209760	Frequency control
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	8	107024	Reserve
63	Chandpur CCGP	PDB	1*106+1*57	163	100	1992320	ST Under maint.
	Chandpur Desh 200MW	IPP	0	200	17	71000	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	11	279900	Engine problem
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	11340	
**	Tripura	Imported power	0	160	100	1763520	
66	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	25	170600	
67	Lakdhanvi 52 MW	IPP	6*8.92	52	0	0	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	18	409500	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1268	24028006	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	213	4091920	Gas shortage
71	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	277632	
72	Jamulpur 95MW	IPP	12*8.924	95	50	140160	Low demand
73	Sarisshabari (Solar)	IPP	1*3	3	0	10500	
74	United Mymensingh PPL	IPP	200	200	50	350400	Low demand
Mymensingh Area Total				522	333	4870612	
75	Fenchugonj CCGP-1	PDB	2*32+1*33	70	30	712000	
76	Fenchugonj CCGP-2	PDB	2*35+1*35	90	40	954080	
77	Kushnara 163 MW CCGP GT	IPP	1*109+1*54	163	100	1893861	
78	Shajibazar 330 MW	PDB	3*110	330	140	3909000	FGMO
79	Fenchugonj (Barakatullah) 51M	RPP	19*2.90	51	48	211200	
80	Fenchugonj (EPL) 44MW	RPP	12*3.5+5*2	44	21	141000	Engine problem
81	Hobiganj 11MW	SIPP, REB	4*2.90	11	8	189267	
82	Shajibazar GT: Unit- 8, 9	RPP	2*35	66	40	1335000	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	20	185280	Frequency control
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	49	450720	
85	Sylhet GT 150 MW	PDB	1*142	142	77	1863960	Frequency control
86	Sylhet GT 20 MW	PDB	1*20	20	0	0	
87	Sylhet (EPL) 50MW	RPP	27*2	50	25	348960	Low demand
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	25	435744	Engine problem
89	Summit Bibiana-2	IPP	1*222+1*119	341	290	7505500	FGMO
90	Bibiyana-3 285MW	PDB	285 MW	0	0	0	On test
	Sylhet (Desh) 10MW	RPP	6*1.95	10	9	76860	
Sylhet Area Total				1549	922	20212432	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	693	10448000	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khulna (KPCL-2)	QRPP	7*17	115	0	39360	Reserve
94	Fandpur Peaking	PDB	6*6.89	54	22	127200	Low demand
95	Khulna CCGP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*6.98	109	41	151040	
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	300	5226048	Spinning reserve
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	153375	Low demand
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	0	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	53	180480	Low demand
Khulna Area Total				2209	1149	16325503	
100	Summit Barisal 110 MW	IPP	7*17.076	110	16	44930	Low demand
101	Barisal GT: Unit-1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	26	429100	Engine problem
103	Bhola CCGP 194MW	PDB	2*63+1*68	194	184	4691290	FGMO
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	52	640019	
Barisal Area Total				462	278	5805339	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Gas shortage
106	Baghabari Peaking 50MW	PDB	6*8.9	52	0	37896	Reserve
107	Bera Peaking	PDB	9*8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7*7.79	50	50	159490	
109	Katakhal (Northern)	QRPP	6*8.9	50	0	0	Reserve
110	Katakhal Peaking	PDB	6*8.7	50	0	0	Reserve
111	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
112	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	145	3971927	FGMO
113	Sirajgonj Unit-3 225MW	NWPGCL	1*141	141	0	0	Gas shortage
	Sirajgonj Unit-4 414 MW(Gas)	SNWPGCL	1*282	282	0	0	Gas shortage
114	Santahar Peaking	PDB	6*8.7	50	23	49447	
115	Bogra (GBB)	RPP	6*4	22	22	368640	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	5	89928	Engine problem
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	124434	
118	Rajlanka 52 MW	IPP	6*8.92	52	26	100800	Low demand
119	Chapainawabganj-100 MW	PDB	12*8.924	104	26	48144	Low demand
Rajshahi Area Total				1546	308	<	