

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	72	1678000	
	Ghorasal ST: Unit-3	PDB	1*210	170	120	2895480	
	Ghorasal ST: Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal ST: Unit-5	PDB	1*210	190	100	2312100	
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	270	6381936	
3	Ghorasal 78MW (MAX)	IPB	2*40	78	30	1028608	
4	Ghorasal (Regent)	IPB	3*43.35	108	87	1122818	
5	Haripur GT: Unit-1,2	SBU, PDB	2*32	40	20	208900	
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	381	8289280	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	350	7616000	
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	450	8830637	
10	Meghnaghat (IEL)	QRPP	12*9	100	7	153600	Low demand
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	15	269736	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	15	272075	Low demand
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	10	200508	Low demand
15	Narsingdi (Doreen)	SIPP, REB	8*2.90	22	22	462913	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	130	2971000	
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	7	127200	Low demand
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	218	4444856	
21	Pagla (DPA)	QRPP	100*0.5	50	0	0	Reserve
22	Gagnagar (Orion)	IPP	12*8.924	102	7	116496	Low demand
23	Katpott 51 MW	IPP	7*7.9	51	6	218640	Low demand
24	Banco Energy 54MW	IPP	3*18	54	18	433440	Low demand
25	Kodda 149 MW	BPDB-RPCL	9*17.06	149	16	236160	Low demand
26	Northern 55 MW	IPP	3*19.3	55	0	374004	Reserve
27	Southern 55MW	IPP	3*19.3	55	17	481000	Low demand
28	Bosila 108MW	IPP	12*9.75+1*3.5	108	0	0	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP REB	3*8.67+4*8.73	80	35	967200	Engine problem
30	Summit Maona	SIPP REB	4*8.73	33	33	728300	
31	Summit Rugganj	SIPP REB	4*8.73	33	7	395100	Engine problem
32	Gazipur (RPCL)	IPP	6*8.9	52	8	82632	Low demand
33	Tongi GT	PDB	1* 105	105	0	0	Under maint.
34	Summit Gazipur	IPP	18*17.076	300	14	717600	Low demand
	APR Energy , Keraniganj	IPP	236*1.4	300	0	0	Reserve
35	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
36	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
	Summit Gazipur-1. 150MW	IPP	149 MW	149	15	807840	Low demand
Dhaka area Total				5848	2480	54825059	
37	Chittagong ST-1 (Raozan)	PDB	1*210	180	0	0	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
38	Raazan 25 MW (RPCL)	IPP	3*8.9	25	8	84960	Low demand
39	Patenga 50MW	IPP	8*6.98	50	18	392160	Low demand
40	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	188	4129653	
41	Sikalbaha ST 60MW	PDB	1*60	40	0	0	
42	Sikalbaha 225MW	PDB	1*150+1*175	225	202	4767465	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	60	1463674	
44	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	31	497280	
45	Hathazari peaking	PDB	11*8.9	98	0	168796	Reserve
46	Dohazari Peaking	PDB	6*17	102	49	306637	
47	Juidah (Acom)	QRPP	8*13.45	100	100	1186680	
48	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	19	462096	
*	Malancha, Ctg. EPZ (Uniled)		5*8.73+3*9.34	0	42	1138560	
49	Chittagong ECPV 108 MW	IPP	16*7	108	52	813120	Low demand
Chittagong area Total				1561	769	15411081	
50	Ashuganj ST: Unit- 3	APSC	1*150	135	90	2254008	Gas shortage
	Ashuganj ST: Unit- 4	APSC	1*150	129	70	1701940	Gas shortage
	Ashuganj ST: Unit- 5	APSC	1*150	134	0	0	Under maint.
51	Ashuganj CAPP 225 MW	APSC	1*142+1*75	221	194	4543000	FGMO
52	Ashuganj CAPP(North)	APSC	1*360	360	360	8307000	
53	Ashuganj CAPP(South)	APSC	1*360	360	316	6881000	FGMO
54	Ashuganj Engines TSK	APSC	14*3.968	45	43	673416	
55	Ashuganj (Precision) 55MW	RPP	15*4	55	5	156480	Gas shortage
56	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
57	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	16	736000	Gas shortage
58	Ashuganj (Midland) 51MW	IPP	6*9.34	51	12	406911	Gas shortage
59	B.Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	269736	
60	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	0	Reserve
61	Chandpur CAPP	PDB	1*106+1*57	163	90	2104170	
62	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	470700	
63	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	210240	
**	Tripura	Imported power	0	160	158	2988480	
64	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	33	453500	
65	Lakdhani 52 MW	IPP	6*8.92	52	0	0	Reserve
66	Summit Comilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	20	392120	
67	Daudkandi bangla trak	IPP	15*1.4	200	0	0	Reserve
Comilla Area Total				2541	1530	32448701	
68	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	198	4421760	
69	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	519048	
70	Jamalpur 95MW	IPP	12*8.924	95	16	233280	Low demand
71	Sarishabari (Solar)	IPP	1*3	3	0	0	
72	United Mymensingh PPL	IPP	200	200	180	1764000	Engine problem
Mymensingh Area Total				522	416	6938088	
73	Fenchuganj CAPP-1	PDB	2*32+1*33	70	60	1980000	
74	Fenchuganj CAPP-2	PDB	2*35+1*35	90	62	1463423	
75	Kushiara 163 MW CAPP GT	IPP	1*109+1*54	163	163	3076772	
76	Shajibazar 330 MW	PDB	3*110	330	238	5010036	FGMO
77	Fenchuganj (Barakatullah) 51MW	RPP	19*2.90	51	33	279700	
78	Fenchuganj (EPL) 44MW	RPP	12*3.3+5*2	44	47	456000	
79	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	264000	
80	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	62	1302000	
81	Shajibazar 86MW	RPP	32*2.90	86	10	429120	
82	Shajibazar (EPL) 50MW	RPP	27*2.0	50	46	387360	
83	Sylhet GT 160 MW	PDB	1*142	142	78	2062770	
84	Sylhet GT 20 MW	PDB	1*20	20	0	40000	Reserve
85	Sylhet (EPL) 50MW	RPP	27*2	50	44	514840	Engine problem
86	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	23	481512	
87	Summit Bibiana- 2	IPP	1*222+1*119	341	320	7009000	FGMO
88	Sylhet (Desh) 10MW	RPP	6*1.95	10	0	17820	Reserve
Sylhet Area Total				1549	1197	24774353	
89	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
	Bheramara (HVDC)	Imported power	1*500	500	485	11618909	
90	Khulna (KPCL-1 & 3)	IPP	19*6.5	110	10	282240	Low demand
91	Khulna (KPCL-2)	QRPP	7*17	115	16	365760	Low demand
92	Faridpur Peaking	PDB	8*6.89	54	41	425760	
93	Khulna CAPP 225MW	NWPGCL	1*150+1*75	230	50	1317120	Low demand
94	Gopalganj Peaking	PDB	16*9.98	109	78	778112	
95	Bheramara 360 MW	NWPGCL	1*278+1*132	410	410	8546976	
96	Noapara (KZA) 40MW	QRPP	5*8.5	40	32	349500	Engine problem
97	Khulna (Aggreko) 55MW	QRPP	71*0.85	55	0	0	Contract Expired
98	Bangla Trak Noapara	IPP	70*1.4	100	93	529920	
Khulna Area Total				1769	1215	24214297	
99	Summit Barisal 110 MW	IPP	7*17.076	110	110	1342272	
100	Barisal GT: Unit-1, 2	PDB	2*20	30	0	8858	
101	Bhola (Venture) 33MW	RPP	1*34.50	33	38	706530	
102	Bhola CAPP 194MW	PDB	2*63+1*68	194	120	2874000	ST Under maint.
103	Bhola Aggreko 95MW	QRPP	96*1.10	95	96	1440771	
Barisal Area Total				462	364	6372431	
104	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
105	Baghabari Peaking 50MW	PDB	6*8.9	52	50	510016	
106	Bera Peaking	PDB	9*8.29	71	42	247737	
107	Ammura 50MW	QRPP	7*7.79	50	50	720810	
108	Katakhal (Northern)	QRPP	6*8.9	50	50	817760	
109	Katakhal Peaking	PDB	6*8.7	50	46	447700	
110	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	
111	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	220	0	
112	Sirajgonj Unit-3 225MW	NWPGCL	1*150+1*75	0	132	3362600	On test
113	Santalaha Peaking	PDB	6*8.7	50	34	376146	
114	Boogra (GBS)	RPP	6*4	22	22	502560	
115	Ullapara (Summit)	SIPP, REB	5*3.3+5*2	10	10	237824	
116	Rajlanka 52 MW	IPP	4*2.90	11	11	255600	
117	Chapainawabganj-100 MW	PDB	6*8.92	52	43	772320	
Rajshahi Area Total				1123	785	9485189	
118	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling
	Barapukuria Unit-2	PDB	1*125	85	60	1003636	
119	Barapukuria Unit-3	PDB	1*275	274	0	0	Coal shortage
120	Rangpur GT	PDB	1*20	20	15	217000	
121	Saidpur GT	PDB	1*20	20	18	121000	
Rangpur Area Total				484	93	1341636	
Total				15859	8849	175810835	
Eastern Grid Total				12021	6392	134397282	
Western Grid Total				3838	2457	41413553	
National Grid Total				15859	8849	175810835	