

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	74	1702000	
	Ghorasal ST: Unit-3	PDB	1*210	170	110	2783025	Gas shortage
	Ghorasal ST: Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal ST: Unit-5	PDB	1*210	190	100	2223900	Gas shortage
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	0	0	under maint.
3	Ghorashal 78MW (MAX)	QRPP	2*40	78	74	1582112	
4	Ghorashal (Regent)	IPP	34*3.35	108	90	1913182	Engine problem
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	20	221600	
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	388	8608770	Gas shortage
7	Haripur NEPC 110MW	IPP	8*15	110	110	408600	
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	321	7588000	Gas shortage
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	430	8796213	Gas shortage
10	Meghnaghat (IEL)	QRPP	12*8.9	100	100	943680	
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	64	944904	Engine problem
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	771585	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	100	982832	
15	Narsinghdi (Doreen)	SIPP, REB	8*2.90	22	19	397440	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	0	0	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	53	276480	Low demand
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	100	903360	
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	216	4802820	
21	Pagla (DPA )	QRPP	100*0.5	50	21	559200	Low demand
22	Gagnagar (Orion)	IPP	12*8.924	102	102	964224	
23	Katpotti 51 MW	IPP	7*7.9	51	41	707424	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	867600	
25	Kodda 149 MW	BPDB-RPCL	9*17.06	149	145	1407840	
26	Northern 55 MW	IPP	3*19.3	55	55	693301	
27	Southern 55MW	IPP	3*19.3	55	55	776680	
28	Bosila 108MW	IPP	12*8.775+1*3.5	108	24	770880	Engine problem
29	Summit Power, (Madhabdi+Ash)	SIPP, REB	3*3.67+4*8.73	80	51	1124340	Engine problem
30	Summit Maona	SIPP, REB	4*8.73	33	33	634271	
31	Summit Ruppangj	SIPP, REB	4*8.73	33	33	818900	
32	Gazipur (RPCL)	IPP	6*8.9	52	41	587004	Engine problem
33	Tongi GT	PDB	1* 105	105	0	0	Under maint.
34	Summit Gazipur	IPP	18*17.076	300	207	2807670	Machine problem
35	APR Energy , Keraniganj	IPP	236*1.4	300	0	0	Low demand
36	Bramhangoan 100 MW (Aggre)	IPP	100	100	10	347797	Low demand
36	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	11	62334	Low demand
	Summit Gazipur-1 150MW	IPP	149 MW	149	103	2000160	Engine problem
<b>Dhaka area Total</b>				<b>5848</b>	<b>3410</b>	<b>6080128</b>	
37	Chittagong ST-1 (Raozan)	PDB	1*210	180	0	0	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
38	Raozan 25 MW (RPCL)	IPP	3*8.9	25	16	276300	Engine problem
39	Patenga 50MW	IPP	8*6.98	50	48	616320	
40	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	136	3577169	
41	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
42	Sikalbaha 225MW	PDB	1*150+1*175	225	206	5215428	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	80	1632870	
44	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1	51	40	647520	
45	Halhazari peaking	PDB	11*8.9	98	72	502936	
46	Dohazari Peaking	PDB	6*17	102	48	285205	
47	Juidah (Acom)	QRPP	8*13.45	100	90	1512840	Engine problem
48	Barakunda (Regent)	SIPP, PDB	8*2.90	22	19	457392	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	32	744960	
49	Chittagong ECPV 108 MW	IPP	16*7	108	93	1293120	Engine problem
<b>Chittagong area Total</b>				<b>1561</b>	<b>880</b>	<b>16762060</b>	
50	Ashuganj ST: Unit-3	APSCL	1*150	135	80	1937656	Gas shortage
	Ashuganj ST: Unit-4	APSCL	1*150	129	0	0	Under maint.
	Ashuganj ST: Unit-5	APSCL	1*150	134	80	1923456	Gas shortage
51	Ashuganj CAPP 225 MW	APSCL	1*142+1*75	221	198	4837000	
52	Ashuganj CAPP(North)	APSCL	1*360	360	360	8960000	
53	Ashuganj CAPP(South)	APSCL	1*360	360	316	7423000	FGMO
54	Ashuganj Engines TSK	APSCL	14*3.968	45	15	467568	Gas shortage
55	Ashuganj (Precision) 55MW	RPP	15*4	55	5	150240	Gas shortage
56	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
57	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	68	1656000	Gas shortage
58	Ashuganj (Midland) 51MW	IPP	6*9.34	51	51	1053894	
59	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	944904	
60	Daudkandi Peaking 52MW	PDB	6*8.92	52	33	199896	
61	Chandpur CAPP	PDB	1*106+1*57	163	153	3593270	
62	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	19	449748	
63	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	237780	
**	Tripura	Imported power	0	160	144	2720640	
64	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	33	776000	
65	Lakshnavi 52 MW	IPP	6*8.92	52	8	112805	Low demand
66	Summit Comilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	21	497070	
67	Daudkandi bangla trak	IPP	15*1.4	200	10	63360	Low demand
<b>Comilla Area Total</b>				<b>2541</b>	<b>1695</b>	<b>38124287</b>	
68	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	46	1100640	Gas shortage
69	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	445896	
70	Jamalpur 95MW	IPP	12*8.924	95	88	793920	Engine problem
71	Sarishabari (Solar)	IPP	1*3	3	0	13250	
72	United Mymensingh PPL	IPP	200	200	182	3729600	Engine problem
<b>Mymensingh Area Total</b>				<b>522</b>	<b>336</b>	<b>6083306</b>	
73	Fenchuganj CAPP-1	PDB	2*32+1*33	70	58	1339000	
74	Fenchuganj CAPP-2	PDB	2*35+1*35	90	31	744000	
75	Kushara 163 MW CAPP GT	IPP	1*109+1*54	163	163	3123441	
76	Shajibazar 330 MW	PDB	3*110	330	313	6989577	FGMO.
77	Fenchuganj (Barakatullah) 51M	RPP	19*2.90	51	47	849600	
78	Fenchuganj (EPL) 44MW	RPP	12*3.3+5*2	44	50	1078000	
79	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	264000	
80	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	67	1396000	
81	Shajibazar 86MW	RPP	32*2.90	86	86	1172160	
82	Shajibazar (EPL) 50MW	PDB	27*2.0	50	47	793800	
83	Sylhet CT 150 MW	PDB	1*142	142	130	2246550	
84	Sylhet CT 20 MW	PDB	1*20	20	19	268000	
85	Sylhet (EPL) 50MW	RPP	27*2	50	46	932520	
86	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	8	287472	line problem
87	Summit Bibiana- 2	IPP	1*222+1*119	341	280	7299750	FGMO
88	Sylhet (Desh) 10MW	RPP	6*1.95	10	9	216180	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>1365</b>	<b>29011050</b>	
89	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
	Bheramara (HVDC )	Imported power	1*500	500	484	11739636	
90	Khulna (KPCL-1 & 3)	IPP	19*6.5	110	88	846720	Engine problem
91	Khulna (KPCL-2)	QRPP	7*17	115	115	1279680	
92	Faridpur Peaking	PDB	8*6.89	54	39	881460	
93	Khulna CAPP 225MW	NWPGCL	1*150+1*75	230	120	2562240	Low demand
94	Gopalganj Peaking	PDB	16*6.98	109	72	730880	
95	Bheramara 360 MW	NWPGCL	1*278+1*132	410	413	9050400	
96	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	615000	Contract Expired
97	Khulna (Aggreko) 55MW	QRPP	71*0.85	55	0	0	Engine problem
98	Bangla Trak Noapara	IPP	70*1.4	100	94	598080	
<b>Khulna Area Total</b>				<b>1769</b>	<b>1465</b>	<b>28304096</b>	
99	Summit Bansal 110 MW	IPP	7*17.076	110	110	2420448	
100	Bansal GT: Unit-1, 2	PDB	2*20	30	24	148765	Low demand
101	Bhola (Venture) 33MW	RPP	1*34.50	33	38	649404	
102	Bhola CAPP 194MW	PDB	2*63+1*68	194	0	1052000	Under maint.
103	Bhola Aggreko 95MW	QRPP	96*1.10	95	97	1313384	
<b>Bansal Area Total</b>				<b>462</b>	<b>269</b>	<b>5584001</b>	
104	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
105	Baghabari Peaking 50MW	PDB	6*8.9	52	50	556808	
106	Bera Peaking	PDB	9*8.29	71	31	294613	
107	Amnura 50MW	QRPP	7*7.9	50	40	991350	Engine problem
108	Katakali (Northern)	QRPP	6*8.9	50	50	1174320	
109	Katakali Peaking	PDB	6*8.7	50	31	210700	
110	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	214	5444827	
111	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	200	5373836	
	Sirajgonj Unit-3 225MW	NWPGCL	1*150+1*75	0	0	0	On test
	Sirajgonj Unit-4 414 MW(Gas)	SNWPGCL	1*272+1*132 MW	0	0	1892272	
112	Santahar Peaking	PDB	6*8.7	50	32	402619	
113	Bogra (GBB)	RPP	6*4	22	22	499200	
114	Bogra (EPL)	RPP	5*3.3+5*2	10	10	241272	Engine problem
115	Ullapara (Summit)	SIPP, REB	4*2.90	11	0	240550	tripped at 19:50
116	Rajlanka 52 MW	IPP	6*8.92	52	52	962880	
117	Chapainawabganj-100 MW	PDB	12*8.924	104	90	918688	Engine problem
<b>Rajshahi Area Total</b>				<b>1123</b>	<b>822</b>	<b>19202115</b>	
118	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling
	Barapukuria Unit-2	PDB	1*125	85	0	0	Coal shortage
119	Barapukuria Unit-3	PDB	1*275	274	0	0	Coal shortage
120	Rangpur GT	PDB	1*20	20	14	163000	
121	Saidpur GT	PDB	1*20	20	10	91000	
<b>Rangpur Area Total</b>				<b>484</b>	<b>24</b>	<b>254000</b>	
<b>Total</b>				<b>15859</b>	<b>10266</b>	<b>204305043</b>	
Eastern Grid Total				12021	7686	150960831	
Western Grid Total				3838	2580	53344212	
National Grid Total				15859	10266	204305043	