

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 9-Sep-18

Page -2

Sl No.	Name of the Power Station	Producer	Installed Capacity	Presen Capacity	Peak Generation	Enervv Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	74	1669000	
	Ghorasal ST: Unit-3	PDB	1*210	170	110	2610090	Gas shortage
	Ghorasal ST: Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal ST: Unit-5	PDB	1*210	190	100	2148300	Gas shortage
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	0	0	under maint.
3	Ghorashai 78MW (MAX)	QRPP	2*40	78	70	1605632	
4	Ghorashai (Regent)	IPP	34*3.35	108	87	2120182	Engine problem
5	Haripur GT: Unit-1, 2	SBU_PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	352	8858170	Gas shortage
7	Haripur NEPC 110MW	IPP	8*15	110	110	856600	
8	Haripur Power CCGP 360M	IPP	1*235+1*125	360	310	7422000	Gas shortage
9	Meghnaghat CCGP 450MW	IPP	2*150+1*150	450	400	8548462	Gas shortage
10	Meghnaghat (IEL)	QRPP	12*8.9	100	100	1907520	
11	Meghnaghat CCGP(Summit)	QRPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	81	1749432	Engine problem
13	Madanganj 55 MW	(IPP)	3*17.08+1*11.3	55	40	972519	Engine problem
14	Keraniganj (Powerpac) 100	QRPP	8*13.45	100	100	1528024	Engine problem
15	Narsingdi (Doreen)	SIPP, REB	8*2.90	22	22	490356	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	0	0	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	100	676800	
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	100	1894080	
20	Siddhirgonj CCGP-335 MW	EGCB	1*217	217	180	4963402	frequency control.
21	Paiga (DPA)	QRPP	100*0.5	50	45	434032	CT setting 800/1 by DPCC.
22	Gaigagar (Onion)	IPP	12*8.924	102	102	1450224	
23	Katpotti 51 MW	IPP	7*7.9	51	40	971472	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	1285920	
25	Kodda 149 MW	BPDB-RPCL	9*17.06	149	149	2567520	
26	Northern 55 MW	IPP	3*19.3	55	56	1239207	
27	Southern 55MW	IPP	3*19.3	55	55	1129800	
28	Bosila 108MW	IPP	12*8.775+1*3.5	108	78	1733760	Engine problem
29	Summit Power (Madhabadi)	SIPP,REB	3*3.67+8*7.3	80	56	1307220	Engine problem
30	Summit Maona	SIPP,REB	4*8.73	33	33	809000	
31	Summit Ruggani	SIPP,REB	4*8.73	33	25	748800	
32	Gazipur (RPCL)	IPP	6*8.9	52	40	973152	Engine problem
33	Tongi GT	PDB	1* 105	105	0	0	Under maint.
34	Summit Gazipur	IPP	18*17.076	300	218	4651850	Machine problem
35	APR Energy , Keraniganj	IPP	236*1.4	300	173	740623	Low demand
36	Bramhangon 100 MW (A	IPP	100	100	50	322840	High Voltage
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	81	360978	High Voltage
38	Summit Gazipur-1 150MW	IPP	149 MW	149	106	2239200	Engine problem
				5849	3697	73005167	
37	Chittagong ST-1 (Raooan)	PDB	1*210	180	0	0	Gas shortage
	Chittong ST-2 (Raooan)	PDB	1*210	180	0	100000	synchronized at 20:30.
38	Raozan 25 MW (RPCL)	IPP	3*8.9	25	16	370260	Engine problem
39	Patenga 50MW	IPP	8*6.98	50	45	991680	
40	Kaptai Hydro: Unit-1,2,3,4	PDB	2*40+3*50	230	151	3231422	unit # 05 under maint.
41	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
42	Sikalbaha 225MW	PDB	1*150+1*75	225	231	6221527	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	135	2100121	
44	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+	51	50	1065600	
45	Hathazari peaking	PDB	11*8.9	98	82	930040	
46	Dohazari Peaking	PDB	6*17	102	46	560878	
47	Juidah (Accor)	QRPP	8*13.45	100	80	1788480	Engine problem
48	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	19	456192	
49	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	31	430080	
	Chittagong ECPV 108 MW	IPP	16*7	108	93	1959360	Engine problem
				1251	979	19205640	
				1591	80	1977200	
50	Ashuganj ST: Unit- 3	APSCL	1*150	150	60	1977200	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	0	0	Under maint.
	Ashuganj ST: Unit- 5	APSCL	1*150	134	100	2063708	Gas shortage
51	Ashuganj CCGP 225 MW	APSCL	1*142+1*75	221	205	4964000	
52	Ashuganj CCGP(North)	APSCL	1*360	360	360	8979000	
53	Ashuganj CCGP(South)	APSCL	1*360	360	301	6716000	FGMO
54	Ashuganj Engines TSK	APSCL	14*3.968	45	30	856296	Gas shortage
55	Ashuganj (Precision) 55M	RPP	15*4	55	15	173760	Gas shortage
56	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
57	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	68	1656000	Gas shortage
58	Ashuganj (Midland) 51MW	IPP	6*9.34	51	51	1176501	
59	B.Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	1749432	
60	Daudkandi Peaking 52MW	PDB	6*8.92	52	40	338416	
61	Chandpur CCGP	PDB	1*106+1*57	163	153	3575010	
62	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	465444	
63	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	225000	
**	Trijura	Imported power		0	174	3069690	
64	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	33	821000	
65	Lakhdhanvi 52 MW	IPP	6*8.92	52	25	391291	Low demand
66	Summit Comilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	22	482980	
67	Daudkandi bangle trak	IPP	154*1.4	200	200	783360	
				2541	1980	40611358	
68	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	40	924960	Gas shortage
69	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	431100	
70	Jamalpur 95MW	IPP	12*8.924	95	89	1278720	Engine problem
71	Sansidhan (Solar)	IPP	1*3	3	0	13850	
72	United Mymensingh PPL	IPP	200	200	185	4188000	Engine problem
				522	334	6817430	
73	Fenchugonj CCGP-1	PDB	2*32+1*33	70	58	1354000	
74	Fenchugonj CCGP-2	PDB	2*35+1*35	90	60	551100	
75	Kushnara 163 MW CCGP C	IPP	1*109+1*54	163	163	3379745	
76	Shajibazar 330 MW	PDB	3*110	330	300	6885660	FGMO.
77	Fenchugonj (Barakatullah)	RPP	19*2.90	51	46	975600	
78	Fenchugonj (EPL) 44MW	RPP	12*3.5+2	44	50	1179000	
79	Hobiganj 110MW	SIPP, REB	4*2.90	11	11	260880	
80	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	54	1387000	frequency control.
81	Shajibazar 86MW	RPP	32*2.90	86	86	2048640	
82	Shajibazar (EPL) 50MW	RPP	27*2.0	50	47	1075680	
83	Sylhet GT 150 MW	PDB	1*142	142	98	2377850	
84	Sylhet GT 20 MW	PDB	1*20	20	18	284000	
85	Sylhet (EPL) 50MW	RPP	27*2	50	47	1098000	
86	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	12	275856	
87	Summit Bibiana- 2	IPP	1*222+1*119	341	285	7258000	FGMO
88	Sylhet (Desh) 10MW	RPP	6*1.95	10	9	213120	
				1549	1344	30604131	
89	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
	Bheramara (HVDC)	Imported power	1*500	500	485	11821091	
90	Khulna (KPCL-1 & 3)	IPP	19*6.5	110	98	1133760	Engine problem
91	Khulna (KPCL-2)	QRPP	7*17	115	85	1739520	Engine problem
92	Fandpur Peaking	PDB	8*6.89	54	28	239040	
93	Khulna CCGP 225MW	NWPGCL	1*150+1*75	230	236	3828480	
94	Gopalganj Peaking	PDB	16*6.98	109	70	534400	
95	Bheramara 360 MW	NWPGCL	1*278+1*132	410	417	9659944	
96	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	830625	
97	Khulna (Aggreko) 55MW	QRPP	71*0.85	55	0	0	Contract Expired
98	Bangla Trak Noapara	IPP	70*1.4	100	94	617280	
				1769	1553	30403140	
99	Summit Barisal 110 MW	IPP	7*17.076	110	110	2635200	
100	Barisal GT: Unit-1, 2	PDB	2*20	30	20	91547	
101	Bhola (Venture) 33MW	RPP	1*34.50	33	38	694794	
102	Bhola CCGP 194MW	PDB	2*63+1*68	194	120	2882000	
103	Bhola Aggreko 95MW	QRPP	96*1.10	95	96	2317715	
				462	384	8621256	
104	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
105	Baghabari Peaking 50MW	PDB	6*8.9	52	50	598752	
106	Bera Peaking	PDB	9*8.29	71	48	534390	
107	Amnura 50MW	QRPP	7*7.9	50	40	1007320	Engine problem
108	Katakhat (Northern)	QRPP	6*8.9	50	50	1197840	
109	Katakhat Peaking	PDB	6*8.7	50	38	357608	
110	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	215	5332664	
111	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	220	5390472	
	Sirajgonj Unit-3 225MW	NWPGCL	1*150+1*75	0	0	0	On test
	Sirajgonj Unit-4 414 MW	NWPGCL	1*272+1*132 MW	0	0	1948727	
112	Santahar Peaking	PDB	6*8.7	50	25	338146	
113	Bogra (GBB)	RPP	6*4	22	22	502560	Engine problem
114	Bogra (EPL)	RPP	5*3.3+5*2	10	10	231408	Engine problem
115	Ulapara (Summit)	SIPP, REB	4*2.90	11	11	217854	
116	Rajlanika 52 MW	IPP	6*8.92	52	8	655880	Oil shortage.
117	Chaganawalsganj-100 MW	PDB	12*8.924	104	100	1488896	
				1123	837	19802417	
118	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling
	Barapukuria Unit-2	PDB	1*125	85	0	0	Coal shortage
119	Barapukuria Unit-3	PDB	1*275	274	0	0	Coal shortage
120	Rangpur GT	PDB	1*20	20	11	152000	
121	Saidpur GT	PDB	1*20	20	10	124000	
				484	21	276000	