

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	74	1689000	
	Ghorasal ST: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal ST: Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal ST: Unit-5	PDB	1*210	190	120	2835000	Gas shortage
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	365	8661290	
	Ghorasal 78MW (MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorashal (Regent)	IPP	3*43.35	108	12	291681	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	330	6097570	Gas shortage
7	Haripur NEPC 110MW	IPP	8*15	110	103	1402800	
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	241	7307000	Gas shortage
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	260	8274812	Gas shortage
10	Meghnaghat (IEL)	QRPP	12*9	100	100	2199360	
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	81	1830120	Engine problem
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	1078597	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	100	2056920	
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	364896	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Under maint.
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	0	0	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	100	1246080	
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	97	2153280	
20	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	150	4424365	
21	Pagla (DPA )	QRPP	100*0.5	50	51	612150	
22	Gagnagar (Orion)	IPP	12*8.924	102	102	2053584	
23	Katpotti 51 MW	IPP	7*7.9	51	26	751104	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	1185480	
25	Kodda 149 MW	BPDB-RPCL	9*17.06	149	133	2241120	Engine problem
26	Northern 55 MW	IPP	3*19.3	55	55	1282136	
27	Southern 55MW	IPP	3*19.3	55	55	1180517	
28	Bosila 108MW	IPP	12*9.75+1*13.5	108	70	1359360	
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*8.7+4*8.73	80	50	1125420	Engine problem
30	Summit Madona	SIPP, REB	4*8.73	33	33	754800	
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	788100	
32	Gazipur (RPCL)	IPP	6*8.9	52	41	836112	Engine problem
33	Tongi GT	PDB	1* 105	105	0	0	Under maint.
34	Summit Gazipur	IPP	18*17.076	300	260	4684470	Engine problem
	APR Energy, Keraniganj	IPP	236*1.4	300	73	508497	Low demand
35	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	97	666124	
36	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	100	890150	
	Summit Gazipur-1. 150MW	IPP	149 MW	149	108	2414880	Engine problem
<b>Dhaka area Total</b>				<b>5848</b>	<b>3548</b>	<b>75246775</b>	
37	Chittagong ST-1 (Raozan)	PDB	1*210	180	130	3000000	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
38	Raozan 25 MW (RPCL)	IPP	3*8.9	25	16	340380	Engine problem
	Teknaf Solartech 20MW	Teknaf Solartech Energ	28MW	0	0	116000	
39	Patenga 50MW	IPP	8*6.98	50	34	973440	Engine problem
40	Kaptal Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	150	3325538	unit # 05 under maint.
41	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
42	Sikalbaha 225MW	PDB	1*150+1*175	225	192	2604473	Gas shortage
43	Sikalbaha Peaking GT	PDB	1*150	150	135	3120355	
44	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	40	918240	Engine problem
45	Hathazari peaking	PDB	1*8.9	98	72	979600	
46	Dohazari Peaking	PDB	6*17	102	44	715941	
47	Juldah (Acom)	QRPP	8*13.45	100	90	2076480	Engine problem
48	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	19	454704	
*	Malancha, Ctg. EPZ (Uniled)		5*8.73+3*9.34	0	15	364320	
49	Chittagong ECPV 108 MW	IPP	16*7	108	90	2087040	Engine problem
<b>Chittagong area Total</b>				<b>1561</b>	<b>1027</b>	<b>21076511</b>	
50	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	120	2691400	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	100	2324176	Gas shortage
51	Ashuganj CCPP 225 MW	APSCL	1*142+1*75	221	209	4660000	
52	Ashuganj CCPP(North)	APSCL	1*360	360	360	8921500	
53	Ashuganj CCPP(South)	APSCL	1*360	360	301	7470000	FGMO
54	Ashuganj Engines TSK	APSCL	14*3.968	46	42	868032	Gas shortage
55	Ashuganj (Precision) 55MW	RPP	15*4	55	5	153120	Gas shortage
56	Ashuganj (Uniled) 53MW	QRPP	14*4	53	5	120000	Gas shortage
57	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	68	1656000	Gas shortage
58	Ashuganj (Midland) 51MW	IPP	6*9.34	51	0	0	Development work
59	B Bara (Aggreko) 85MW	QRPP	86*1.10	85	85	1830120	
60	Daudkandi Peaking 52MW	PDB	6*8.92	52	49	422040	
61	Chandpur CCPP	PDB	1*106+1*57	163	100	3265460	
62	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	0	490284	tripped at 19:55.
63	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	0	185400	tripped at 19:55.
**	Tripura	Imported power	0	160	150	3076800	
64	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	33	777200	
65	Lakdhanvi 52 MW	IPP	6*8.92	52	0	71040	Line over load
66	Summit Cornilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	18	446800	
67	Daudkandi bangla trak	IPP	154*1.4	200	200	936840	
<b>Comilla Area Total</b>				<b>2541</b>	<b>1845</b>	<b>40366212</b>	
68	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	65	1097060	Gas shortage
69	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	426204	
70	Jamalpur 95MW	IPP	12*8.924	95	87	1788480	Engine problem
71	Sarishabari (Solar)	IPP	1*3	3	0	14800	
72	Uniled Mymensingh PPL	IPP	200	200	178	3852000	Engine problem
<b>Mymensingh Area Total</b>				<b>522</b>	<b>352</b>	<b>7178544</b>	
73	Fenchugonj CCPP-1	PDB	2*32+1*33	70	58	1339000	
74	Fenchugonj CCPP-2	PDB	2*35+1*35	90	60	1440000	
75	Kushara 163 MW CCPP GT	IPP	1*109+1*54	163	100	3486256	
76	Shajbazar 330 MW	PDB	3*110	330	301	7002759	FGMO.
77	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	47	1132200	
78	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	47	1109000	
79	Hobganj 11MW	SIPP, REB	4*2.90	11	11	264000	
80	Shajbazar GT: Unit- 8, 9	PDB	2*35	66	56	1341000	Frequency control.
81	Shajbazar 86MW	RPP	32*2.90	86	86	1911360	
82	Shajbazar (EPL) 50MW	RPP	2*25.0	50	46	991080	
83	Sylhet GT 150 MW	PDB	1*142	142	100	2495440	
84	Sylhet GT 20 MW	PDB	1*20	20	18	444000	
85	Sylhet (EPL) 50MW	RPP	2*25	50	44	1038720	
86	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	21	436920	Engine problem
87	Summit Bibiana- 2	IPP	1*222+1*119	341	270	7452950	FGMO
88	Sylhet (Desh) 10MW	RPP	6*1.95	10	9	214200	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>1274</b>	<b>32098885</b>	
89	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
	Bheramara (HVDC )	Imported power	2*500	1000	769	18749090	
90	Khulna (KPCL-1 & 3)	IPP	19*6.5	110	88	1510560	Engine problem
91	Khulna (KPCL-2)	QRPP	7*17	115	99	2157120	Engine problem
92	Faridpur Peaking	PDB	8*6.89	54	41	396000	
93	Khulna CCPP 225MW	NWPGL	1*150+1*75	230	241	3927360	
94	Gopalganj Peaking	PDB	16*6.98	109	55	597120	
95	Bheramara 360 MW	NWPGL	1*278+1*132	410	410	9785376	
96	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	925500	
97	Khulna (Aggreko) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
98	Bangla Trak Noapara	IPP	70*1.4	100	94	736320	Engine problem
<b>Khulna Area Total</b>				<b>2214</b>	<b>1837</b>	<b>38784446</b>	
99	Summit Barisal 110 MW	IPP	7*17.076	110	110	2640000	
100	Barisal GT: Unit- 1, 2	PDB	2*20	30	24	166869	
101	Bhola (Venture) 33MW	RPP	1*34.50	33	38	693998	
102	Bhola CCPP 194MW	PDB	2*63+1*68	194	118	2543000	
103	Bhola Aggreko 95MW	QRPP	96*1.10	95	97	2269005	
<b>Barisal Area Total</b>				<b>462</b>	<b>387</b>	<b>8312872</b>	
104	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
105	Baghabari Peaking 50MW	PDB	6*8.9	52	50	426432	
106	Bera Peaking	PDB	9*8.29	71	49	445529	
107	Amnura 50MW	QRPP	7*7.79	50	50	1064360	
108	Katakhal (Northern)	QRPP	6*8.9	50	50	1161984	
109	Katakhal Peaking	PDB	6*8.7	50	32	275049	
110	Sirajgonj Unit-1 225MW	NWPGL	1*150+1*75	210	215	4869109	FGMO
111	Sirajgonj Unit-2 225MW	NWPGL	1*150+1*75	220	220	0	
	Sirajgonj Unit-3 225MW	NWPGL	1*150+1*75	141	0	0	On test
	Sirajgonj Unit-4 414 MW (Gas)	SNWPGL	1*272+1*132 MW	0	0	0	On test
112	Santihar Peaking	PDB	6*8.7	50	33	326490	
113	Bogra (GBB)	RPP	6*4	22	22	500160	
114	Bogra (EPL)	RPP	5*3.3+5*2	10	10	229752	Engine problem
115	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	249156	
116	Rajlanka 52 MW	IPP	6*8.92	52	52	1088160	
117	Chapainawabganj-100 MW	PDB	12*8.924	104	102	1222792	
<b>Rajshahi Area Total</b>				<b>1264</b>	<b>896</b>	<b>11861973</b>	
118	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling
	Barapukuria Unit-2	PDB	1*125	85	0	0	Coal shortage
119	Barapukuria Unit-3	PDB	1*275	274	170	4143600	Coal shortage
120	Rangpur GT	PDB	1*20	20	9	97	