

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	74	1685000	
	Ghorasal ST: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal ST: Unit-4	PDB	1*210	180	15	0	Synchronized at 20:05.
	Ghorasal ST: Unit-5	PDB	1*210	190	120	2853900	Gas shortage
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	350	7400172	
	Ghorasal 78MW (MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal (Regent)	IPP	3*43.35	108	22	1285590	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	370	7598080	Gas shortage
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	348	6910000	
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	225	4528125	GT-2 Under Maint.,
10	Meghnaghat (IEL)	QRPP	12*9	100	15	514560	Low demand
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	15	528168	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	15	507277	Low demand
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	10	487448	Low demand
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	282312	Engine problem
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Under maint.
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	106	2730000	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	10	503040	Low demand
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	0	0	Under maint.
21	Pagla (DPA)	QRPP	100*0.5	50	51	739200	
22	Gagnagar (Orion)	IPP	12*8.924	102	7	255024	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	34	495984	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	807840	
25	Kodda 149 MW	BPDB-RPCL	9*17.06	149	16	486720	Low demand
26	Northern 55 MW	IPP	3*19.3	55	56	681091	
27	Southern 55MW	IPP	3*19.3	55	0	754380	Reserve
28	Bosila 108MW	IPP	12*9.0	108	59	783360	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*8.67+4*8.73	80	49	1115180	Engine problem
30	Summit Madona	SIPP, REB	4*8.73	33	33	825100	
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	652600	
32	Gazipur (RPCL)	IPP	6*8.9	52	42	671280	Engine problem
33	Tongi GT	PDB	1* 105	105	0	90657	Under maint.
34	Summit Gazipur	IPP	18*17.076	300	240	3126326	Engine problem
	APR Energy, Keraniganj	IPP	236*1.4	300	0	0	Reserve
35	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
36	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
	Summit Gazipur-1. 150MW	IPP	149 MW	149	92	1523520	Low demand
Dhaka area Total				5848	2480	50821934	
37	Chittagong ST-1 (Raozan)	PDB	1*210	180	80	1900000	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
38	Raozan 25 MW (RPCL)	IPP	3*8.9	25	16	274880	Engine problem
	Teknaf Solartech 20MW	Teknaf Solartech Energ	28MW	0	0	89100	
39	Patenga 50MW	IPP	8*6.98	50	50	588000	
40	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	143	3266975	unit # 05 under maint.
41	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
42	Sikalbaha 225MW	PDB	1*150+1*175	225	216	5186805	
43	Sikalbaha Peaking GT	PDB	1*150	150	135	1655552	
44	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	42	757440	Engine problem
45	Hathazari peaking	PDB	1*8.9	98	64	592424	
46	Dohazari Peaking	PDB	6*17	102	49	483364	
47	Juldah (Acorn)	QRPP	8*13.45	100	103	1802280	
48	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	19	459408	
*	Malancha, Ctg. EPZ (Uniled)		5*8.73+3*9.34	0	32	705120	
49	Chittagong ECPV 108 MW	IPP	16*7	108	86	1288320	Engine problem
Chittagong area Total				1561	1035	19049468	
50	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	120	2899550	
	Ashuganj ST: Unit- 5	APSCL	1*150	134	105	2514518	Gas shortage
51	Ashuganj CAPP 225 MW	APSCL	1*142+1*75	221	202	4574000	FGMO
52	Ashuganj CAPP(North)	APSCL	1*360	360	360	8966100	
53	Ashuganj CAPP(South)	APSCL	1*360	360	334	6827000	FGMO
54	Ashuganj Engines TSK	APSCL	14*3.968	46	44	349216	
55	Ashuganj (Precision) 55MW	RPP	15*4	55	5	150240	Gas shortage
56	Ashuganj (Uniled) 53MW	QRPP	14*4	53	5	120000	Gas shortage
57	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	68	1672727	Gas shortage
58	Ashuganj (Midland) 51MW	IPP	6*9.34	51	0	0	Development work
59	B Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	528168	
60	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	0	Reserve
61	Chandpur CAPP	PDB	1*106+1*57	163	155	3657860	
62	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	515988	
63	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	190980	Engine problem
**	Tripura	Imported power	0	160	156	2540160	
64	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	33	723200	
65	Lakdhanvi 52 MW	IPP	6*8.92	52	0	7760	Line over load
66	Summit Cornilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	21	448300	
67	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Comilla Area Total				2541	1722	36755767	
68	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	46	1030200	Gas shortage
69	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	400608	
70	Jamalpur 95MW	IPP	12*8.924	95	48	652800	Low demand
71	Sarishabari (Solar)	IPP	1*3	3	0	14200	
72	Uniled Mymensingh PPL	IPP	200	200	185	2904000	
Mymensingh Area Total				522	301	5001808	
73	Fenchugonj CAPP-1	PDB	2*32+1*33	70	58	1342000	
74	Fenchugonj CAPP-2	PDB	2*35+1*35	90	60	907760	
75	Kushara 163 MW CAPP GT	IPP	1*109+1*54	163	163	3159949	FGMO.
76	Shajbazar 330 MW	PDB	3*110	330	318	6933756	
77	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	44	828000	
78	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	50	887000	
79	Hobganj 11MW	SIPP, REB	4*2.90	11	11	244848	
80	Shajbazar GT: Unit- 8, 9	PDB	2*35	66	65	1437000	
81	Shajbazar 86MW	RPP	32*2.90	86	86	1419840	
82	Shajbazar (EPL) 50MW	RPP	27*2.0	50	44	844200	
83	Sylhet GT 150 MW	PDB	1*142	142	128	2945610	
84	Sylhet GT 20 MW	PDB	1*20	20	19	114000	
85	Sylhet (EPL) 50MW	RPP	27*2	50	46	818000	
86	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	28	412608	
87	Summit Bibiana- 2	IPP	1*222+1*119	341	325	7438000	FGMO
88	Sylhet (Desh) 10MW	RPP	6*1.95	10	9	216540	
Sylhet Area Total				1549	1454	29049111	
89	Bheramara GT-1,2,3	PDB	3*20	46	0	0	
	Bheramara (HVDC)	Imported power	2*500	1000	780	18580363	
90	Khulna (KPCL-1 & 3)	IPP	19*6.5	110	10	336480	Low demand
91	Khulna (KPCL-2)	QRPP	7*17	115	33	667200	Low demand
92	Faridpur Peaking	PDB	8*6.89	54	0	0	Reserve
93	Khulna CAPP 225MW	NWPGL	1*150+1*75	230	120	3054720	Low demand
94	Gopalganj Peaking	PDB	16*6.98	109	76	677376	
95	Bheramara 360 MW	NWPGL	1*278+1*132	410	420	8201664	
96	Noapara (KZA) 40MW	QRPP	5*8.5	40	32	368250	Engine problem
97	Khulna (Aggreko) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
98	Bangla Trak Noapara	IPP	70*1.4	100	0	46080	Reserve
Khulna Area Total				2214	1471	31932133	
99	Summit Barisal 110 MW	IPP	7*17.076	110	110	1397760	
100	Barisal GT: Unit- 1, 2	PDB	2*20	30	0	0	Reserve
101	Bhola (Venture) 33MW	RPP	1*34.50	33	30	486925	
102	Bhola CAPP 194MW	PDB	2*63+1*68	194	136	3043000	ST under maint.
103	Bhola Aggreko 95MW	QRPP	96*1.10	95	96	1806162	
Barisal Area Total				462	372	6733847	
104	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
105	Baghabari Peaking 50MW	PDB	6*8.9	52	50	331320	
106	Bera Peaking	PDB	9*8.29	71	52	409888	
107	Amnura 50MW	QRPP	7*7.79	50	50	876590	
108	Katakhal (Northern)	QRPP	6*8.9	50	50	762672	
109	Katakhal Peaking	PDB	6*8.7	50	36	363700	
110	Sirajgonj Unit-1 225MW	NWPGL	1*150+1*75	210	221	4936854	FGMO
111	Sirajgonj Unit-2 225MW	NWPGL	1*150+1*75	220	188	0	FGMO.
	Sirajgonj Unit-3 225MW	NWPGL	1*150+1*75	141	0	0	On test
	Sirajgonj Unit-4 414 MW (Gas)	SNWPGL	1*272+1*132 MW	0	0	0	On test
112	Santihar Peaking	PDB	6*8.7	50	33	383760	
113	Bogra (GBB)	RPP	6*4	22	22	484560	
114	Bogra (EPL)	RPP	5*3.3+5*2	10	12	271728	
115	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	199980	
116	Rajlanka 52 MW	IPP	6*8.92	52	52	604320	
117	Chapainawabganj-100 MW	PDB	12*8.924	104	64	603844	
Rajshahi Area Total				1264	841	10229216	
118	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling
	Barapukuria Unit-2	PDB	1*125	85	0	0	Coal shortage
119	Barapukuria Unit-3	PDB	1*275	274	160	3899100	Coal shortage
120	Rangpur GT	PDB	1*20	20	10	92000	
121	Saidpur GT	PDB	1*20	20	18		