

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	70	1535000	
	Ghorasal ST: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal ST: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	190	4599000	
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	380	8990581	
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	79	1745184	
4	Ghorasal (Regent)	IPP	34*3.35	108	92	1684227	Engine problem
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	365	8431610	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	96	463000	Engine problem
8	Haripur Power CCGP 360MW	IPP	1*235+1*125	360	355	7923000	
9	Meghnaghat CCGP 450MW	IPP	2*150+1*150	450	450	9455875	
10	Meghnaghat (IEL)	QRPP	12*8.9	100	100	1096320	
11	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	98	1321800	
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	47	865119	Engine problem
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	86	1032234	Engine problem
15	Narsingdi (Doreen)	SIPP, REB	8*2.90	22	22	459720	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Under maint.
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	0	0	Gas restriction
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	80	371520	Engine problem
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	70	1040640	Engine problem
20	Siddhirgonj CCGP-335 MW	EGCB	1*217	217	0	0	Under maint.
21	Pagla (DPA)	QRPP	100*0.5	50	45	667000	
22	Gagnagar (Orion)	IPP	12*8.924	102	102	788256	
23	Katpotti 51 MW	IPP	7*7.9	51	39	823776	
24	Banco Energy 54MW	IPP	3*18	54	54	636480	
25	Kodda 149 MW	BPDB-RPCL	9*17.06	149	149	2009760	
26	Northern 55 MW	IPP	3*19.3	55	56	988134	
27	Southern 55MW	IPP	3*19.3	55	55	1329450	
28	Bosila 108MW	IPP	12*8.775+1*3.5	108	8	277440	Engine problem
29	Summit Power,(Madhabdi+Ashu)	SIPP,REB	3*3.67+4*8.73	80	57	1275000	Engine problem
30	Summit Maona	SIPP,REB	4*8.73	33	33	809770	
31	Summit Rugganj	SIPP,REB	4*8.73	33	33	788500	
32	Gazipur (RPCL)	IPP	6*8.9	52	34	646620	Engine problem
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur	IPP	18*17.076	300	268	4952940	Engine problem
35	APR Energy , Keraniganj	IPP	236*1.4	300	57	117957	Low demand
36	Bramhangoan 100 MW (Aggre)	IPP	100	100	30	55680	Low demand
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	51	79450	Low demand
38	Summit Gazipur-1 150MW	IPP	149 MW	149	113	1929600	Engine problem
Dhaka area Total				5848	3764	69190643	
39	Chittagong ST-1 (Raozan)	PDB	1*210	180	150	3400000	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	140	3200000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	469440	
	Teknaf Solartech 20MW	Teknaf Solartech Energy	28MW	0	0	112890	
41	Patenga 50MW	IPP	8*6.98	50	40	871680	Engine problem
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	142	3236985	Unit-5 under maint.
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	228	4313439	
45	Sikalbaha Peaking GT	PDB	1*150	150	0	78077	Gas shortage
46	Sikalbaha (Energyis)	RPP	4*12.5+2*11.9+1*13+1*11	51	40	935520	Engine problem
47	Hathazari peaking	PDB	11*8.9	98	73	886440	
48	Dohazari Peaking	PDB	6*17	102	51	585345	
49	Juddah (Acom)	QRPP	8*13.45	100	90	2080080	Engine problem
50	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	22	501408	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	18	564480	
51	Chittagong ECPV 108 MW	IPP	16*7	108	98	2076480	Engine problem
Chittagong area Total				1561	1117	23312264	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	90	2174920	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	90	2153870	Gas shortage
53	Ashuganj CCGP 225 MW	APSCL	1*142+1*175	221	222	5061000	FGMO
54	Ashuganj CCGP(North)	APSCL	1*360	360	360	8989000	
55	Ashuganj CCGP(South)	APSCL	1*360	360	298	7447500	FGMO
56	Ashuganj Engines TSK	APSCL	14*3.968	45	19	429120	Gas shortage
57	Ashuganj (Precision) 55MW	RPP	15*4	55	0	0	Under maint.
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*116	195	68	1655999	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	0	0	Under maint.
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	1321800	
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	40	202360	
63	Chandpur CCGP	PDB	1*106+1*57	163	140	3262920	
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	509592	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	256140	
**	Tripura	Imported power	0	160	174	3511680	
66	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	25	690500	
67	Lakdhami 52 MW	IPP	6*8.92	52	0	14242	Line O/L
68	Summit Comilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	21	515870	Engine problem
69	Daudkandi bangla trak	IPP	154*1.4	200	50	94080	Low demand
Comilla Area Total				2541	1720	38410593	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	85	1899020	Gas shortage
71	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	451872	
72	Jamalpur 95MW	IPP	12*8.924	95	73	694080	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	0	
74	United Mymensingh PPL	IPP	200	200	168	3775200	Engine problem
Mymensingh Area Total				522	348	6821072	
75	Fenchugonj CCGP-1	PDB	2*32+1*33	70	56	128000	
76	Fenchugonj CCGP-2	PDB	2*35+1*35	90	50	1313520	
77	Kushira 163 MW CCGP GT	IPP	1*109+1*54	163	163	3195515	
78	Shajibazar 330 MW	PDB	3*110	330	303	7002759	FGMO.
79	Fenchugonj (Barakatullah) 51M	RPP	19*2.90	51	50	1048800	
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	50	1037000	
81	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	214080	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	55	1466000	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	89	1715520	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	47	916560	
85	Sylhet GT 150 MW	PDB	1*142	142	0	0	Under maint.
86	Sylhet GT 20 MW	PDB	1*20	20	19	455000	
87	Sylhet (EPL) 50MW	RPP	27*2	50	41	913220	Engine problem
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	24	492720	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	280	7368700	FGMO
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	9	216720	
Sylhet Area Total				1549	1247	28636114	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	718	17264727	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	110	101	846240	Engine problem
93	Khulna (KPCL-2)	QRPP	7*17	115	98	1198080	Engine problem
94	Fariapur Peaking	PDB	8*6.89	54	42	391680	
95	Khulna CCGP 225MW	NWPGCL	1*150+1*75	230	240	3576000	
96	Gopalganj Peaking	PDB	16*6.98	109	65	502912	
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	350	5930496	Gas restriction
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	32	497625	Engine problem
99	Khulna (Aggreco) 55MW Bangla Trak Noapara	QRPP IPP	71*0.85 70*1.4	100 100	96	558720	Contract Expired
Khulna Area Total				2214	1742	30766480	
100	Summit Barisal 110 MW	IPP	7*17.076	110	96	1731840	Low demand
101	Barisal GT: Unit-1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	33	685006	
103	Bhola CCGP 194MW	PDB	2*63+1*68	194	154	4198940	
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	97	2266789	
Barisal Area Total				462	380	8882575	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	253888	
107	Bera Peaking	PDB	9*8.29	71	53	423888	
108	Amnura 50MW	QRPP	7*7.79	50	50	875090	
109	Katakhal (Northern)	QRPP	6*8.9	50	43	984288	Engine problem
110	Katakhal Peaking	PDB	6*8.7	50	38	285560	
111	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas restriction
112	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	220	0	FGMO.
113	Sirajgonj Unit-3 225MW	NWPGCL	1*150+1*75	141	0	0	On test
	Sirajgonj Unit-4 414 MW(Gas)	SNWPGCL	1*272+1*132 MW	0	301	7119546	On test
114	Santahar Peaking	PDB	6*8.7	50	0	0	Under maint.
115	Bogra (GBB)	RPP	6*4	22	22	507840	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	11	232524	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	223002	
118	Rajlanka 52 MW	IPP	6*8.92	52	44	826080	Engine problem
119	Chapainawabganj-100 MW	PDB	12*8.924	104	90	570672	
Rajshahi Area Total				1264	933	12302378	
120	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling
	Barapukuria Unit-2	PDB	1*125	85	0	0	Coal shortage
121	Barapukuria Unit-3	PDB	1*275	274	150	3752100	
122	Rangpur GT	PDB	1*20	20	12	86000	
123	Saidpur GT	PDB	1*20	20	18	125000	