

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
					Generation		
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	68	1462000	
	Ghorasal ST: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Unit-4 GT	PDB	1*210	180	251	4988000	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Gas shortage
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	250	5908145	Gas shortage
3	Ghorashal 78MW (MAX)	IPP	2*40	78	0	0	Gas shortage
4	Ghorashal (Regent)	IPP	3*43.35	108	0	0	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Under maint.
7	Haripur NEPC 110MW	IPP	8*15	110	110	402000	
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	354	8249000	
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	0	0	Under maint.
10	Meghnaghat (IEL)	QRPP	12*9	100	100	1507200	
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	100	1374792	
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	863140	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	100	1138406	
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	16	366768	Engine problem
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	60	2391000	Frequency control
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	100	237120	
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	73	1168310	Engine problem
20	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	219	5140293	
21	Pagla (DPA)	QRPP	100*0.5	50	40	566940	
22	Gagnagar (Orion)	IPP	12*8.924	102	102	1151568	
23	Katpotti 51 MW	IPP	7*7.9	51	18	293616	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	1069200	
25	Kodda 149 MW	BPDB-RPCL	9*17.06	149	149	735360	
26	Northern 55 MW	IPP	3*19.3	55	55	945386	
27	Southern 55MW	IPP	3*19.3	55	45	1036740	Engine problem
28	Bosila 108MW	IPP	12*9.75+1*3.5	108	46	935040	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*8.67+4*9.73	80	57	1233780	Engine problem
30	Summit Masara	SIPP, REB	4*8.73	33	25	576800	Engine problem
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	823100	
32	Gazipur (RPCL)	IPP	6*8.9	52	42	668912	Engine problem
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur	IPP	18*17.076	300	281	4674430	Engine problem
35	APR Energy , Keraniganj	IPP	236*1.4	300	0	52414	Reserve
36	Bramhangaoan 100 MW (Aggrek)	IPP	100	100	71	142339	Low demand
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	101	176001	
38	Summit Gazipur-1. 150MW	IPP	149 MW	149	113	2255040	Engine problem
Dhaka area Total				5848	3088	52533840	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	150	3500000	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	150	3400000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	26	308340	
	Teknaf Solartech 20MW	Teknaf Solartech Energ	28MW	0	0	137970	
41	Patenga 50MW	IPP	8*6.98	50	46	711840	
42	Kaptal Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	88	1949862	Unit-2 under maint.
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	203	4865170	Gas shortage
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Gas shortage
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	50	819840	
47	Hathazari peaking	PDB	1*8.9	98	72	460047	
48	Dohazari Peaking	PDB	6*17	102	51	266698	
49	Juidah (Acorn)	QRPP	8*13.45	100	100	1783560	
	Juidah 100 MW Unit-3	IPP	100 MW	0	0	0	On test
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	22	529970	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	6	609120	
51	Chattogram ECPV 108 MW	IPP	16*7	108	98	1480320	Engine problem
Chattogram area Total				1561	1062	20822737	
52	Ashuganj ST: Unit- 3	APSCl	1*150	135	80	1998972	Gas shortage
	Ashuganj ST: Unit- 4	APSCl	1*150	129	100	2384695	Gas shortage
	Ashuganj ST: Unit- 5	APSCl	1*150	134	0	0	Gas shortage
53	Ashuganj CCPP 225 MW	APSCl	1*142+1*75	221	130	3150000	Gas shortage
54	Ashuganj CCPP(North)	APSCl	1*360	360	360	8973100	
55	Ashuganj CCPP(South)	APSCl	1*360	360	301	7348500	FGMO
56	Ashuganj Engines TSK	APSCl	14*3.968	45	38	453672	Gas shortage
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	154080	
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	77	1823272	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	0	0	Under maint.
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	1374792	
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	42	135112	
63	Chandpur CCPP	PDB	1*106+1*57	163	100	2360200	ST Under maint.
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	19	451368	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	189900	Engine problem
**	Tripura	Imported power	0	160	144	2818560	
66	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	33	676500	
67	Lakdhanvi 52 MW	IPP	6*8.92	52	52	680597	
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	21	393120	Engine problem
69	Daudkandi bangla trak	IPP	154*1.4	200	110	151680	Low demand
Cumilla Area Total				2541	1710	35636120	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	46	1027120	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	483408	
72	Jamalpur 95MW	IPP	12*8.924	95	64	542400	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	13350	
74	United Mymensingh PPL	IPP	200	200	200	3741600	
Mymensingh Area Total				522	332	5807878	
75	Fenchugonj CCPP-1	PDB	2*32+1*33	70	55	1276000	
76	Fenchugonj CCPP-2	PDB	2*35+1*35	90	50	1002000	
77	Kushibara 163 MW CCPP GT	IPP	1*109+1*54	163	130	3449937	Frequency control
78	Shajibazar 330 MW	PDB	3*110	330	137	3312144	FGMO.
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	50	798000	
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	50	1191000	
81	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	237024	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	40	1433000	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	86	1820160	
84	Shajibazar (EPL) 50MW	RPP	2*72.0	50	47	978840	
85	Sylhet GT 150 MW	PDB	1*142	142	78	2197670	Frequency control
86	Sylhet GT 20 MW	PDB	1*20	20	0	8000	Reserve
87	Sylhet (EPL) 50MW	RPP	27*2	50	47	1074940	
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	25	587292	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	270	7255170	FGMO
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	232200	
Sylhet Area Total				1549	1086	26848877	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	758	16834181	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	110	0	0	Contract Expired
93	Khulna (KPCL-2)	QRPP	7*17	115	112	1286400	
94	Faridpur Peaking	PDB	8*6.89	54	30	105600	
95	Khulna CCPP 225MW	NWPGL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*6.98	109	82	416000	
97	Bheramara 360 MW	NWPGL	1*278+1*132	410	350	9494208	Frequency control
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	577500	
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	50	113280	Low demand
	Labon Chora 105 MW	IPP	105	0	91	1272000	Engine problem
Khulna Area Total				2214	1513	30099169	
100	Summit Barisal 110 MW	IPP	7*17.076	110	110	919680	
101	Barisal GT: Unit- 1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	28	458500	Engine problem
103	Bhola CCPP 194MW	PDB	2*63+1*68	194	155	4349670	FGMO
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	96	2173526	
Barisal Area Total				462	389	7901376	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	43	156273	
107	Bera Peaking	PDB	9*8.29	71	55	240926	
108	Amnura 50MW	QRPP	7*7.9	50	50	1132520	
109	Katakhal (Northern)	QRPP	6*8.9	50	35	552736	Engine problem
110	Katakhal Peaking	PDB	6*8.7	50	37	245577	
111	Sirajgonj Unit-1 225MW	NWPGL	1*150+1*75	210	176	4668354	FGMO
112	Sirajgonj Unit-2 225MW	NWPGL	1*150+1*75	220	220	5085391	
113	Sirajgonj Unit-3 225MW	NWPGL	1*150+1*75	141	0	0	On test
	Sirajgonj Unit-4 414 MW(Gas)	SNWPGL	1*272+1*132	0	0	0	On test
114	Santihar Peaking	PDB	6*8.7	50	43	160579	
115	Bogra (GBB)	RPP	6*4	22	22	478800	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	5	112788	Engine problem
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	8	166590	Engine problem
118	Rajlanka 52 MW	IPP	6*8.92	52	47	345600	Engine problem
119	Chapainawabganj-100 MW	PDB	12*8.924	104	92	565908	
Rajshahi Area Total				1264	833	13912042	
120	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling
	Barapukuria Unit-2	PDB	1*125	85	0	0	Coal shortage
121							