

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present | Peak | Energy | Remarks |
|------------------------------|--------------------------------|------------------------|-------------------------|-------------|-------------|-----------------|-----------------------|
| | | | | Capacity | Hour | Generated | |
| | | | Unit No. X Capacity | MW | MW | MW | |
| 1 | Ghorasal ST: Unit-1,2 | PDB | 2*55 | 85 | 65 | 1392000 | |
| | Ghorasal GT: Unit-3 | PDB | 1*210 | 170 | 0 | 0 | Under maint. |
| | Ghorasal GT: Unit-4 | PDB | 1*210 | 180 | 251 | 6044000 | |
| | Ghorasal ST: Unit-5 | PDB | 1*210 | 190 | 0 | 0 | Gas shortage |
| 2 | Ghorasal ST: Unit-7 | QRPP | 1*243+1*122 | 365 | 215 | 6223636 | Gas shortage |
| 3 | Ghorasal 78MW (MAX) | QRPP | 2*40 | 78 | 0 | 0 | Gas shortage |
| 4 | Ghorasal (Regent) | IPP | 3*43.35 | 108 | 0 | 0 | Engine problem |
| 5 | Haripur GT: Unit-1, 2 | SBU, PDB | 2*32 | 40 | 0 | 125500 | Gas shortage |
| 6 | Haripur 412 MW CCPP | EGCB | 1*273+1*139 | 412 | 0 | 0 | Under maint. |
| 7 | Haripur NEPC 110MW | IPP | 8*15 | 110 | 110 | 491100 | |
| 8 | Haripur Power CCPP 360MW | IPP | 1*235+1*125 | 360 | 352 | 8279000 | |
| 9 | Meghnaghat CCPP 450MW | IPP | 2*150+1*150 | 450 | 0 | 0 | Under maint. |
| 10 | Meghnaghat (IEL) | QRPP | 12*9 | 100 | 97 | 1142400 | Engine problem |
| 11 | Meghnaghat CCPP(Summit) | IPP | 2*110+1*110 | 305 | 0 | 0 | Reserve |
| 12 | Madanganj 102MW | QRPP | 6*17 | 100 | 100 | 1446528 | |
| 13 | Madanganj-55 MW | (IPP) | 3*17.08+1*11.3 | 55 | 55 | 1059636 | |
| 14 | Keraniganj (Powerpac) 100MW | QRPP | 8*13.45 | 100 | 100 | 877998 | |
| 15 | Narshingdi (Doreen) | SIPP, REB | 8*2.90 | 22 | 19 | 305172 | Engine problem |
| 16 | Siddhirgonj ST 210MW | PDB | 1*210 | 115 | 0 | 0 | Gas shortage |
| 17 | Siddhirgonj GT Unit-1 & 2 | EGCB | 2*105 | 210 | 30 | 1186000 | Gas shortage |
| 18 | Siddhirgonj (Desh) | QRPP | 96*1.2 | 100 | 85 | 329280 | Engine problem |
| 19 | Siddhirgonj (Dutch Bangla) | QRPP | 12*8.9 | 100 | 90 | 724390 | Engine problem |
| 20 | Siddhirgonj CCPP-335 MW | EGCB | 1*217 | 217 | 120 | 4472875 | |
| 21 | Pagla (DPA) | QRPP | 100*0.5 | 50 | 45 | 343280 | Line over load |
| 22 | Gagnagar (Orion) | IPP | 12*8.924 | 102 | 102 | 1745424 | |
| 23 | Katpotti 51 MW | IPP | 7*7.9 | 51 | 0 | 99360 | Reserve |
| 24 | Banco Energy 54MW | IPP | 3*18 | 54 | 54 | 1232280 | |
| 25 | Kodda 149MW | BPDB-RPCL | 9*17.06 | 149 | 133 | 945600 | Engine problem |
| 26 | Northern 55 MW | IPP | 3*19.3 | 55 | 55 | 955500 | |
| 27 | Southern 55MW | IPP | 3*19.3 | 55 | 55 | 739000 | |
| 28 | Bosila 108MW | IPP | 12*8.75+1*3.5 | 108 | 46 | 866880 | Engine problem |
| 29 | Summit Power (Madhabdi+Ashuli) | SIPP, REB | 3*8.67+4*8.73 | 80 | 57 | 1333320 | Engine problem |
| 30 | Summit Maona | SIPP, REB | 4*8.73 | 33 | 33 | 782500 | |
| 31 | Summit Rugganj | SIPP, REB | 4*8.73 | 33 | 25 | 618200 | Engine problem |
| 32 | Gazipur (RPCL) | IPP | 6*8.9 | 52 | 43 | 839316 | Engine problem |
| 33 | Tongi GT | PDB | 1* 105 | 105 | 0 | 0 | Gas shortage |
| 34 | Summit Gazipur | IPP | 18*17.076 | 300 | 273 | 3896620 | Engine problem |
| 35 | APR Energy , Keraniganj | IPP | 256*1.4 | 300 | 264 | 436637 | Low demand |
| 36 | Bramhangaoan 100 MW (Aggreko) | IPP | 100 | 100 | 40 | 64383 | Low demand |
| 37 | Aggreko Aurahati 100MW | IPP | 0.85*23+0.95*91 | 100 | 50 | 131148 | Low demand |
| 38 | Summit Gazipur-1. 150MW | IPP | 149 | 149 | 125 | 1454400 | Engine problem |
| Dhaka area Total | | | | 5848 | 3089 | 50583363 | |
| 39 | Chattogram ST-1 (Raozan) | PDB | 1*210 | 180 | 0 | 0 | Gas shortage |
| | Chittagong ST-2 (Raozan) | PDB | 1*210 | 180 | 0 | 0 | Gas shortage |
| 40 | Raozan 25 MW (RPCL) | IPP | 3*8.9 | 25 | 25 | 591840 | |
| | Teknaf Solartech 20MW | Teknaf Solartech Energ | 20 | 20 | 0 | 135000 | |
| 41 | Patenga 50MW | IPP | 8*6.98 | 50 | 46 | 1107840 | Engine problem |
| 42 | Kaptai Hydro: Unit-1,2,3,4, 5 | PDB | 2*40+3*50 | 230 | 115 | 2173161 | Unit-2,5 under maint. |
| 43 | Sikalbaha ST 60MW | PDB | 1*60 | 40 | 0 | 0 | Under maint. |
| 44 | Sikalbaha 225MW | PDB | 1*150+1*175 | 225 | 0 | 1013496 | Gas shortage |
| 45 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 145 | 934145 | HSD |
| 46 | Sikalbaha (Energis) | RPP | 4*12.5+2*11.9+1*3+1*1.5 | 51 | 32 | 968160 | |
| 47 | Hathazari peaking | PDB | 1*8.9 | 98 | 65 | 1480952 | |
| 48 | Dohazari Peaking | PDB | 6*17 | 102 | 51 | 616429 | |
| 49 | Juidah (Acorn) | QRPP | 8*13.45 | 100 | 70 | 1721160 | Line over load |
| | Juidah 100 MW Unit-3 | IPP | 0 | 0 | 106 | 1119360 | On test |
| 50 | Barakkunda (Regent) | SIPP, PDB | 8*2.90 | 22 | 22 | 537120 | |
| * | Malancha, Ctg. EPZ (United) | | 5*8.73+3*9.34 | 0 | 4 | 409920 | |
| 51 | Chattogram ECPV 108 MW | IPP | 16*7 | 108 | 105 | 2208960 | |
| Chattogram area Total | | | | 1581 | 786 | 15017543 | |
| 52 | Ashuganj ST: Unit- 3 | APSCL | 1*150 | 135 | 80 | 2076060 | Gas shortage |
| | Ashuganj ST: Unit- 4 | APSCL | 1*150 | 129 | 0 | 0 | Under maint. |
| | Ashuganj ST: Unit- 5 | APSCL | 1*150 | 134 | 80 | 2053690 | Gas shortage |
| 53 | Ashuganj CCPP 225 MW | APSCL | 1*142+1*75 | 221 | 210 | 4715000 | FGMO |
| 54 | Ashuganj CCPP(North) | APSCL | 1*360 | 360 | 360 | 8964500 | |
| 55 | Ashuganj CCPP(South) | APSCL | 1*360 | 360 | 305 | 7567000 | FGMO |
| 56 | Ashuganj Engines TSK | APSCL | 14*3.968 | 45 | 41 | 819432 | |
| 57 | Ashuganj (Precision) 55MW | RPP | 15*4 | 55 | 5 | 153120 | Gas shortage |
| 58 | Ashuganj (United) 53MW | QRPP | 14*4 | 53 | 5 | 120000 | Gas shortage |
| 59 | Ashuganj 195MW Modular | IPP | 20*9.73+1*16 | 195 | 8 | 317818 | Gas shortage |
| 60 | Ashuganj (Midland) 51MW | IPP | 6*9.34 | 51 | 51 | 1011452 | |
| | Midland 150MW | IPP | 23*7.015 | 0 | 2 | 6690 | On test |
| 61 | B. Baria (Aggreko) 85MW | QRPP | 86*1.10 | 85 | 85 | 1446528 | |
| 62 | Daudkandi Peaking 52MW | PDB | 6*8.92 | 52 | 47 | 202872 | |
| 63 | Chandpur CCPP | PDB | 1*106+1*57 | 163 | 100 | 2333410 | ST Under maint. |
| | Chandpur Desh 200MW | IPP | 0 | 0 | 0 | 15840 | On Test |
| 64 | Feni (Doreen) 22MW | SIPP, PDB | 8*2.90 | 22 | 0 | 0 | Engine problem |
| 65 | Feni, Mohipal (Doreen) | SIPP, REB | 4*2.90 | 11 | 8 | 230040 | |
| ** | Tripura | Imported power | 0 | 160 | 148 | 2684160 | |
| 66 | Jangalla (Summit) 33MW | SIPP, PDB | 4*8.73 | 33 | 33 | 735300 | |
| 67 | Lakdhanvi 52 MW | IPP | 6*8.92 | 52 | 25 | 519086 | Line over load |
| 68 | Summit Cumilla 25MW | SIPP, PDB | 3*3.67+2*6.97 | 25 | 22 | 413440 | |
| 69 | Daudkandi bangla trak | IPP | 154*1.4 | 200 | 50 | 61440 | Low demand |
| Cumilla Area Total | | | | 2541 | 1665 | 36446878 | |
| 70 | Mymensingh RPCL 210MW | IPP | 4*35+1*70 | 202 | 0 | 530050 | Gas shortage |
| 71 | Tangal (Doreen) 22MW | SIPP, PDB | 8*2.90 | 22 | 22 | 498852 | |
| 72 | Jamalpur 95MW | IPP | 12*8.924 | 95 | 77 | 1569600 | Engine problem |
| 73 | Sarishabari (Solar) | IPP | 1*3 | 3 | 0 | 9600 | |
| 74 | United Mymensingh PPL | IPP | 200 | 200 | 200 | 2529600 | |
| Mymensingh Area Total | | | | 522 | 299 | 5137702 | |
| 75 | Fenchugonj CCPP-1 | PDB | 2*32+1*33 | 70 | 55 | 1281000 | |
| 76 | Fenchugonj CCPP-2 | PDB | 2*35+1*35 | 90 | 63 | 1508160 | FGMO |
| 77 | Kushara 163 MW CCPP GT | IPP | 1*109+1*54 | 163 | 163 | 3596154 | |
| 78 | Shajibazar 330 MW | PDB | 3*110 | 330 | 242 | 5830600 | GT-1 under maint. |
| 79 | Fenchugonj (Barakatullah) 51MW | RPP | 19*2.90 | 51 | 53 | 1220400 | |
| 80 | Fenchugonj (EPL) 44MW | RPP | 12*3.5+5*2 | 44 | 50 | 1146000 | |
| 81 | Hobiganj 110MW | SIPP, REB | 4*2.90 | 11 | 11 | 220844 | |
| 82 | Shajibazar GT: Unit- 8, 9 | PDB | 2*35 | 66 | 59 | 1441000 | FGMO |
| 83 | Shajibazar 86MW | RPP | 32*2.90 | 86 | 89 | 1861440 | |
| 84 | Shajibazar (EPL) 50MW | RPP | 27*2.0 | 50 | 44 | 1014480 | |
| 85 | Sylhet GT 150 MW | PDB | 1*142 | 142 | 130 | 2443730 | |
| 86 | Sylhet GT 20 MW | PDB | 1*20 | 20 | 0 | 0 | |
| 87 | Sylhet (EPL) 50MW | RPP | 27*2 | 50 | 48 | 1105840 | |
| 88 | Shahjahanulla 25 MW | SIPP, REB | 3*9.34 | 25 | 17 | 361344 | Engine problem |
| 89 | Summit Bibiana- 2 | IPP | 1*222+1*119 | 341 | 295 | 7452500 | FGMO |
| 90 | Sylhet (Desh) 10MW | RPP | 6*1.95 | 10 | 10 | 234540 | |
| Sylhet Area Total | | | | 1549 | 1329 | 30718132 | |
| 91 | Bheramara GT-1,2,3 | PDB | 3*20 | 46 | 0 | 0 | Reserve |
| ** | Bheramara (HVDC) | Imported power | 2*500 | 1000 | 685 | 15749818 | |
| 92 | Khuina (KPCL-1 & 3) | IPP | 19*6.5 | 0 | 0 | 0 | Contract Expired |
| 93 | Khuina (KPCL-2) | QRPP | 7*17 | 115 | 77 | 619200 | Engine problem |
| 94 | Faridpur Peaking | PDB | 8*6.89 | 54 | 13 | 39360 | Engine problem |
| 95 | Khuina CCPP 225MW | NWPGCL | 1*150+1*75 | 230 | 0 | 0 | Reserve |
| 96 | Gopalganj Peaking | PDB | 16*6.98 | 109 | 40 | 205824 | |
| 97 | Bheramara 360 MW | NWPGCL | 1*278+1*132 | 410 | 330 | 8174592 | Gas shortage |
| 98 | Noapara (KZA) 40MW | QRPP | 5*8.5 | 40 | 40 | 675750 | |
| | Khuina (Aggreco) 55MW | QRPP | 71*0.85 | 0 | 0 | 0 | Contract Expired |
| 99 | Bangla Trak Noapara | IPP | 70*1.4 | 100 | 96 | 229440 | |
| | Labon Chora 105 MW | IPP | 6*18.445 | 105 | 105 | 1418400 | |
| Khuina Area Total | | | | 2209 | 1386 | 27112384 | |
| 100 | Summit Barisal 110 MW | IPP | 7*17.076 | 110 | 110 | 990720 | |
| 101 | Barisal GT: Unit- 1, 2 | PDB | 2*20 | 30 | 0 | 0 | Reserve |
| 102 | Bhola (Venture) 33MW | RPP | 1*34.50 | 33 | 21 | 359400 | Engine problem |
| 103 | Bhola CCPP 194MW | PDB | 2*63+1*68 | 194 | 155 | 4375328 | FGMO |
| 104 | Bhola Aggreko 95MW | QRPP | 96*1.10 | 95 | 98 | 1361032 | |
| Barisal Area Total | | | | 462 | 384 | 7086480 | |
| 105 | Baghabari GT 71MW | PDB | 1*71 | 71 | 0 | 0 | Gas shortage |
| | Baghabari GT 100MW | PDB | 1*100 | 100 | 0 | 0 | Under maint. |
| 106 | Baghabari Peaking 50MW | PDB | 6*8.9 | 52 | 43 | 191926 | |
| 107 | Bera Peaking | PDB | 9*8.29 | 71 | 48 | 195066 | |
| 108 | Amnura 50MW | QRPP | 7*7.9 | 50 | 50 | 826770 | |
| 109 | Katakhal (Northern) | QRPP | 6*8.9 | 50 | 43 | 172416 | Engine problem |
| | Katakhal Peaking | PDB | 6*8.7 | 50 | 46 | 174784 | Reserve |
| 111 | Sraigonj Unit-1 225MW | NWPGCL | 1*150+1*75 | 210 | 184 | 4002364 | FGMO |
| 112 | Sraigonj Unit-2 225MW | NWPGCL | 1*150+1*75 | 220 | 179 | 4145373 | FGMO |
| 113 | Sraigonj Unit-3 225MW | NWPGCL | 1*141 | 141 | 0 | 0 | On test |
| | Sraigonj Unit-4 414 MW(Gas) | SNWPGCL | 1*282 | 282 | 0 | 0 | |
| 114 | Santahar Peaking | PDB | 6*8.7 | 50 | 37 | 172484 | |
| 115 | Bogra (GBB) | RPP | 6*4 | 22 | 22 | 463440 | |
| 116 | Bogra (EPL) | RPP | 5*3.4+5*2 | 10 | 5 | 114048 | Engine problem |
| 117 | Ullapara (Summit) | SIPP, REB | 4*2.90 | 11 | 11 | 123228 | |
| 118 | Rajlanka 52 MW | IPP | 6*8.92 | 52 | 43 | 871200 | Engine problem |
| 119 | Chapainawabganj-100 MW | PDB | 12*8.924 | 104 | 66 | 353804 | |
| Rajshahi Area Total | | | | 1546 | 777 | 11806903 | |
| 120 | Barapukuria Unit-1 | PDB | 1*125 | 85 | 0 | 0 | Under overhauling |