

Date : 13-Nov-18		Page -2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	884000	#2 Under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal GT: Unit-4	PDB	1*210	180	247	6031000	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Gas shortage
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	220	5505181	Gas shortage
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	0	0	Under maint.
7	Haripur NEPC 110MW	IPP	8*15	110	110	418900	
8	Haripur Power CCGP 360MW	IPP	1*235+1*125	360	351	8052000	
9	Meghnaghat CCGP 450MW	IPP	2*150+1*150	450	225	5213125	Gas shortage
10	Meghnaghat (IEL)	QRPP	12*8.9	100	35	774720	Low demand
11	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	80	1594560	Engine problem
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	1186333	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	44	300387	Low demand
15	Narsingdi (Doreen)	SIPP, REB	8*2.90	22	16	355140	Engine problem
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	87	1989000	FGMO
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	75	649260	Engine problem
20	Siddhirgonj CCGP-335 MW	EGCB	1*217	217	0	0	Under maint.
21	Pagla (DPA)	QRPP	100*0.5	50	46	333380	
22	Gagnagar (Orion)	IPP	12*8.924	102	102	1665648	
23	Katpoti 51 MW	IPP	7*7.9	51	40	936192	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	1216440	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	133	845280	Engine problem
26	Northern 55 MW	IPP	3*19.3	55	55	1012553	
27	Southern 55MW	IPP	3*19.3	55	55	756000	
28	Bosila 108MW	IPP	12*8.775+1*3.5	108	46	876480	Engine problem
29	Summit Power,(Madhabdi+Ashu)	SIPP,REB	3*3.67+4*8.73	80	50	1109960	Engine problem
30	Summit Maona	SIPP,REB	4*8.73	33	25	602300	Engine problem
31	Summit Rugganj	SIPP,REB	4*8.73	33	25	721200	Engine problem
32	Gazipur (RPCL)	IPP	6*8.9	52	43	710424	Engine problem
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	268	3512726	Engine problem
35	APR Energy , Keraniganj	IPP	256*1.4	300	53	30651	Low demand
36	Bramhangaoan 100 MW (Aggre)	IPP	100	100	50	27411	Low demand
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	51	27645	Low demand
38	Summit Gazipur-1 150MW	IPP	149	149	105	1594080	Low demand
Dhaka area Total				5848	2781	48931976	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	0	0	Gas shortage
	Chittong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	417600	
	Teknaf Solartech 20MW	Teknaf Solartech Energ	20	20	0	94230	
41	Patenga 50MW	IPP	8*6.98	50	50	876480	
42	Kapital Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	70	1634400	Unit-2,5 under maint.
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	202	4803704	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Gas shortage
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1	51	40	995040	Engine problem
47	Hathazari peaking	PDB	11*8.9	98	84	306348	
48	Dohazari Peaking	PDB	6*17	102	51	377257	
49	Juldah (Acom)	QRPP	8*13.45	100	76	1181250	Engine problem
	Juldah 100 MW Unit-3	IPP	0	0	100	2236800	On test
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	22	510960	
*	Malancha, Ctg. EPZ (Unilted)		5*8.73+3*9.34	0	6	527040	
51	Chattogram ECPV 108 MW	IPP	16*7	108	105	1086720	
Chattogram area Total				1581	831	15048099	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	90	2511044	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	100	2414338	Gas shortage
53	Ashuganj CCGP 225 MW	APSCL	1*142+1*75	221	192	4734000	FGMO
54	Ashuganj CCGP(North)	APSCL	1*360	360	350	6205800	
55	Ashuganj CCGP(South)	APSCL	1*360	360	301	7542500	FGMO
56	Ashuganj Engines TSK	APSCL	14*3.968	45	30	859248	Gas shortage
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	152640	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	16	434909	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	51	1244524	
	Midland 150MW	IPP	23*7.015	0	5	36800	On test
61	B Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	1594560	
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	50	116040	
63	Chandpur CCGP	PDB	1*106+1*57	163	90	2151580	ST Under maint.
	Chandpur Desh 200MW	IPP	0	0	201	3129000	On Test
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	507276	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	200880	Engine problem
**	Tripura	Imported power	0	160	124	2232960	
66	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	33	783200	
67	Lakhdhari 52 MW	IPP	6*8.92	52	52	1023259	
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	13	343260	Engine problem
69	Daudkandi bangla trak	IPP	154*1.4	200	20	11520	Low demand
Cumilla Area Total				2541	1843	38349338	
70	Mymensingh RPCL 210MW	IPP	4*36+1*70	202	49	1198730	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	447696	
72	Jamnalpur 95MW	IPP	12*8.924	95	79	1855680	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	12650	
74	United Mymensingh PPL	IPP	200	200	185	2412000	Engine problem
Mymensingh Area Total				522	333	5926756	
75	Fenchugonj CCGP-1	PDB	2*32+1*33	70	57	1292000	
	Fenchugonj CCGP-2	PDB	2*35+1*35	70	77	1600080	
77	Kushia 163 MW CCGP GT	IPP	1*109+1*54	163	163	3420581	
78	Shahjibazar 330 MW	PDB	3*110	330	0	0	Under maint.
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	38	1091400	Engine problem
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	42	1081000	
81	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	219396	
82	Shahjibazar GT: Unit- 8, 9	PDB	2*35	66	57	1489000	
83	Shahjibazar 86MW	RPP	32*2.90	86	86	1873920	
84	Shahjibazar (EPL) 50MW	RPP	27*2.0	50	40	827640	Engine problem
85	Sylhet GT 150 MW	PDB	1*142	142	90	1154820	Frequency control
86	Sylhet GT 20 MW	PDB	1*20	20	0	0	
87	Sylhet (EPL) 50MW	RPP	27*2	50	48	1031800	
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	25	571056	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	260	7476300	FGMO
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	252180	
Sylhet Area Total				1549	1004	23381713	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	553	12441454	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khulna (KPCL-2)	QRPP	7*17	115	100	592250	Engine problem
94	Fandpur Peaking	PDB	8*6.89	54	25	105120	
95	Khulna CCGP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*6.98	109	35	130560	
97	Bheramara 360 MW	NWPGCL	1*276+1*132	410	0	0	Under maint.
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	948750	
	Khulna (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	96	100800	
	Labon Chora 105 MW	IPP	6*18.445	105	105	1585440	
Khulna Area Total				2209	954	15904374	
100	Summit Barisal 110 MW	IPP	7*17.076	110	54	839040	Low demand
101	Barisal GT: Unit-1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	20	442520	Engine problem
103	Bhola CCGP 194MW	PDB	2*63+1*68	194	65	1298000	
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	95	2161106	
Barisal Area Total				462	234	4740666	
105	Baghabari GT 71MW	PDB	1*71	71	0	310000	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Gas shortage
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	121560	
107	Bera Peaking	PDB	9*8.29	71	48	90611	
108	Amnura 50MW	QRPP	7*7.79	50	50	1038000	
109	Katakhal (Northern)	QRPP	6*8.9	50	43	207985	Engine problem
110	Katakhal Peaking	PDB	6*8.7	50	37	62797	
111	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
112	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	220	4720909	FGMO
113	Sirajgonj Unit-3 225MW	NWPGCL	1*141	141	6	197900	On test
	Sirajgonj Unit-4 414 MW(Gas)	SNWPGCL	1*282	282	0	0	
114	Santahar Peaking	PDB	6*8.7	50	47	221058	
115	Bogra (GBB)	RPP	6*4	22	22	463680	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	5	109152	Engine problem
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	190782	
118	Rajlanka 52 MW	IPP	6*8.92	52	44	1226400	
119	Chapainawabganj-100 MW	PDB	12*8.924	104	93	452508	
Rajshahi Area Total				1546	676	9413342	
120	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling
	Barapukuria Unit-2	PDB	1*125				