

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	38	880000	#2 under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal GT: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Gas shortage
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	300	7204963	Gas shortage
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	35	780864	Gas shortage
4	Ghorasal (Regent)	IPP	3*43.35	108	12	1345500	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	340	7052290	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	13	102000	Low demand
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	362	8076000	
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	450	10038875	
10	Meghnaghat (IEL)	QRPP	12*9	100	75	266880	Low demand
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	50	270672	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	15	616995	Low demand
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	10	90945	Low demand
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	338220	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	0	0	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	17	54720	Low demand
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	50	255360	Low demand
20	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	0	0	Gas shortage
21	Pagla (DPA)	QRPP	100*0.5	50	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	50	581616	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	47	800880	
24	Banco Energy 54MW	IPP	3*18	54	54	1070280	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	48	100800	Low demand
26	Northern 55 MW	IPP	3*19.3	55	37	661947	Low demand
27	Southern 55MW	IPP	3*19.3	55	36	181800	Low demand
28	Bosila 108MW	IPP	12*9.75+1*3.5	108	45	833280	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*9.73	80	56	1276080	Engine problem
30	Summit Maona	SIPP, REB	4*8.73	33	33	798440	
31	Summit Rugganj	SIPP, REB	4*8.73	33	25	613300	Engine problem
32	Gazipur (RPCL)	IPP	6*8.9	52	43	642348	Engine problem
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	130	541960	Low demand
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	100	512640	Low demand
Dhaka area Total				5848	2490	45989615	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	0	0	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	130	3200000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	374220	
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	110160	
41	Patenga 50MW	IPP	8*6.98	50	50	809760	
42	Kaptal Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	75	1230484	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Combustion inspection.
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Gas shortage
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	40	911520	Engine problem
47	Hathazari peaking	PDB	1*8.9	98	58	282312	
48	Dohazari Peaking	PDB	6*17	102	68	373224	
49	Juidah (Acorn)	QRPP	8*13.45	100	100	1018080	
	Juidah 100 MW Unit-3	IPP	0	0	100	1670400	On test
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	22	528672	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	27	529440	
51	Chattogram ECPV 108 MW	IPP	16*7	108	52	762240	Low demand
Chattogram area Total				1581	747	11746512	
52	Ashuganj ST: Unit- 3	APSCl	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCl	1*150	129	80	2038370	Gas shortage
	Ashuganj ST: Unit- 5	APSCl	1*150	134	80	2053690	Gas shortage
53	Ashuganj CCPP 225 MW	APSCl	1*142+1*75	221	176	4356000	FGMO
54	Ashuganj CCPP(North)	APSCl	1*360	360	250	5809500	ST Under maint.
55	Ashuganj CCPP(South)	APSCl	1*360	360	283	6852000	FGMO
56	Ashuganj Engines TSK	APSCl	14*3.968	45	10	367920	Gas shortage
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	156480	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	200727	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	51	1221316	
	Midland 150MW	IPP	23*7.015	0	5	98690	On test
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	270672	
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	9768	Reserve
63	Chandpur CCPP	PDB	1*106+1*57	163	100	2352100	ST Under maint.
	Chandpur Desh 200MW	IPP	0	0	121	2112000	On Test
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	522020	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	194400	Engine problem
**	Tripura	Imported power	0	160	118	2115840	
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	33	397800	
67	Lakdhanvi 52 MW	IPP	6*8.92	52	8	186787	Low demand
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	22	481090	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2541	1470	31917170	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	97	2374240	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	461448	
72	Jamalpur 95MW	IPP	12*8.924	95	71	991680	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	9700	
74	United Mymensingh PPL	IPP	200	200	150	1284000	Engine problem
Mymensingh Area Total				522	338	5121068	
75	Fenchugonj CCPP-1	PDB	2*32+1*33	70	57	1308000	
76	Fenchugonj CCPP-2	PDB	2*35+1*35	90	63	1503600	
77	Kushara 163 MW CCPP GT	IPP	1*109+1*54	163	130	3164465	Frequency Control.
78	Shajbazar 330 MW	PDB	3*110	330	303	7191000	FGMO
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	1168800	
80	Fenchugonj (EPL) 44MW	RPP	12*3.6+5*2	44	21	504000	Gas shortage
81	Hobiganj 110MW	SIPP, REB	4*2.90	11	11	225792	
82	Shajbazar GT: Unit- 8, 9	RPP	2*35	66	47	1437000	Frequency Control.
83	Shajbazar 86MW	RPP	32*2.90	86	86	1611840	
84	Shajbazar (EPL) 50MW	RPP	27*2.0	50	46	1101800	
85	Sylhet GT 150 MW	PDB	1*142	142	98	2421650	Frequency Control.
86	Sylhet GT 20 MW	PDB	1*20	20	0	0	Under maint.
87	Sylhet (EPL) 50MW	RPP	27*2	50	48	1087200	
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	25	528840	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	0	0	Under maint.
	Bibiyana-3 285MW	PDB	285 MW	0	270	1924600	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	214380	
Sylhet Area Total				1549	1268	25382767	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	683	12254545	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khulna (KPCL-2)	QRPP	7*17	115	32	183360	Low demand
94	Faridpur Peaking	PDB	8*6.89	54	21	85920	Low demand
95	Khulna CCPP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*6.98	109	21	341632	Low demand
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	119	3305952	ST Under maint.
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	646875	
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	0	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	90	868800	Engine problem
Khulna Area Total				2209	1006	17687084	
100	Summit Barisal 110 MW	IPP	7*17.076	110	64	299328	Low demand
101	Barisal GT: Unit-1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	27	623297	
103	Bhola CCPP 194MW	PDB	2*63+1*68	194	177	4450310	FGMO
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	97	1546261	
Barisal Area Total				462	365	6919196	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	
	Baghabari GT 100MW	PDB	1*100	100	0	0	Gas shortage
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	122424	
107	Bera Peaking	PDB	9*8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7*7.79	50	50	663970	
109	Katakhal (Northern)	QRPP	6*8.9	50	0	23246	Reserve
110	Katakhal Peaking	PDB	6*8.7	50	0	0	Reserve
111	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
112	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	185	4567282	FGMO
113	Sirajgonj Unit-3 225MW	NWPGCL	1*141	141	0	0	Gas shortage
	Sirajgonj Unit-4. 414 MW (Gas)	SNWPGCL	1*282	282	0	0	Gas shortage
114	Santahar Peaking	PDB	6*8.7	50	39	172076	
115	Bogra (GBB)	RPP	6*4	22	22	477360	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	5	123660	Engine problem
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	182286	
118	Rajlanka 52 MW	IPP	6*8.92	52	52	912480	
119	Chapainawabganj-100 MW	PDB	12*8.924	104	79	302984	Low demand
Rajshahi Area Total				1546 </			