

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
					Generation		
				Unit No. X Capacity	MW	MW	MW
1	Ghorasal ST: Unit-1,2	PDB	2'55	85	38	880000	#2 under maint.
	Ghorasal GT: Unit-3	PDB	1'210	170	0	0	Under maint.
	Ghorasal GT: Unit-4	PDB	1'210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1'210	190	120	2850750	Gas shortage
2	Ghorasal ST: Unit-7	QRPP	1'240+1'122	365	280	6257663	Gas shortage
3	Ghorasal 78MW (MAX)	QRPP	2'40	78	0	51744	Gas shortage
4	Ghorasal (Regent)	IPP	3'43.35	108	12	675363	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2'32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	347	8263220	FGMO
7	Haripur NEPC 110MW	IPP	8'15	110	0	0	Reserve
8	Haripur Power CCPP 360MW	IPP	1'235+1'125	360	305	7250000	Frequency Control.
9	Meghnaghat CCPP 450MW	IPP	2'150+1'150	450	350	8386500	Frequency Control.
10	Meghnaghat (IEL)	QRPP	12'8.9	100	7	18240	Low demand
11	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6'17	100	0	24360	Reserve
13	Madanganj-55 MW	(IPP)	3'17.08+1'11.3	55	0	34347	Reserve
14	Keraniganj (Powerpac) 100MW	QRPP	8'13.45	100	0	0	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8'2.90	22	22	175680	
16	Siddhirgonj ST 210MW	PDB	1'210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2'105	210	98	1882000	Gas Shortage.
18	Siddhirgonj (Desh)	QRPP	96'1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12'8.9	100	0	0	Reserve
20	Siddhirgonj CCPP-335 MW	EGCB	1'217	217	120	3078656	Gas shortage
21	Pagla (DPA )	QRPP	100'0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12'8.924	102	0	14256	Reserve
23	Katpotti 51 MW	IPP	7'7.9	51	32	86016	Low demand
24	Banco Energy 54MW	IPP	3'18	54	54	251640	
25	Kodda 149MW	BPDB-RPCL	9'17.06	149	0	0	Reserve
26	Northern 55 MW	IPP	3'19.3	55	36	102061	Low demand
27	Southern 55MW	IPP	3'19.3	55	0	0	Reserve
28	Bosila 108MW	IPP	12'8.75+1'13.5	108	47	159360	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3'8.67+4'8.73	80	39	1224440	Engine problem
30	Summit Maona	SIPP, REB	4'8.73	33	33	788900	
31	Summit Rugganj	SIPP, REB	4'8.73	33	25	600900	Engine problem
32	Gazipur (RPCL)	IPP	6'8.9	52	42	138360	Engine problem
33	Tongi GT	PDB	1' 105	105	0	0	Gas shortage
34	Summit Gazipur - 2	IPP	18'17.076	300	0	27590	Reserve
35	APR Energy, Keraniganj	IPP	256'1.4	300	0	0	Reserve
36	Bramhangoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85'23+0.95'91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	0	40320	Reserve
<b>Dhaka area Total</b>				<b>5798</b>	<b>2007</b>	<b>43260366</b>	
39	Chattogram ST-1 (Raozan)	PDB	1'210	180	0	0	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1'210	180	120	3000000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3'8.9	25	25	127980	
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	127170	
41	Patenga 50MW	IPP	8'6.98	50	50	236640	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	32	716000	Low water level
43	Sikalbaha ST 60MW	PDB	1'60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	Under maint.
45	Sikalbaha Peaking GT	PDB	1'150	150	120	2729383	Gas shortage
46	Sikalbaha (Energis)	RPP	4'12.5+2'11.9+1'3+1'1.5	51	50	398400	
47	Hathazari peaking	PDB	1'18.9	98	8	43360	Low demand
48	Dohazari Peaking	PDB	6'17	102	51	319287	Low demand
49	Juidah (Acorn)	QRPP	8'13.45	100	0	62520	Reserve
	Juidah 100 MW Unit-3	IPP	0	100	100	765120	
50	Barakunda (Regent)	SIPP, PDB	8'2.90	22	22	532608	
	Malancha, Ctg. EPZ (United)		5'8.73+3'9.34	0	38	555930	
51	Chattogram ECPV 108 MW	IPP	16'7	108	0	48000	Reserve
<b>Chattogram area Total</b>				<b>1681</b>	<b>616</b>	<b>9662398</b>	
52	Ashuganj ST: Unit- 3	APSCL	1'150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1'150	129	150	2157110	
	Ashuganj ST: Unit- 5	APSCL	1'150	134	108	2143852	Gas shortage
53	Ashuganj CCPP 225 MW	APSCL	1'142+1'175	221	185	4604000	FGMO
54	Ashuganj CCPP(North)	APSCL	1'360	360	260	5838500	ST Under maint.
55	Ashuganj CCPP(South)	APSCL	1'360	360	305	6975600	FGMO
56	Ashuganj Engines TSK	APSCL	14'3.968	45	39	588392	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15'4	55	5	153600	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14'4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20'9.73+1'116	195	8	200727	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6'9.34	51	25	366144	Gas shortage
	Midland 150MW	IPP	23'7.015	150	54	98690	Low demand
61	B.Baria (Aggreko) 85MW	QRPP	86'1.10	85	85	24360	
62	Daudkandi Peaking 52MW	PDB	6'8.92	52	8	6952	Low demand
63	Chandpur CCPP	PDB	1'106+1'57	163	96	2342600	ST Under maint.
	Chandpur Desh 200MW	IPP	0	200	85	645600	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8'2.90	22	22	414360	
65	Feni, Mohipal (Doreen)	SIPP, REB	4'2.90	11	11	256860	
**	Tripura	Imported power	0	160	104	1974720	
66	Jangalla (Summit) 33MW	SIPP, PDB	4'8.73	33	25	140400	
67	Lakdhanvi 52 MW	IPP	6'8.92	52	0	0	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3'3.67+2'6.97	25	22	460040	
69	Daudkandi bangla trak	IPP	154'1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1602</b>	<b>29522407</b>	
70	Mymensingh RPCL 210MW	IPP	4'35+1'70	202	156	3095640	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8'2.90	22	20	279900	
72	Jamalpur 95MW	IPP	12'8.924	95	80	350400	Engine problem
73	Sarishabari (Solar)	IPP	1'3	3	0	11850	
74	United Mymensingh PPL	IPP	200	200	80	393600	Low demand
<b>Mymensingh Area Total</b>				<b>522</b>	<b>336</b>	<b>4131390</b>	
75	Fenchugonj CCPP-1	PDB	2'32+1'33	70	40	1144000	
76	Fenchugonj CCPP-2	PDB	2'35+1'35	90	63	1502840	
77	Kushiar 163 MW CCPP GT	IPP	1'109+1'54	163	100	2550616	Machine problem.
78	Shajibazar 330 MW	PDB	3'110	330	269	6065000	FGMO
79	Fenchugonj (Barakatullah) 51MW	RPP	19'2.90	51	50	391800	
80	Fenchugonj (EPL) 44MW	RPP	12'3.9+5'2	44	21	212000	Engine problem
81	Rediganj 110 MW	SIPP, REB	4'2.90	111	11	220900	
82	Shajibazar GT: Unit- 8, 9	PDB	2'35	66	54	1345000	FGMO
83	Shajibazar 86MW	RPP	32'2.90	86	89	624000	
84	Shajibazar (EPL) 50MW	RPP	27'2.0	50	49	596160	
85	Sylhet GT 150 MW	PDB	1'142	142	78	2032810	Frequency Control.
86	Sylhet GT 20 MW	PDB	1'20	20	0	0	Under maint.
87	Sylhet (EPL) 50MW	RPP	27'2	50	49	568320	
88	Shahjahanulla 25 MW	SIPP, REB	3'9.34	25	25	528912	
89	Summit Bibiana- 2	IPP	1'222+1'119	341	0	0	Under maint.
	Bibiyana-3 285MW	PDB	285 MW	0	0	2618200	On test
90	Sylhet (Desh) 10MW	RPP	6'1.95	10	9	57420	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>907</b>	<b>20457878</b>	
91	Bheramara GT-1,2,3	PDB	3'20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2'500	1000	679	9959272	
92	Khuina (KPCL-1 & 3)	IPP	19'6.5	0	0	0	Contract Expired
93	Khuina (KPCL-2)	QRPP	7'17	115	40	210240	Low demand
94	Faridpur Peaking	PDB	8'6.89	54	30	156960	
95	Khuina CCPP 225MW	NWPGCL	1'150+1'175	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16'6.98	109	65	336640	Low demand
97	Bheramara 360 MW	NWPGCL	1'278+1'132	410	200	6149088	ST Under maint.
98	Noapara (KZA) 40MW	QRPP	5'8.5	40	40	235125	
	Khuina (Aggreco) 55MW	QRPP	71'0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70'1.4	100	0	0	Reserve
	Labon Chora 105 MW	IPP	6'18.445	105	105	503520	
<b>Khuina Area Total</b>				<b>2209</b>	<b>1159</b>	<b>17550845</b>	
100	Summit Barisal 110 MW	IPP	7'17.076	110	48	208320	Low demand
101	Barisal GT: Unit- 1, 2	PDB	2'20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1'34.50	33	25	437500	Engine problem
103	Bhola CCPP 194MW	PDB	2'63+1'68	194	30	2357000	FGMO,GT-2 & ST under ma
104	Bhola Aggreko 95MW	QRPP	96'1.10	95	97	1022831	
<b>Barisal Area Total</b>				<b>462</b>	<b>200</b>	<b>4025651</b>	
105	Baghabari GT 71MW	PDB	1'71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1'100	100	0	0	Gas shortage
106	Baghabari Peaking 50MW	PDB	6'8.9	52	0	0	Reserve
107	Bera Peaking	PDB	9'8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7'7.79	50	50	172810	
109	Katakhal (Northern)	QRPP	6'8.9	50	0	0	Reserve
110	Katakhal Peaking	PDB	6'8.7	50	0	0	Reserve
111	Sraigonj Unit-1 225MW	NWPGCL	1'150+1'175	210	0	0	Gas shortage
112	Sraigonj Unit-2 225MW	NWPGCL	1'150+1'175	220	174	3894300	Engine problem
113	Sraigonj Unit-3 225MW	NWPGCL	1'141	141	0	0	Gas shortage
	Sraigonj Unit-4. 414 MW(Gas)	SNWPGCL	1'282	282	0	0	Gas shortage
114	Santabar Peaking	PDB	6'8.7	50	39	160368	
115	Bogra (GBB)	RPP	6'4	22	22	359520	
116	Bogra (EPL)	RPP	5'3.3+5'2	10	5	121716	Engine problem
117	Ullapara (Summit)	SIPP, REB	4'2.90	11	11	159156	
118	Rajlanka 52 MW	IPP	6'8.92	52	52	216000	
119	Chapainawabganj-100 MW	PDB	12'8.924	104	29	170880	Low demand
<b>Rajshahi Area Total</b>				<b>1546</b>	<b>382</b>	<b>5054550</b>	