

Date : 31-Dec-18							Page -2
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	740000	#2 under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	0	30000	Under maint.
	Ghorasal GT: Unit-4	PDB	1*210	180	200	1462000	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	250	4808263	Frequency control
3	Ghorashal 78MW (MAX)	QRPP	2*40	78	20	402976	Gas shortage
4	Ghorashal (Regent)	IPP	34*3.35	108	12	783045	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	345	8403068	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CCGP 360MW	IPP	1*235+1*125	360	336	7336000	Frequency control
9	Meghnaghat CCGP 450MW	IPP	2*150+1*150	450	380	8492750	Frequency control
10	Meghnaghat (IEL)	QRPP	12*8.9	100	0	0	Reserve
11	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	0	0	Reserve
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	30	64313	Low demand
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	0	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	252828	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	157	2399000	FGMO
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	0	Reserve
20	Siddhirgonj CCGP-335 MW	EGCB	1*217	217	180	2092164	Low demand
21	Pagla (DPA )	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	7	18720	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	24	194160	Low demand
24	Banco Energy 54MW	IPP	3*18	54	55	254520	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	0	0	Reserve
26	Northern 55 MW	IPP	3*19.3	55	18	153227	Low demand
27	Southern 55MW	IPP	3*19.3	55	0	0	Reserve
28	Bosila 108MW	IPP	12*8.775+1*3.5	108	46	173760	Engine problem
29	Summit Power,(Madhabdi+Ashu)	SIPP,REB	3*3.67+4*8.73	80	57	1090320	Engine problem
30	Summit Maona	SIPP,REB	4*8.73	33	33	523900	
31	Summit Rugganj	SIPP,REB	4*8.73	33	33	460400	
32	Gazipur (RPCL)	IPP	6*8.9	52	8	24624	Low demand
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	27	72763	Low demand
35	APR Energy , Keranigonj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggre	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1 150MW	IPP	149	149	0	0	Reserve
<b>Dhaka area Total</b>				<b>5798</b>	<b>2275</b>	<b>40232801</b>	
39	Chattoogram ST-1 (Raozan)	PDB	1*210	180	0	0	Gas shortage
	Chittogong ST-2 (Raozan)	PDB	1*210	180	120	3100000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	77940	
	Teknaf Solartech 20MW Teknaf Solartech Energ		20	20	0	130680	
41	Patenga 50MW	IPP	8*6.98	50	50	155520	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	42	805000	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
45	Sikalbaha Peaking GT	PDB	1*150	150	130	2390982	FGMO
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*11	51	51	244320	
47	Hathazari peaking	PDB	11*8.9	98	40	75120	
48	Dohazari Peaking	PDB	6*17	102	68	217483	
49	Juldah (Acom)	QRPP	8*13.45	100	50	81840	Low demand
	Juldah 100 MW Unit-3	IPP	0	100	80	391680	
50	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	22	389424	
	* Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	42	493920	
51	Chattoogram ECPV 108 MW	IPP	16*7	108	32	73920	Low demand
<b>Chattoogram area Total</b>				<b>1681</b>	<b>752</b>	<b>8627829</b>	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	100	2533120	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	100	2492482	Gas shortage
53	Ashuganj CCGP 225 MW	APSCL	1*142+1*75	221	184	4704000	FGMO
54	Ashuganj CCGP(North)	APSCL	1*360	360	0	0	Reserve
55	Ashuganj CCGP(South)	APSCL	1*360	360	300	6809000	FGMO
56	Ashuganj Engines TSK	APSCL	14*3.968	45	40	619416	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	30	400800	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	85000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	73	853090	Low demand
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	51	499693	
	Midland 150MW	IPP	23*7.015	150	10	48500	Low demand
61	B.Barria (Aggreko) 85MW	QRPP	86*1.10	85	85	481050	
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	6640	Reserve
63	Chandpur CCGP	PDB	1*106+1*57	163	96	1961249	ST Under maint.
	Chandpur Desh 200MW	IPP	0	200	31	127680	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	336276	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	134460	Engine problem
**	Tripura	Imported power	0	160	106	1821120	
66	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	24	104500	Low demand
67	Lakdhanvi 52 MW	IPP	6*8.92	52	0	0	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	22	413570	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1287</b>	<b>24431646</b>	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	164	3573200	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	322308	
72	Jampur 95MW	IPP	12*8.924	95	79	289920	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	13750	
74	United Mymensingh PPL	IPP	200	200	7	146400	Low demand
<b>Mymensingh Area Total</b>				<b>522</b>	<b>272</b>	<b>4345578</b>	
75	Fenchugonj CCGP-1	PDB	2*32+1*33	70	24	145000	
	Fenchugonj CCGP-2	PDB	2*35+1*35	90	32	592000	
77	Kushara 163 MW CCGP GT	IPP	1*109+1*54	163	0	0	Reserve
78	Shajibazar 330 MW	PDB	3*110	330	138	3221000	FGMO
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	22	229200	
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	20	268000	Engine problem
81	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	168192	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	52	1132000	FGMO
83	Shajibazar 86MW	RPP	32*2.90	66	66	501120	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	49	600480	
85	Sylhet GT 150 MW	PDB	1*142	142	98	814200	
86	Sylhet GT 20 MW	PDB	1*20	20	0	0	Reserve
87	Sylhet (EPL) 50MW	RPP	27*2	50	25	354280	Low demand
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	0	0	High voltage
89	Summit Bibiana- 2	IPP	1*222+1*119	341	290	7428084	FGMO
	Bibiana-3 285MW	PDB	285 MW	0	0	0	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	0	0	High voltage
<b>Sylhet Area Total</b>				<b>1549</b>	<b>847</b>	<b>15453556</b>	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	665	10173091	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khulna (KPCL-2)	QRPP	7*17	115	16	45120	Low demand
94	Fandpur Peaking	PDB	8*6.89	54	36	137280	
95	Khulna CCGP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*6.98	109	26	107392	
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	350	7580448	Frequency control
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	188625	
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	0	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	105	343680	
<b>Khulna Area Total</b>				<b>2209</b>	<b>1238</b>	<b>18575636</b>	
100	Summit Barisal 110 MW	IPP	7*17.076	110	32	137280	Low demand
101	Barisal GT: Unit-1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	27	374500	
103	Bhola CCGP 194MW	PDB	2*63+1*68	194	185	4294966	FGMO
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	72	552494	
<b>Barisal Area Total</b>				<b>462</b>	<b>316</b>	<b>5329240</b>	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	522000	Gas shortage
106	Baghabari Peaking 50MW	PDB	6*8.9	52	0	0	Reserve
107	Bera Peaking	PDB	9*8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7*7.79	50	50	169070	
109	Katakhali (Northern)	QRPP	6*8.9	50	0	0	Reserve
110	Katakhali Peaking	PDB	6*8.7	50	0	0	Reserve
111	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
112	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	164	3926736	FGMO
113	Sirajgonj Unit-3 225MW	NWPGCL	1*141	141	0	0	Gas shortage
	Sirajgonj Unit-4 414 MW(Gas	SNWPGCL	1*282	282	0	0	Gas shortage
114	Santahar Peaking	PDB	6*8.7	50	15	33005	
115	Bogra (GBB)	RPP	6*4	22	22	308160	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	5	82368	Engine problem
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	121122	
118	Rajlanka 52 MW	IPP	6*8.92	52	34	166560	Low demand
119	Chapainawabganj-100 MW	PDB	12*8.924	104	43	147908	Low demand
<b>Rajshahi Area Total</b>				<b>1546</b>	<b>344</b>	<b>5476929</b>	
120	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling
	Barapukuria Unit-2	PDB	1*125	85			