

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	725000	#1 Under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	213	6601800	On test
	Ghorasal GT: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	240	5603290	Gas shortage
3	Ghorasal 78MW (MAX)	IPB	2*40	78	35	106624	Gas shortage
4	Ghorasal (Regent)	IPB	3*43.35	108	0	0	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	359	7967750	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	305	6991000	Frequency control
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	330	8523625	Frequency control
10	Meghnaghat (IEL)	QRPP	12*9	100	0	0	Reserve
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	0	32280	Reserve
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	0	28515	Reserve
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	0	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	132804	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	150	1000000	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	0	Reserve
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	120	3215000	Gas shortage
21	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	0	17568	Reserve
23	Katpotti 51 MW	IPP	7*7.9	51	12	40848	Low demand
24	Banco Energy 54MW	IPP	3*18	54	54	196560	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	0	0	Reserve
26	Northern 55 MW	IPP	3*19.3	55	0	686669	Reserve
27	Southern 55MW	IPP	3*19.3	55	0	0	Reserve
28	Bosila 108MW	IPP	12*8.75+1*3.5	108	31	60480	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*8.67+4*8.73	80	50	140180	Engine problem
30	Summit Masana	SIPP, REB	4*8.73	33	33	744867	
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	792500	
32	Gazipur (RPCL)	IPP	6*8.9	52	42	500124	Engine problem
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	0	479333	Reserve
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	0	434880	Reserve
Dhaka area Total				5798	2064	46021697	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	150	3500000	
	Chittagong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	26	399780	
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	138375	
41	Patenga 50MW	IPP	8*6.98	50	50	692160	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	70	1292100	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	320259	Gas shortage
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	32	788160	Low demand
47	Hathazari peaking	PDB	1*18.9	98	0	76136	Reserve
48	Dohazari Peaking	PDB	6*17	102	34	71913	Low demand
49	Juidah (Acorn)	QRPP	8*13.45	100	0	261840	Reserve
	Juidah 100 MW Unit-3	IPP	0	100	75	1266240	Engine problem
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	22	476976	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	42	941760	
51	Chattogram ECPV 108 MW	IPP	16*7	108	0	324480	Reserve
Chattogram area Total				1681	501	10550179	
52	Ashuganj ST: Unit- 3	APSCl	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCl	1*150	129	80	2216480	Gas shortage
	Ashuganj ST: Unit- 5	APSCl	1*150	134	80	2183924	Gas shortage
53	Ashuganj CAPP 225 MW	APSCl	1*142+1*75	221	0	0	Under maint.
54	Ashuganj CAPP(North)	APSCl	1*360	360	160	4906900	ST under maint.
55	Ashuganj CAPP(South)	APSCl	1*360	360	294	6736500	FGMO
56	Ashuganj Engines TSK	APSCl	14*3.968	45	33	816624	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	57	1245120	
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	217454	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	42	311806	Engine problem
	Midland 150MW	IPP	23*7.015	150	0	23418	Ashuganj Bus red hot.
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	1233329	
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	0	Reserve
63	Chandpur CAPP	PDB	1*106+1*57	163	100	2319490	
	Chandpur Desh 200MW	IPP	0	200	52	285600	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	19	434556	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	218160	
**	Tripura	Imported power	0	160	114	2102400	
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	25	394400	Engine problem
67	Lakdhanvi 52 MW	IPP	6*8.92	52	0	0	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	22	490110	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1187	26256271	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	211	4038400	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	524916	
72	Jamalpur 95MW	IPP	12*8.924	95	87	1485120	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	12200	
74	United Mymensingh PPL	IPP	200	200	200	1207200	
Mymensingh Area Total				522	520	7267836	
75	Fenchugonj CAPP-1	PDB	2*32+1*33	70	30	624000	GT-1 under maint.
76	Fenchugonj CAPP-2	PDB	2*35+1*35	90	61	1341200	
77	Kushara 163 MW CAPP GT	IPP	1*109+1*54	163	130	3027469	Frequency control
78	Shajbazar 330 MW	PDB	3*110	330	100	1549000	GT-2 under maint.
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	511200	
80	Fenchugonj (EPL) 44MW	RPP	12*3.5+5*2	44	50	487000	
81	Hobiganj 110MW	SIPP, REB	4*2.90	11	11	251616	
82	Shajbazar GT: Unit- 8, 9	PDB	0	2*35	0	0	Under maint.
83	Shajbazar 86MW	RPP	32*2.90	86	89	1136880	
84	Shajbazar (EPL) 50MW	RPP	27*2.0	50	49	882360	
85	Sylhet GT 150 MW	PDB	1*142	142	80	2092830	Frequency control
86	Sylhet GT 20 MW	PDB	1*20	20	20	97000	
87	Sylhet (EPL) 50MW	RPP	27*2	50	23	384400	Engine problem
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	25	74976	Engine problem
89	Summit Bibiana- 2	IPP	1*222+1*119	341	300	7138750	FGMO
	Bibiana-3 285MW	PDB	285 MW	0	110	486000	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	52380	
Sylhet Area Total				1549	1141	20135861	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	696	10388363	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khulna (KPCL-2)	QRPP	7*17	115	49	612480	Low demand
94	Faridpur Peaking	PDB	8*6.89	54	44	171840	
95	Khulna CAPP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*6.98	109	51	282880	Low demand
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	330	7092864	Low demand
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	733875	
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	26880	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	105	1679520	Engine problem
Khulna Area Total				2209	1315	20988702	
100	Summit Barisal 110 MW	IPP	7*17.076	110	32	155424	Low demand
101	Barisal GT: Unit-1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	16	298974	Engine problem
103	Bhola CAPP 194MW	PDB	2*63+1*68	194	92	1726645	FGMO & GT-1 under maint.
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	95	1722985	Engine problem
Barisal Area Total				462	235	3904928	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	292923	
107	Bera Peaking	PDB	9*8.29	71	35	134997	
108	Amnura 50MW	QRPP	7*7.9	50	40	322930	Engine problem
109	Katakhal (Northern)	QRPP	6*8.9	50	50	168435	
110	Katakhal Peaking	PDB	6*8.7	50	0	0	Reserve
111	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
112	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	159	2854591	Gas shortage
113	Sirajgonj Unit-3 225MW	NWPGCL	1*141	141	164	4036736	FGMO
	Sirajgonj Unit-4. 414 MW (Gas)	SNWPGCL	1*282	282	0	0	Gas shortage
114	Santahar Peaking	PDB	6*8.7	50	35	585855	
115	Bogra (GBB)	RPP	6*4	22	22	510960	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	15	343692	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	184888	
118	Rajlanka 52 MW	IPP	6*8.92	52	51	568320	Engine problem
119	Chapainawabganj-100 MW	PDB	12*8.924	104	102	568716	
	Paramount Baghabari	IPP	200 MW	0	0	83636	