

Date : 28-Jan-19		Page -2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	716000	#1 Under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	137	3560900	On test
	Ghorasal GT: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal ST: Unit-7	PDB	1*243+1*1122	365	300	6946109	
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal (Regent)	IPP	3*4.35	108	0	0	Gas shortage
5	Haripur GT: Unit-1, 2	SB, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	360	8582870	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	320	7063000	Frequency control
9	Meghnaghal CCPP 450MW	IPP	2*150+1*150	450	370	8343125	Frequency control
10	Meghnaghal (IEL)	QRPP	12*8.9	100	0	16320	Reserve
11	Meghnaghal CCPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	14	28680	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	834045	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	0	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	0	285228	Engine problem
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	124	2594000	FGMO
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	14400	Reserve
20	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	150	3430765	Frequency control
21	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	24	808560	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	40	314640	
24	Banco Energy 54MW	IPP	3*18	54	54	637920	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	0	28320	Reserve
26	Northern 55 MW	IPP	3*19.3	55	55	330631	
27	Southern 55MW	IPP	3*19.3	55	17	187490	Low demand
28	Bosila 108MW	IPP	12*8.775+1*3.5	108	31	271680	Engine problem
29	Summit Power/(Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	60	51	1139280	Engine problem
30	Summit Misona	SIPP, REB	4*8.73	33	33	671900	
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	822000	
32	Gazipur (RPCL)	IPP	8*8.9	52	42	677880	Engine problem
33	Tongi GT	PDB	1*105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	12	868000	Low demand
35	APR Energy, Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	77	370080	Low demand
Dhaka area Total				5798	2324	49543823	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	0	200000	Gas shortage
	Chittong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	441720	
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	128385	
41	Patenga 50MW	IPP	8*6.98	50	50	581280	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	80	1796585	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*1175	225	151	2116291	Gas shortage
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*13+1*11.5	51	40	778080	Engine problem
47	Hathazari peaking	PDB	11*8.9	98	0	77156	Reserve
48	Dohazari Peaking	PDB	6*17	102	58	130437	Low demand
49	Juidah (Acorn)	QRPP	8*13.45	100	60	768600	Low demand
	Juidah 100 MW Unit-3	IPP	0	100	84	1599360	Engine problem
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	22	529440	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	25	542400	
51	Chattogram ECPV 108 MW	IPP	16*7	108	59	434880	Low demand
Chattogram area Total				1681	654	10124514	
52	Ashuganj ST: Unit- 3	AFSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	AFSCL	1*150	129	100	2374800	Gas shortage
	Ashuganj ST: Unit- 5	AFSCL	1*150	134	0	0	Under maint.
53	Ashuganj CCPP 225 MW	AFSCL	1*142+1*175	221	21	4663000	
54	Ashuganj CCPP(North)	AFSCL	1*360	360	260	5336200	ST under maint.
55	Ashuganj CCPP(South)	AFSCL	1*360	360	305	7360500	FGMO
56	Ashuganj Engines TSK	AFSCL	14*3.968	45	36	820008	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	30	555840	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*116	195	109	1237818	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	45	774710	Engine problem
	Midland 150MW	IPP	23*7.015	150	71	270980	Low demand
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	50	626590	Line Over Load
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	8	6136	Low demand
63	Chandpur CCPP	PDB	1*106+1*57	163	100	2337120	
	Chandpur Desh 200MW	IPP	0	200	70	1062720	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	19	457884	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	259200	
**	Tripura	Imported power	0	160	126	2295360	
66	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	25	466800	Engine problem
67	Lakdhanvi 52 MW	IPP	6*8.92	52	17	34872	Low demand
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	0	523550	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1618	31584088	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	176	4378080	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	526320	
72	Jamalpur 95MW	IPP	12*8.924	95	87	1399680	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	11150	
74	United Mymensingh PPL	IPP	200	200	60	1461600	High Voltage
	United Jamalpur PPL	IPP	115 MW	0	50	504000	
Mymensingh Area Total				522	395	8280830	
75	Fenchugonj CCPP-1	PDB	2*32+1*33	70	30	887000	GT-1 under maint.
76	Fenchugonj CCPP-2	PDB	2*35+1*35	90	60	1441848	
77	Kushiera 163 MW CCPP GT	IPP	1*109+1*54	163	130	3250088	Frequency control
78	Shajibazar 330 MW	PDB	3*110	330	94	1939080	GT-2 under maint.
79	Fenchugonj (Barakattullah) 51MW	RPP	19*2.90	51	53	666000	
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	50	594000	
81	Hobiganj 11MW	SIPP, REB	4*2.90	11	0	176208	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	71	660000	
83	Shajibazar 86MW	RPP	32*2.90	86	50	747840	Line Over Load
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	49	716040	
85	Syhet GT 150 MW	PDB	1*142	142	77	1952880	Frequency control
86	Syhet GT 20 MW	PDB	1*20	20	0	42000	Engine problem
87	Syhet (EPL) 50MW	RPP	27*2	50	23	555320	Engine problem
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	25	568632	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	260	7053500	FGMO
	Bibiyana-3 285MW	PDB	285 MW	0	299	6811600	On test
90	Syhet (Desh) 10MW	RPP	6*1.95	10	10	248580	
Syhet Area Total				1549	1281	28110534	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	686	12941818	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khulna (KPCL-2)	QRPP	7*17	115	115	807360	
94	Faridpur Peaking	PDB	8*6.89	54	44	143520	
95	Khulna CCPP 225MW	NWPGCL	1*150+1*175	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*6.98	109	98	424704	
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	380	8102880	Frequency control
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	829125	
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	20	24000	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	105	1747680	
Khulna Area Total				2209	1488	25021087	
100	Summit Barisal 110 MW	IPP	7*17.076	110	111	784320	
101	Barisal GT: Unit- 1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	15	295922	Engine problem
103	Bhola CCPP 194MW	PDB	2*63+1*68	194	30	721000	Under maint.
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	81	2048724	Engine problem
Barisal Area Total				462	237	3849966	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	107632	
107	Bera Peaking	PDB	9*8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7*7.9	50	40	516030	Engine problem
109	Katakhal (Northern)	QRPP	6*8.9	50	50	289630	
110	Katakhal Peaking	PDB	6*8.7	50	0	6047	Under maint.
111	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*175	210	0	0	Gas shortage
112	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*175	220	179	4488600	FGMO
113	Sirajgonj Unit-3 225MW	NWPGCL	1*141	141	179	4456118	FGMO
	Sirajgonj Unit-4 414 MW (Gas)	SNWPGCL	1*282	282	0	0	Gas shortage
114	Santahar Peaking	PDB	6*8.7	50	29	191670	
115	Bogra (GBB)	RPP	6*4	22	22	498240	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	15	351612	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	208098	
118	Rajlanka 52 MW	IPP	6*8.92	52	52	545280	
119	Chapainawabganj-100 MW	PDB	12*8.924	104	102	979204	
	Paramount Baghabari	IPP	200 MW	0	0	41818	
	Confidence CPBL-2	IPP	113 MW	0	0	26880	
Rajshahi Area Total				1546	729	12706859	
120	Barapukuria Unit-1	PDB	1*125	85	0	0	Under overhauling
	Barapukuria Unit-2	PDB	1*125	85	0	0	Coal shortage
121	Barapukuria Unit-3	PDB	1*275	274	149	3652200	
122	Rangpur GT	PDB	1*20	20	0	0	Reserve
123	Saidpur GT	PDB	1*20	20	16	255000	
Rangpur Area Total				484	165	3907200	
Total				17142	8891	173129001	
Eastern Grid Total				12441	6272	127643889	
Western Grid Total				4701	2619	45485112	
National Grid Total				17142	8891	173129001	