

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	74	1725000	
	Ghorasal GT: Unit-3	PDB	1*210	170	94	4864300	On test
	Ghorasal GT: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	265	6039809	
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	70	1480192	
4	Ghorasal (Regent)	IPP	3*43.35	108	0	7318	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	350	8427520	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	355	7163000	
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	360	8521000	Frequency control
10	Meghnaghat (IEL)	QRPP	12*9	100	0	6720	Reserve
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	150	4146356	GT-2 Under maint.
12	Madanganj 102MW	QRPP	6*17	100	0	0	Reserve
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	0	33684	Reserve
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	0	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	412704	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	0	0	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	7	6720	Low demand
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	0	0	Machine problem
21	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	30	101376	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	35	768816	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	312840	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	16	78240	Low demand
26	Northern 55 MW	IPP	3*19.3	55	55	179605	
27	Southern 55MW	IPP	3*19.3	55	55	268000	
28	Bosila 108MW	IPP	12*8.75+1*13.5	108	53	735360	
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*9.73	80	47	1159080	Engine problem
30	Summit Maona	SIPP, REB	4*8.73	33	33	746600	
31	Summit Rugganj	SIPP, REB	4*8.73	33	31	693100	
32	Gazipur (RPCL)	IPP	6*8.9	52	50	676320	
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	0	17560	Reserve
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	67	175680	Low demand
Dhaka area Total				5798	2270	48746900	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	120	2800000	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	120	2800000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	13	90720	Machine problem
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	117720	
41	Patenga 50MW	IPP	8*6.98	50	25	479520	Engine problem
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	71	1707127	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	201	4839518	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	149	2864360	
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	50	1126440	
47	Hathazari peaking	PDB	1*8.9	98	85	143468	
48	Dohazari Peaking	PDB	6*17	102	85	407355	
49	Juidah (Acorn)	QRPP	8*13.45	100	60	350760	Engine problem
	Juidah 100 MW Unit-3	IPP	0	100	100	1872960	
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	22	497376	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	26	742080	
51	Chattogram ECPV 108 MW	IPP	16*7	108	106	916800	
Chattogram area Total				1681	1233	21742404	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	80	2056288	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	80	1998790	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	0	0	Under maint.
53	Ashuganj CAPP 225 MW	APSCL	1*142+1*75	221	186	4459000	FGMO
54	Ashuganj CAPP(North)	APSCL	1*360	360	320	7279000	
55	Ashuganj CAPP(South)	APSCL	1*360	360	300	6416000	Gas shortage
56	Ashuganj Engines TSK	APSCL	14*3.968	45	33	639432	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	6	266880	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	264000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	267636	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	35	579594	Engine problem
	Midland 150MW	IPP	23*7.015	150	50	163920	Low demand
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	0	Reserve
63	Chandpur CAPP	PDB	1*106+1*57	163	50	1413040	ST Under maint
	Chandpur Desh 200MW	IPP	0	200	200	971520	
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	19	410904	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	208800	
**	Tripura	Imported power	0	160	152	2977920	
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	25	490900	Engine problem
67	Lakshani 52 MW	IPP	6*8.92	52	34	55204	Low demand
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	21	478820	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1615	31397648	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	156	2738160	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	0	0	gas pipe maint.
72	Jamalpur 95MW	IPP	12*8.924	95	85	702720	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	13450	
74	United Mymensingh PPL	IPP	200	200	70	228000	Low demand
	United Jamalpur PPL	IPP	115 MW	115	110	2223600	
Mymensingh Area Total				637	421	5905930	
75	Fenchugonj CAPP-1	PDB	2*32+1*33	70	60	1403000	
76	Fenchugonj CAPP-2	PDB	2*35+1*35	90	62	1292700	
77	Kushara 163 MW CAPP GT	IPP	1*109+1*54	163	130	3165218	Frequency control
78	Shajibazar 330 MW	PDB	3*110	330	331	7472000	FGMO
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	824400	
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	50	759000	
81	Hobiganj 14 MW	SIPP, REB	4*2.90	11	8	96048	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	62	1365120	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	88	1406440	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	45	830520	
85	Sylhet GT 150 MW	PDB	1*142	142	108	2485680	FGMO
86	Sylhet GT 20 MW	PDB	1*20	20	19	471000	
87	Sylhet (EPL) 50MW	RPP	27*2	50	49	741200	
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	16	306216	Machine problem
89	Summit Bibiana- 2	IPP	1*222+1*119	341	290	6592800	FGMO
	Bibiyana-3 285MW	PDB	285 MW	0	0	0	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	143100	
Sylhet Area Total				1549	1381	29353322	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	857	17126545	
92	Khuina (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khuina (KPCL-2)	QRPP	7*17	115	16	473280	Low demand
94	Faridpur Peaking	PDB	8*6.89	54	36	500640	
95	Khuina CAPP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*9.88	109	20	93568	Low demand
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	200	5854464	Gas shortage
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	8	449625	Low demand
	Khuina (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	204480	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	17	1591680	Low demand
	Madhumati Power Plant	IPP	100 MW	0	108	1367693	On test
Khuina Area Total				2209	1262	27661975	
100	Summit Barisal 110 MW	IPP	7*17.076	110	16	842496	Low demand
101	Barisal GT: Unit- 1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	28	373100	Engine problem
103	Bhola CAPP 194MW	PDB	2*63+1*68	194	125	2992000	Gas shortage
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	70	2075663	Low demand
Barisal Area Total				462	239	6283259	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	269254	
107	Bera Peaking	PDB	9*8.29	71	54	186158	
108	Amnura 50MW	QRPP	7*7.9	50	40	697160	
109	Katakhal (Northern)	QRPP	6*8.9	50	50	357271	
110	Katakhal Peaking	PDB	6*8.7	50	40	142317	
111	Sraigonj Unit-1 225MW	NWPGCL	1*150+1*75	210	181	4540009	FGMO
112	Sraigonj Unit-2 225MW	NWPGCL	1*150+1*75	220	0	0	Gas shortage
113	Sraigonj Unit-3 225MW	NWPGCL	1*141	220	177	4567445	FGMO
	Sraigonj Unit-4. 414 MW(Gas)	SNWPGCL	1*282	282	0	3738545	On test
114	Santahar Peaking	PDB	6*8.7	50	21	78988	
115	Bogra (GBB)	RPP	6*4	22	22	500160	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	17	389664	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	243162	
118	Rajlanka 52 MW	IPP	6*8.92	52	52	893760	