

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	74	1721000	
	Ghorasal GT: Unit-3	PDB	1*210	170	134	3397100	On test
	Ghorasal GT: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	90	585900	synchronized at 17:03.
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	330	7832872	Frequency control
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	74	1649536	Gas shortage
4	Ghorasal (Regent)	IPP	3*43.35	108	106	2531045	
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	310	8355260	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	41100	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	358	7945000	
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	405	8710625	Machine problem
10	Meghnaghat (IEL)	QRPP	12*9	100	50	90240	Low demand
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	150	3982429	Machine problem
12	Madanganj 102MW	QRPP	6*17	100	0	58608	Reserve
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	113988	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	15	39403	Low demand
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	417744	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	130	2814000	Frequency control
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	15	19200	Low demand
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	0	0	Machine problem
21	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	102	506736	
23	Katpotti 51 MW	IPP	7*7.9	51	48	834576	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	565660	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	117	827520	
26	Northern 55 MW	IPP	3*19.3	55	55	871967	
27	Southern 55MW	IPP	3*19.3	55	55	320000	
28	Bosila 108MW	IPP	12*8.75+1*3.5	108	35	406080	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*9.73	80	57	1333140	Engine problem
30	Summit Masora	SIPP, REB	4*8.73	33	25	606900	Engine problem
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	798600	
32	Gazipur (RPCL)	IPP	6*8.9	52	51	759660	
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	106	303600	Low demand
35	APR Energy , Keraniganj	IPP	256*1.4	300	52	84370	Low demand
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	125	973440	Low demand
Dhaka area Total				5798	3230	59488199	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	125	3000000	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	16	208483	Engine problem
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	114210	
41	Patenga 50MW	IPP	8*6.98	50	0	0	33 kV feeder fault
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	83	1889127	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	189	4866276	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	0	2100900	tripped at 15:20
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	41	899040	Engine problem
47	Hathazari peaking	PDB	1*8.9	98	79	319688	
48	Dohazari Peaking	PDB	6*17	102	65	331807	
49	Juidah (Acorn)	QRPP	8*13.45	100	78	594120	Engine problem
	Juidah 100 MW Unit-3	IPP	0	100	100	1736640	
50	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	17	636000	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	7	401760	
51	Chattogram ECPV 108 MW	IPP	16*7	108	104	1407360	
Chattogram area Total				1681	904	18505411	
52	Ashuganj ST: Unit- 3	APSCl	1*150	135	120	2273780	Gas shortage
	Ashuganj ST: Unit- 4	APSCl	1*150	129	80	2008685	Gas shortage
	Ashuganj ST: Unit- 5	APSCl	1*150	134	0	0	Under maint.
53	Ashuganj CAPP 225 MW	APSCl	1*142+1*75	221	194	4590000	FGMO
54	Ashuganj CAPP(North)	APSCl	1*360	360	360	8215000	
55	Ashuganj CAPP(South)	APSCl	1*360	360	360	7943500	
56	Ashuganj Engines TSK	APSCl	14*3.968	45	40	890568	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	127880	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	200727	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	35	557178	Engine problem
	Midland 150MW	IPP	23*7.015	150	80	1027054	Low demand
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	6776	Reserve
63	Chandpur CAPP	PDB	1*106+1*57	163	100	1500447	
	Chandpur Desh 200MW	IPP	0	200	160	2368320	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	21	501876	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	240480	
**	Tripura	Imported power	0	160	164	3060480	
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	25	406900	Engine problem
67	Lakhdhavi 52 MW	IPP	6*8.92	52	52	727037	
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	18	480760	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1838	37247248	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	74	4148200	tripped at 18:19
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	0	0	Gas pipe maint.
72	Jamalpur 95MW	IPP	12*8.924	95	79	1205760	
73	Sarishabari (Solar)	IPP	1*3	3	0	14350	
74	United Mymensingh PPL	IPP	200	200	200	1178400	
	United Jamalpur PPL	IPP	115 MW	115	111	2176800	
Mymensingh Area Total				637	464	8723510	
75	Fenchugonj CAPP-1	PDB	2*32+1*33	70	58	1407000	
76	Fenchugonj CAPP-2	PDB	2*35+1*35	90	60	1437960	ST Under maint
77	Kushara 163 MW CAPP GT	IPP	1*109+1*54	163	100	3146400	Frequency control
78	Shajibazar 330 MW	PDB	3*110	330	169	6505000	FGMO
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	937200	
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	40	860000	
81	Hobiganj 110 MW	SIPP, REB	4*2.90	11	11	182784	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	67	1451232	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	85	1215360	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	47	1079280	
85	Sylhet GT 150 MW	PDB	1*142	142	90	1760000	FGMO
86	Sylhet GT 20 MW	PDB	1*20	20	0	25000	Reserve
87	Sylhet (EPL) 50MW	RPP	27*2	50	48	1049360	
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	16	376080	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	295	7155000	FGMO
	Bibiyana-3 285MW	PDB	285 MW	0	0	0	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	182520	
Sylhet Area Total				1549	1149	28770176	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	955	20176727	
92	Khuina (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khuina (KPCL-2)	QRPP	7*17	115	115	746880	
94	Faridpur Peaking	PDB	8*6.89	54	39	235200	
95	Khuina CAPP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*6.98	109	71	903808	Low demand
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	210	5824224	Line O/L
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	272250	
	Khuina (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	50	117120	Low demand
	Labon Chora 105 MW	IPP	6*18.445	105	105	1680000	
	Madhumati Power Plant	IPP	100 MW	0	0	0	On test
Khuina Area Total				2209	1585	29956209	
100	Summit Barisal 110 MW	IPP	7*17.076	110	110	1167360	
101	Barisal GT: Unit-1, 2	PDB	2*20	30	24	79623	
102	Bhola (Venture) 33MW	RPP	1*34.50	33	30	505902	Machine problem
103	Bhola CAPP 194MW	PDB	2*63+1*68	194	82	4137056	Under ST syn. Process.
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	97	2238545	
Barisal Area Total				462	343	8128486	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	287568	
107	Bera Peaking	PDB	9*8.29	71	54	204138	
108	Amnura 50MW	QRPP	7*7.9	50	40	501070	Engine problem
109	Katakhal (Northern)	QRPP	6*8.9	50	50	523934	
110	Katakhal Peaking	PDB	6*8.7	50	45	152928	
111	Sraigonj Unit-1 225MW	NWPGCL	1*150+1*75	210	180	4649282	FGMO
112	Sraigonj Unit-2 225MW	NWPGCL	1*150+1*75	220	4	365055	Gas shortage
113	Sraigonj Unit-3 225MW	NWPGCL	1*141	220	185	365055	FGMO
	Sraigonj Unit-4. 414 MW(Gas)	SNWPGCL	1*282	282	0	225818	On test
114	Santahar Peaking	PDB	6*8.7	50	30	171243	
115	Bogra (GBB)	RPP	6*4	22	22	513840	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	17	372096	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	217512	