

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	74	1737000	
	Ghorasal GT: Unit-3	PDB	1*210	170	134	3380800	On test
	Ghorasal GT: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	120	2740500	Gas shortage
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	300	6913073	Frequency control
3	Ghorasal 78MW (MAX)	IPPP	2*40	78	40	1438208	
4	Ghorasal (Regent)	IPPP	3*43.35	108	110	1496045	
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	372	8536784	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	355	7303000	
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	400	8380875	Machine problem
10	Meghnaghat (IEL)	QRPP	12*9	100	0	0	Reserve
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	335	5255040	
12	Madanganj 102MW	QRPP	6*17	100	0	25776	Reserve
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	15	44025	Low demand
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	0	Reserve
15	Narsingdi (Doreen)	SIPP, REB	8*2.90	22	19	418464	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	150	3508000	Frequency control
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	0	Reserve
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	0	0	Machine problem
21	Pagla (DPA )	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	7	31392	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	46	732288	
24	Banco Energy 54MW	IPP	3*18	54	35	335162	Low demand
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	48	232800	Low demand
26	Northern 55 MW	IPP	3*19.3	55	55	615259	
27	Southern 55MW	IPP	3*19.3	55	17	447000	Low demand
28	Bosila 108MW	IPP	12*9.75+1*3.5	108	49	376320	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*9.73	80	57	1225380	Engine problem
30	Summit Masana	SIPP, REB	4*8.73	33	25	593400	Engine problem
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	816600	
32	Gazipur (RPCL)	IPP	6*8.9	52	51	558084	
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	42	160580	Low demand
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	15	70560	Low demand
<b>Dhaka area Total</b>				<b>5798</b>	<b>2904</b>	<b>57375415</b>	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	120	2900000	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	16	98984	Engine problem
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	133110	
41	Patenga 50MW	IPP	8*6.98	50	0	60960	33 kV feeder fault
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	83	1948156	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	204	4909604	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	under S/D
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	41	934080	Engine problem
47	Hathazari peaking	PDB	1*18.9	98	51	225556	Low demand
48	Dohazari Peaking	PDB	6*17	102	67	333684	
49	Juidah (Acorn)	QRPP	8*13.45	100	10	258120	Low demand
	Juidah 100 MW Unit-3	IPP	0	100	100	2231040	
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	17	392064	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	33	533280	
51	Chattogram ECPV 108 MW	IPP	16*7	108	105	861120	
<b>Chattogram area Total</b>				<b>1681</b>	<b>847</b>	<b>15819758</b>	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	100	2125490	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	80	1850365	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	0	0	Under maint.
53	Ashuganj CAPP 225 MW	APSCL	1*142+1*75	221	196	4679000	FGMO
54	Ashuganj CAPP(North)	APSCL	1*360	360	360	7823900	
55	Ashuganj CAPP(South)	APSCL	1*360	360	330	7368500	Frequency control
56	Ashuganj Engines TSK	APSCL	14*3.968	45	40	849528	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	127200	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	200727	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	17	414718	Engine problem
	Midland 150MW	IPP	23*7.015	150	70	461672	Low demand
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	0	Reserve
63	Chandpur CAPP	PDB	1*106+1*57	163	90	1702730	
	Chandpur Desh 200MW	IPP	0	200	140	2031840	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	506196	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	250560	
**	Tripura	Imported power	0	160	154	2968320	
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	25	300500	Engine problem
67	Lakdhanvi 52 MW	IPP	6*8.92	52	0	21230	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	21	524320	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1674</b>	<b>34126796</b>	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	156	3611000	Gas shortage
71	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	0	0	Gas pipe maint.
72	Jamalpur 95MW	IPP	12*8.924	95	78	1347840	Low voltage
73	Sarishabari (Solar)	IPP	1*3	3	0	12800	
74	United Mymensingh PPL	IPP	200	200	180	1351200	Low demand
	United Jamalpur PPL	IPP	115 MW	115	113	2472000	Line O/L
<b>Mymensingh Area Total</b>				<b>637</b>	<b>527</b>	<b>8794840</b>	
75	Fenchugonj CAPP-1	PDB	2*32+1*33	70	60	1412000	
76	Fenchugonj CAPP-2	PDB	2*35+1*35	90	59	1389720	ST Under maint
77	Kushiar 163 MW CAPP GT	IPP	1*109+1*54	163	100	2702855	Frequency control
78	Shajbazar 330 MW	PDB	3*110	330	264	6119000	FGMO
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	821400	
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	50	875000	
81	Hobiganj 110MW	SIPP, REB	4*2.90	11	8	189408	
82	Shajbazar GT: Unit- 8, 9	PDB	2*35	66	65	1363680	FGMO
83	Shajbazar 86MW	RPP	32*2.90	86	85	1748160	
84	Shajbazar (EPL) 50MW	RPP	27*2.0	50	47	1032120	
85	Sylhet GT 150 MW	PDB	1*142	142	111	2341480	FGMO
86	Sylhet GT 20 MW	PDB	1*20	20	0	0	Reserve
87	Sylhet (EPL) 50MW	RPP	27*2	50	46	947250	
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	24	129789	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	305	7191800	FGMO
	Bibiana-3 285MW	PDB	285 MW	0	0	1237500	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	84420	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>1287</b>	<b>29585582</b>	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC )	Imported power	2*500	1000	856	18154181	
92	Khuina (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khuina (KPCL-2)	QRPP	7*17	115	115	600000	
94	Faridpur Peaking	PDB	8*6.89	54	35	268800	
95	Khuina CAPP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*9.98	109	42	292224	Low demand
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	200	5434848	Line O/L
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	178875	
	Khuina (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	0	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	90	1069920	Low demand
	Madhumati Power Plant	IPP	100 MW	0	0	0	On test
<b>Khuina Area Total</b>				<b>2209</b>	<b>1378</b>	<b>25998848</b>	
100	Summit Barisal 110 MW	IPP	7*17.076	110	110	1349760	
101	Barisal GT: Unit-1, 2	PDB	2*20	30	0	6279	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	28	535500	
103	Bhola CAPP 194MW	PDB	2*63+1*68	194	180	3871150	
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	96	2282379	
<b>Barisal Area Total</b>				<b>462</b>	<b>414</b>	<b>8045068</b>	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	257788	
107	Bera Peaking	PDB	9*8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7*7.9	50	40	420180	Engine problem
109	Katakhal (Northern)	QRPP	6*8.9	50	0	34917	Reserve
110	Katakhal Peaking	PDB	6*8.7	50	0	34963	Reserve
111	Sraigonj Unit-1 225MW	NWPGCL	1*150+1*75	210	22	1555500	FGMO, GT-1 Syn. at 18:57
112	Sraigonj Unit-2 225MW	NWPGCL	1*150+1*75	220	204	4587173	Gas shortage
113	Sraigonj Unit-3 225MW	NWPGCL	1*141	220	204	4656255	FGMO
	Sraigonj Unit-4 414 MW(Gas)	SNWPGCL	1*282	282	0	0	On test
114	Santahar Peaking	PDB	6*8.7	50	0	89925	Reserve
115	Bogra (GBB)	RPP	6*4	22	22	471840	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	16	393804	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	264360	
118	Rajlanka 52 MW	IPP	6*8.92				