

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	36	700000	#1 Under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	0	0	Gas shortage
	Ghorasal GT: Unit-4	PDB	1*210	180	243	5278000	
	Ghorasal GT: Unit-5	PDB	1*210	190	0	0	Gas line maint.
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	300	8076718	
3	Ghorasal 75MW (MAX)	QRPP	2*40	78	72	1363184	
4	Ghorasal (Regen)	IPP	34*3.35	108	98	2183954	
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	326	8275944	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	110	603800	
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	290	7797000	Gas shortage
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	400	9428875	Gas shortage
10	Meghnaghat (IEL)	QRPP	12*8.9	100	100	1210560	
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	260	6598575	FGMO
12	Madanganj 102MW	QRPP	6*17	100	80	584664	Engine problem
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	468015	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	78	485265	Engine problem
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	411516	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	60	2320000	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Contract Expired
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	98	466560	
20	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	150	4387565	Gas shortage
21	Paglia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	101	927072	
23	Kalpottli 51 MW	IPP	7*7.9	51	30	299328	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	1260360	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	149	2938560	
26	Northern 55 MW	IPP	3*19.3	55	55	1339390	
27	Southern 55MW	IPP	3*19.3	55	55	1108000	
28	Bosila 105MW	IPP	12*8.775+1*3.5	108	32	948480	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	90	47	1150620	Engine problem
30	Summit Maona	SIPP, REB	4*8.73	33	25	585900	Engine problem
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	809100	
32	Gazipur (RPCL)	IPP	6*8.9	52	50	1111596	
33	Tongi GT	PDB	1* 105	105	40	547454	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	250	2019820	Low demand
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	52208	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	124157	Reserve
38	Summit Gazipur-1 150MW	IPP	149	149	149	2977920	
	Gazipur 100 MW	RPCL	100 MW	0	0	0	on test
Dhaka area Total				5798	3846	78842160	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	100	2400000	Gas shortage
	Chittgong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	26	576711	
	Teknaf Solartech 20MW	Teknaf Solartech Energ	20	20	0	133920	
41	Patenga 50MW	IPP	8*6.98	50	43	1105920	Engine problem
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	70	977300	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	230	5431826	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	130	3223262	FGMO
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	16	297600	Engine problem
47	Hathazari peaking	PDB	11*8.9	98	66	879788	
48	Dohazari Peaking	PDB	6*17	102	85	1182044	
49	Juidah (Acom)	QRPP	8*13.45	100	86	1418280	Engine problem
	Juidah 100 MW Unit-3	IPP	0	100	100	2825560	
50	Barabkunda (Regeni)	SIPP, PDB	8*2.90	22	16	365905	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	24	410880	
51	Chattogram ECPV 108 MW	IPP	16*7	108	45	826580	Engine problem
Chattogram area Total				1681	1037	21592556	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	120	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	0	0	Gas shortage
53	Ashuganj CCPP 225 MW	APSCL	1*142+1*75	221	221	4900000	
54	Ashuganj CCPP(North)	APSCL	1*360	360	0	3531000	Engine problem
55	Ashuganj CCPP(South)	APSCL	1*360	360	356	7752500	
56	Ashuganj Engines TSK	APSCL	14*3.968	45	30	593784	Gas shortage
57	Ashuganj (Precision) 55MW	RPP	15*4	55	52	1194720	
58	Ashuganj (United) 53MW	QRPP	14*4	53	53	792000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	188	3596363	
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	45	961884	Engine problem
	Midland 150MW	IPP	23*7.015	150	150	3320363	
61	B.Barla (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	50	84200	
63	Chandpur CCPP	PDB	1*106+1*57	163	100	2328610	
	Chandpur Desh 200MW	IPP	0	200	180	1668000	Engine problem
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	484128	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	194040	
**	Tripura	Imported power	0	160	184	3783360	
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	25	603400	Engine problem
67	Lakdhanvi 52 MW	IPP	6*8.92	52	52	756686	
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	21	344230	Engine problem
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1740	36889268	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	153	3550880	Gas shortage
71	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	408996	
72	Jamalpur 95MW	IPP	12*8.924	95	78	1696320	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	9450	
74	United Mymensingh PPL	IPP	200	200	170	1468800	Engine problem
	United Jamalpur PPL	IPP	115 MW	115	110	2580000	
Mymensingh Area Total				637	531	9714446	
75	Fenchuganj CCPP-1	PDB	2*32+1*33	70	60	1169000	
76	Fenchuganj CCPP-2	PDB	2*35+1*35	90	32	3774400	
77	Kushinara 163 MW CCPP GT	IPP	1*109+1*54	163	163	3625398	
78	Shajibazar 330 MW	PDB	3*110	330	290	5017000	FGMO
79	Fenchuganj (Barakatalah) 51MW	RPP	19*2.90	51	50	606600	
80	Fenchuganj (EPL) 44MW	RPP	12*3.3+5*2	44	50	624000	
81	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	237072	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	30	717792	FGMO & GT-8 Under maint.
83	Shajibazar 86MW	RPP	32*2.90	86	80	1874880	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	45	935280	
85	Sylhet GT 150 MW	PDB	1*142	142	74	1759190	
86	Sylhet GT 20 MW	PDB	1*20	20	19	233000	
87	Sylhet (EPL) 50MW	RPP	27*2	50	40	660180	Engine problem
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	25	491088	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	250	6738500	FGMO
	Bibiyana-3 285 MW	PDB	285 MW	0	0	0	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	126000	
Sylhet Area Total				1549	1229	25092380	
91	Bheramara GT-1,2,3	PDB	3*20	46	46	184500	
**	Bheramara (HVDC)	Imported power	2*500	1000	946	20318545	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khulna (KPCL-2)	QRPP	7*17	115	99	1943040	Engine problem
94	Faridpur Peaking	PDB	8*6.89	54	36	288960	
95	Khulna CCPP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*6.98	109	61	467968	
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	0	0	Under maint.
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	533625	
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	97	629760	
	Labon Chora 105 MW	IPP	6*18.445	105	105	2802560	
	Madhumati Power Plant	IPP	100 MW	0	90	2287296	Engine problem
Khulna Area Total				2209	1520	29256254	
100	Summit Barsal 110 MW	IPP	7*17.076	110	100	1400640	Engine problem
101	Barsal GT: Unit-1, 2	PDB	2*20	30	22	94512	
102	Bhola (Venture) 33MW	RPP	1*34.50	33	37	700840	
103	Bhola CCPP 194MW	PDB	2*63+1*68	194	177	4324440	
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	97	2242844	FGMO
Barsal Area Total				462	433	8763276	
105	Baghabari GT 71MW	PDB	1*71	71	60	1355000	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Gas shortage
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	594656	
107	Bera Peaking	PDB	9*8.29	71	39	349885	
108	Amnura 50MW	QRPP	7*7.79	50	40	252250	Engine problem
109	Katakhal (Northern)	QRPP	6*8.9	50	50	711082	
110	Katakhal Peaking	PDB	6*8.7	50	48	252396	
111	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	165	4640255	FGMO
112	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	152	4095827	FGMO
113	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	154	4577855	FGMO
	Sirajgonj Unit-4 414 MW (Gas)	SNWPGCL	1*282	282	330	8213091	Frequency control
114	Santahar Peaking	PDB	6*8.7	50	35	322468	
115	Bogra (GBB)	RPP	6*4	22	22	499440	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	14	317880	
117	Ullapara (Summit)	SIPP, REB	4*2.90				