

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	656000	#1 Under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	94	2187000	Gas shortage
	Ghorasal GT: Unit-4	PDB	1*210	180	100	2390000	Gas shortage
	Ghorasal ST: Unit-5	PDB	1*210	190	115	2803500	Gas shortage
2	Ghorasal 78MW (MAX)	PDB	1*243+1*122	365	300	6381754	Frequency control
3	Ghorasal (Regent)	ORPP	2*40	78	0	0	Gas shortage
4	Ghorasal (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	153250	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	328	8033504	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	26	136500	Low demand
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	324	7122000	Frequency control
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	360	8307625	Frequency control
10	Meghnaghat (IEL)	QRPP	12*8.9	100	7	48000	Low demand
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	285	6727709	FGMO
12	Madanganj 102MW	QRPP	6*17	100	15	79440	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	15	94724	Low demand
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	10	68786	Low demand
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	263304	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	0	364000	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
18	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	7	37440	Low demand
19	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	170	4362892	
0	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gagnagar (Orion)	IPP	12*8.924	102	24	395280	Low demand
21	Katpott 51 MW	IPP	7*7.9	51	49	1011264	
22	Banco Energy 54MW	IPP	3*18	54	35	693000	Engine problem
23	Kodda 149MW	BPDB-RPCL	9*17.06	149	149	943680	
24	Northern 55 MW	IPP	3*19.3	55	37	642936	Engine problem
25	Southern 55MW	IPP	3*19.3	55	55	764220	
26	Sosila 108MW	IPP	12*9.775+1*3.5	108	63	738240	Engine problem
27	Summit Power, (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	52	1198320	Engine problem
28	Summit Maona	SIPP, REB	4*8.73	33	33	688300	
29	Summit Rugganj	SIPP, REB	4*8.73	33	25	512400	Engine problem
30	Gazipur (RPCL)	IPP	6*8.9	52	49	630516	
31	Tongi GT	PDB	1*105	105	40	733442	Gas shortage
32	Summit Gazipur -2	IPP	18*17.076	300	130	657381	Low demand
33	APR Energy, Keraniganj	IPP	256*1.4	300	0	0	Reserve
34	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
35	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
36	Summit Gazipur-1 150MW	IPP	149	149	80	453600	Low demand
37	Gazipur 100 MW	RPCL	100 MW	0	90	1734408	on test
Dhaka area Total				5698	3124	62014415	
37	Chattogram ST-1 (Raozan)	PDB	1*210	180	100	2400000	
	Chittgong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
38	Raazan 25 MW (RPCL)	IPP	3*8.9	25	25	411370	
39	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	125685	
40	Patenga 50MW	IPP	8*6.98	50	46	1016640	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	34	794220	Low water level
42	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
43	Sikalbaha 225MW	PDB	1*150+1*175	225	205	5194400	FGMO
44	Sikalbaha Peaking GT	PDB	1*150	150	131	3049737	FGMO
45	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	24	448800	Engine problem
	Baraka Sikalbaha PL	IPP	105 MW	0	105	1354067	
46	Hathazari peaking	PDB	11*8.9	98	83	370712	
47	Dohazari Peaking	PDB	6*17	102	85	735767	
48	Juddah (Acom)	QRPP	8*13.45	100	40	561800	Low demand
49	Juddah 100 MW Unit-3	IPP	0	100	100	2116000	
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	19	362976	Engine problem
*	Malancha, Ctg, EPZ (United)		5*8.73+3*9.34	0	42	607680	
51	Chattogram ECPV 108 MW	IPP	16*7	108	90	1538880	Engine problem
	Kaptai Solar	PDB	7.4 MW	0	0	0	on test
	Anwara United	United Group	300 MW	0	140	3939000	on test
Chattogram area Total				1681	1269	25048614	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	80	1923456	Gas shortage
53	Ashuganj CCPP 225 MW	APSCL	1*142+1*75	221	196	4387000	Frequency control
54	Ashuganj CCPP(North)	APSCL	1*360	360	350	7391800	
55	Ashuganj CCPP(South)	APSCL	1*360	360	300	7054500	Frequency control
56	Ashuganj Engines TSK	APSCL	14*3.968	45	0	0	Gas Line maint.
57	Ashuganj (Precision) 55MW	RPP	15*4	55	56	1015680	
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	16	267636	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	25	497644	Engine problem
61	Midland 150MW	IPP	23*7.015	150	10	160581	Low demand
62	B.Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
63	Daudkandi Peaking 52MW	PDB	6*8.92	52	9	31767	Low demand
64	Chandpur CCPP	PDB	1*106+1*57	163	100	2489820	
65	Chandpur Desh 200MW	IPP	0	200	180	2162880	Low demand
66	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	434664	
67	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	202880	
**	Tripura	Imported power	0	160	182	3404160	
68	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	25	435400	Engine problem
69	Lakdhanvi 52 MW	IPP	6*8.92	52	25	283042	Low demand
70	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	20	414170	
71	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1612	32676880	
72	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	149	3080160	GT-1 Under maint
73	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	363276	
74	Jamalpur 95MW	IPP	12*8.924	95	94	1191360	
75	Sarishabari (Solar)	IPP	1*3	3	0	1800	
76	United Mymensingh PPL	IPP	200	200	100	746400	Low demand
77	United Jamalpur PPL	IPP	115 MW	115	95	1815600	Engine problem
Mymensingh Area Total				637	458	7198596	
78	Fenchugonj CCPP-1	PDB	2*32+1*33	70	58	1248000	
79	Fenchugonj CCPP-2	PDB	2*35+1*35	90	58	1256400	
80	Kushlira 163 MW CCPP GT	IPP	1*109+1*54	163	130	3020882	Frequency control
81	Shajibazar 330 MW	PDB	3*110	330	281	6308000	Machine problem
82	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	723600	
83	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	50	868536	
84	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	143136	
85	Shajibazar GT: Unit- 6, 9	PDB	2*35	66	63	1378176	FGMO
86	Shajibazar 86MW	RPP	32*2.90	86	79	1023360	
87	Shajibazar (EPL) 50MW	RPP	27*2.0	50	45	812880	
88	Sylhet GT 150 MW	PDB	1*142	142	111	2157230	Frequency control
89	Sylhet GT 20 MW	PDB	1*20	20	18	202000	
90	Sylhet (EPL) 50MW	RPP	27*2	50	46	844940	
91	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	24	280176	
92	Sumit Bibiana- 2	IPP	1*222+1*119	341	245	5988000	FGMO
	Bibiyana-3 285 MW	PDB	285 MW	0	230	5262000	On test
93	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	115920	
Sylhet Area Total				1549	1512	31631236	
94	Bheramara GT-1,2,3	PDB	3*20	46	32	180700	Low demand
**	Bheramara (HVDC)	Imported power	2*500	1000	931	22535272	
	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
95	Khulna (KPCL-2)	QRPP	7*17	115	115	1084800	
96	Faridpur Peaking	PDB	8*6.89	54	33	271680	
97	Khulna CCPP 225MW	NWPGCL	1*150+1*75	230	45	1207945	Low demand
98	Gopalganj Peaking	PDB	16*6.98	109	66	431232	
99	Bheramara 360 MW	NWPGCL	1*278+1*132	410	0	0	Under maint.
100	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	579375	
0	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
101	Bangla Trak Noapara	IPP	70*1.4	100	100	498240	
102	Labon Chora 105 MW	IPP	6*18.445	105	105	1581120	
103	Madhumati Power Plant	IPP	100 MW	105	108	1872864	
Khulna Area Total				2314	1575	30243228	
104	Summit Barisal 110 MW	IPP	7*17.076	110	110	1040448	
105	Barisal GT: Unit-1, 2	PDB	2*20	30	24	82505	Engine problem
106	Bhola (Venture) 33MW	RPP	1*34.50	33	38	706385	
107	Bhola CCPP 194MW	PDB	2*63+1*68	194	173	4217780	FGMO
108	Bhola Aggreko 95MW	QRPP	96*1.10	95	97	2168341	
Barisal Area Total				462	442	8215459	
109	Baghabari GT 71MW	PDB	1*71	71	60	1365000	
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
110	Baghabari Peaking 50MW	PDB	6*8.9	52	50	492784	
111	Bera Peaking	PDB	9*8.29	71	33	182756	
112	Amnura 50MW	QRPP	7*7.79	50	50	538680	
113	Katakhali (Northern)	QRPP	6*8.9	50	50	322312	
114	Katakhali Peaking	PDB	6*8.7	50	37	216371	
115	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	185	4457336	FGMO
116	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	182	4240482	FGMO
117	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	207	4598790	FGMO
118	Sirajgonj Unit-4 414 MW(Gas)	SNWPGCL	1*282+1*132	414	350		