

Sl. No.	Name of the Power Stations	Producer	Installed Capacity		Present Capacity	Peak Hour Generation	Energy Generated MW	Remarks
			Unit No. X Capacity	MW				
1	Ghorasal ST: Unit-1,2	PDB	2*55	85		35	1396000	Gas shortage
	Ghorasal GT: Unit-3	PDB	1*210	170		0	0	Under maint.
	Ghorasal ST: Unit-6	PDB	1*210	180		160	1495000	Gas shortage
	Ghorasal ST: Unit-5	PDB	1*210	190		110	2720000	Gas shortage
2	Ghorasal 78MW (MAX)	PDB	1*243+1*122	365		300	7418509	Gas shortage.
3	Ghorasal (Regent)	QRPP	2*40	78		72	1050560	
4	Harijpur GT: Unit-1, 2	IPP	3*43.35	108		108	1963360	
5	Harijpur GT: Unit-1, 2	SBU, PDB	2*32	40		20	500100	Gas shortage
6	Harijpur 412 MW CCPP	EGCB	1*273+1*139	412		372	8388610	FGMO
7	Harijpur NEPC 110MW	IPP	8*15	110		13	109600	Low demand
8	Harijpur Power CCPP 360MW	IPP	1*235+1*125	360		324	7433000	Frequency control
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450		225	5136500	GT-1 Under maint
10	Meghnaghat (IEL)	QRPP	12*8.9	100		16	59520	Low demand
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305		290	6626676	FGMO
12	Madanganj 102MW	QRPP	6*17	100		45	149304	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55		55	204470	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100		10	59898	Low demand
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22		22	490464	
16	Siddhirgonj ST 210MW	PDB	1*210	115		0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210		160	3592000	Frequency control
18	Siddhirgonj Desh	QRPP	96*1.2	0		0	0	Contract Expired
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100		15	48000	Low demand
20	Siddhirgonj CCPP-335 MW	EGCB	1*217	217		0	0	Reserve
	Pagla (DPA)	QRPP	100*0.5	0		0	0	Contract Expired
21	Gagnagar (Orion)	IPP	12*8.924	102		24	162432	Low demand
22	Katpott 51 MW	IPP	7*7.9	51		49	495408	
23	Banco Energy 54MW	IPP	3*18	54		35	543600	Engine problem
24	Kodda 149MW	BPDB-RPCL	9*17.06	149		98	481440	Low demand
25	Northern 55 MW	IPP	3*19.3	55		55	443647	
26	Southern 55MW	IPP	3*19.3	55		55	280920	
27	Bosila 108MW	IPP	12*8.775+1*13.5	108		63	767040	Engine problem
28	Summit Power, (Madhabdi+Ashula)	SIPP, REB	3*3.67+4*8.73	80		39	923480	Engine problem
29	Summit Maona	SIPP, REB	4*8.73	33		25	570800	Engine problem
30	Summit Rugganj	SIPP, REB	4*8.73	33		28	714900	Engine problem
31	Gazipur (RPCL)	IPP	6*8.9	52		48	445536	
32	Tongi GT	PDB	1*105	105		0	0	Gas shortage
33	Summit Gazipur -2	IPP	18*11.076	300		182	557017	Low demand
34	APR Energy, Keraniganj	IPP	256*1.4	300		0	0	Reserve
35	Bramhangoan 100 MW (Aggreko)	IPP	100	100		0	0	Reserve
36	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100		0	0	Reserve
37	Summit Gazipur-1 150MW	IPP	149	149		75	393120	Low demand
	Gazipur 100 MW	RPCL	100 MW	105		90	1425600	Engine problem
Dhaka area Total				5803	3218	57098494		
38	Chattogram ST-1 (Raozan)	PDB	1*210	180		100	2400000	Gas shortage
	Chittogong ST-2 (Raozan)	PDB	1*210	180		100	2400000	Gas shortage
39	Raazan 25 MW (RPCL)	IPP	3*8.9	25		25	196969	
40	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20		0	140130	
41	Patenga 50MW	IPP	8*6.98	50		47	917280	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230		37	853740	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40		0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225		217	4922659	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150		132	3066310	FGMO
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*11.5	51		24	462240	Engine problem
47	Baraka Sikalbaha PL	IPP	105 MW	105		90	947590	Engine problem
48	Hathazari peaking	PDB	11*8.9	98		58	250288	
49	Dohazari Peaking	PDB	6*17	102		51	289388	
50	Juidah (Acorn)	QRPP	8*13.45	100		50	310520	Low demand
51	Juidah 100 MW Unit-3	IPP	0	100		100	1872660	
52	Barakunda (Regent)	SIPP, PDB	8*2.90	22		18	405456	
**	Malancha, Ctg, EPZ (United)		5*8.73+3*9.34	0		42	978250	
53	Chattogram ECPV 108 MW	IPP	16*7	108		0	192000	Engine problem
	Kaptai Solar	PDB	7.4 MW	0		0	964944	
	Anwara United	United Group	300 MW	0		0	2514109	on test
Chattogram area Total				1786	1091	24084360		
54	Ashuganj ST: Unit- 3	APSCL	1*150	135		0	1171491	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129		0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134		0	0	Gas shortage
55	Ashuganj CCPP 225 MW	APSCL	1*142+1*75	221		215	4710000	FGMO
56	Ashuganj CCPP(North)	APSCL	1*360	360		360	8073200	
57	Ashuganj CCPP(South)	APSCL	1*360	360		230	7145000	ST tripped 19:24
58	Ashuganj Engines TSK	APSCL	14*3.968	45		0	0	Gas Line maint.
59	Ashuganj (Precision) 55MW	RPP	15*4	55		55	1289760	
60	Ashuganj (United) 53MW	QRPP	14*4	53		0	95000	tripped at 19:24
61	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195		0	535272	tripped at 19:24
62	Ashuganj (Midland) 51MW	IPP	6*9.34	51		0	734672	tripped at 19:24
63	Midland 150MW	IPP	23*7.015	150		0	424872	tripped at 19:24
64	B.Barua (Aggreko) 85MW	QRPP	86*1.10	85		0	0	Contract Expired
65	Daudkandi Peaking 52MW	PDB	6*8.92	52		8	29544	Low demand
66	Chandpur CCPP	PDB	1*106+1*57	163		98	2300630	
67	Chandpur Desh 200MW	IPP	0	200		200	2555520	
68	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22		22	507564	
69	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11		11	212760	
**	Tripura	Imported power	0	160		172	3472320	
70	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33		25	599100	
71	Lakdhanvi 52 MW	IPP	6*8.92	52		52	427387	
72	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25		20	487440	
73	Daudkandi bangla trak	IPP	154*1.4	200		0	0	Reserve
Cumilla Area Total				2991	1468	34714532		
74	Mymensingh RPCL 210MW	IPP	4*35+1*70	202		143	3338600	GT-1 Under maint
75	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22		20	449136	
76	Jamalpur 95MW	IPP	12*8.924	95		92	1756800	
77	Saishabari (Solar)	IPP	1*3	3		0	14800	
78	United Mymensingh PPL	IPP	200	200		190	2138400	Engine problem
79	United Jamalpur PPL	IPP	115 MW	115		93	2188800	Engine problem
Mymensingh Area Total				637	538	9936536		
80	Fenchugonj CCPP-1	PDB	2*32+1*33	70		56	1361000	
81	Fenchugonj CCPP-2	PDB	2*35+1*35	90		58	1154160	
82	Kushliara 163 MW CCPP GT	IPP	1*109+1*54	163		100	3197021	Frequency control
83	Shahjibazar 330 MW	PDB	3*110	330		250	5661000	FGMO
84	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51		53	1164000	
85	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44		50	1135944	
86	Hobiganj 11MW	SIPP, REB	4*2.90	11		11	254448	
87	Shahjibazar GT: Unit- 8, 9	PDB	2*35	66		61	1375488	FGMO
88	Shahjibazar 86MW	RPP	32*2.90	86		82	1652160	
89	Shahjibazar (EPL) 50MW	RPP	27*2.0	50		46	972720	Engine problem
90	Sylhet GT 150 MW	PDB	1*142	142		121	2611270	
91	Sylhet GT 20 MW	PDB	1*20	20		18	345000	
92	Sylhet (EPL) 50MW	RPP	27*2	50		43	859780	
93	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25		24	447576	
94	Summit Bibiana- 2	IPP	1*222+1*119	341		0	0	Gas field shut down
	Bibiyana-3 285 MW	PDB	285 MW	0		260	6181400	On test
95	Sylhet (Desh) 10MW	RPP	6*1.95	10		10	189180	
Sylhet Area Total				1549	1243	28562147		
**	Bheramara GT-1,2,3	PDB	3*20	46		32	147400	
**	Bheramara (HVDC)	Imported power	2*500	1000		931	16713455	
	Khulna (KPCL-1 & 3)	IPP	19*6.5	0		0	0	Contract Expired
97	Khulna (KPCL-2)	QRPP	7*17	115		99	1173120	Engine problem
98	Farijpur Peaking	PDB	8*6.89	54		0	153120	Reserve
99	Khulna CCPP 225MW	NWPGCL	1*150+1*75	220		0	0	Reserve
100	Gopalganj Peaking	PDB	16*6.98	109		80	335488	
101	Bheramara 360 MW	NWPGCL	1*278+1*132	410		0	0	Under maint.
102	Noapara (KZA) 40MW	QRPP	5*8.5	40		32	611625	
103	Khulna (Aggreco) 55MW	QRPP	71*0.85	0		0	0	Contract Expired
104	Bangla Trak Noapara	IPP	70*1.4	100		100	782400	
105	Labon Chora 105 MW	IPP	6*18.445	105		105	1802400	
106	Madhumati Power Plant	IPP	100 MW	105		98	1768464	Engine problem
Khulna Area Total				2314	1457	23487472		
106	Summit Barisal 110 MW	IPP	7*17.076	110		110	1043520	
107	Barisal GT: Unit-1, 2	PDB	2*20	30		12	38831	
108	Bhola (Venture) 33MW	RPP	1*34.50	33		39	717390	
109	Bhola CCPP 194MW	PDB	2*63+1*68	194		143	353906	FGMO
110	Bhola Aggreko 95MW	QRPP	96*1.10	95		96	2294439	
Barisal Area Total				462	400	7628086		
111	Baghabari GT 71MW	PDB	1*71	71		55	1365000	
	Baghabari GT 100MW	PDB	1*100	100		0	0	Under maint.
112	Baghabari Peaking 50MW	PDB	6*8.9	52		50	449296	
113	Bera Peaking							