

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	804000	Gas shortage
	Ghorasal GT: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal GT: Unit-4	PDB	1*210	180	200	4815000	
	Ghorasal ST: Unit-5	PDB	1*210	190	35	157500	Gas shortage
2	Ghorasal ST: Unit-7	PDB	1*240+1*122	365	333	7482200	
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	50	1361024	Gas shortage
4	Ghorasal (Regent)	IPP	34*3.35	108	73	2073136	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	269100	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	333	8296056	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	55	248600	Low demand
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	302	7497000	Frequency control
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	380	8996250	Frequency control
10	Meghnaghat (EL)	QRPP	12*8.9	100	40	281280	Low demand
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	230	6718342	FGMO
12	Madanganj 102MW	QRPP	6*17	100	50	220872	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	244023	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	40	239335	Low demand
15	Narshingdi (Doreen)	SIIPP, REB	8*2.90	22	22	439020	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	0	1013000	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
18	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	100	586560	
19	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	150	4075183	
	Paglia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gagnagar (Orion)	IPP	12*8.924	102	70	797184	Low demand
21	Katpotti 51 MW	IPP	7*7.9	51	6	204672	Low demand
22	Banco Energy 54MW	IPP	3*18	54	54	1130040	
23	Kodda 149MW	BPDB-RPCL	9*17.06	149	127	1607520	Low demand
24	Northern 55 MW	IPP	3*19.3	55	56	959065	
25	Southern 55MW	IPP	3*19.3	55	55	896450	
26	Sosita 108MW	IPP	12*8.775+1*3.5	108	73	1381440	Engine problem
27	Summit Power (Madhabdi+Ashuli)	SIIPP, REB	3*3.67+4*8.73	90	49	1116780	Engine problem
28	Summit Maona	SIIPP, REB	4*8.73	33	25	583600	Engine problem
29	Summit Rugganj	SIIPP, REB	4*8.73	33	33	782600	
30	Gazipur (RPCL)	IPP	6*8.9	52	48	1100952	
31	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
32	Summit Gazipur -2	IPP	18*17.076	300	150	895745	Low demand
33	APR Energy, Keraniganj	IPP	256*1.4	300	0	0	Reserve
34	Bramhangoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
35	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
36	Summit Gazipur-1 150MW	IPP	149	149	133	2076480	Low demand
37	Gazipur 100 MW	RPCL	100 MW	105	107	2223600	
Dhaka area Total				5803	3469	71573609	
38	Chattogram ST-1 (Raozan)	PDB	1*210	180	90	2000000	Gas shortage
	Chittong ST-2 (Raozan)	PDB	1*210	180	120	2900000	Gas shortage
39	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	370611	
40	Teknaf Solartech 20MW	Teknaf Solartech Energ	20	20	0	135675	
41	Patenga 50MW	IPP	8*6.98	50	46	1063200	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	39	820080	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	201	4722496	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Gas shortage
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	24	445920	Engine problem
47	Baraka Sikalbaha PL	IPP	105 MW	105	17	293562	Low demand
48	Hathazari peaking	PDB	11*8.9	98	85	399072	
49	Dohazari Peaking	PDB	6*17	102	62	661939	
50	Juidah (Acorn)	QRPP	8*13.45	100	20	478560	Low demand
51	Juidah 100 MW Unit-3	IPP	0	100	100	2312540	
52	Barakunda (Regent)	SIIPP, PDB	8*2.90	22	21	489696	
**	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	19	461760	
53	Chattogram ECPV 108 MW	IPP	16*7	108	87	1619520	Engine problem
	Kaptai Solar	PDB	7.4 MW	0	0	30200	
	Anwara United	United Group	300 MW	0	303	7273850	on test
Chattogram area Total				1786	1259	26478781	
54	Ashuganj ST: Unit- 3	APSCL	1*150	135	100	2609904	
	Ashuganj ST: Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	0	0	Gas shortage
55	Ashuganj CCPP 225 MW	APSCL	1*142+1*75	221	218	4868000	FGMO
56	Ashuganj CCPP(North)	APSCL	1*360	360	30	3923800	Machine tripped
57	Ashuganj CCPP(South)	APSCL	1*360	360	330	7939500	Frequency control
58	Ashuganj Engines TSK	APSCL	14*3.968	45	0	0	Gas Line maint.
59	Ashuganj (Precision) 55MW	RPP	15*4	55	20	858240	Gas shortage
60	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Engine problem
61	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	110	1405090	Gas shortage
62	Ashuganj (Midland) 51MW	IPP	6*9.34	51	35	728640	Engine problem
63	Midland 150MW	IPP	23*7.015	150	145	1950400	
64	B.Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
65	Daudkandi Peaking 52MW	PDB	6*8.92	52	42	43240	Low demand
66	Chandpur CCPP	PDB	1*106+1*57	163	70	1387960	
67	Chandpur Desh 200MW	IPP	0	200	200	4232160	
68	Feni (Doreen) 22MW	SIIPP, PDB	8*2.90	22	22	378288	
69	Feni, Mohipal (Doreen)	SIIPP, REB	4*2.90	11	11	233640	
**	Tripura	Imported power	0	160	163	3798720	
70	Jangalia (Summit) 33MW	SIIPP, PDB	4*8.73	33	25	777000	Engine problem
71	Lakdhanvi 52 MW	IPP	6*8.92	52	52	845458	
72	Summit Cumilla 25MW	SIIPP, PDB	3*3.67+2*6.97	25	19	337280	Engine problem
73	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1597	36437320	
74	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	147	3401160	GT-1 Under maint
75	Tangail (Doreen) 22MW	SIIPP, PDB	8*2.90	22	0	359676	
76	Jamalpur 95MW	IPP	12*8.924	95	83	1983360	Engine problem
77	Sarishabari (Solar)	IPP	1*3	3	0	9050	
78	United Mymensingh PPL	IPP	200	200	94	1694400	Low demand
79	United Jamalpur PPL	IPP	115 MW	115	83	2002800	Engine problem
Mymensingh Area Total				637	407	9450446	
80	Fenchuganj CCPP-1	PDB	2*32+1*33	70	56	1342000	
81	Fenchuganj CCPP-2	PDB	2*35+1*35	90	58	1401240	
82	Kushlaria 163 MW CCPP GT	IPP	1*109+1*54	163	163	3286783	
83	Shajibazar 330 MW	PDB	3*110	330	95	605000	FGMO
84	Fenchuganj (Barakatullah) 51MW	RPP	19*2.90	51	46	1137000	
85	Fenchuganj (EPL) 44MW	RPP	12*3.3+5*2	44	46	11079496	
86	Hobiganj 11MW	SIIPP, REB	4*2.90	11	11	264000	
87	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	42	1349280	FGMO
88	Shajibazar 86MW	RPP	32*2.90	86	79	1717440	Engine problem
89	Shajibazar (EPL) 50MW	RPP	27*2.0	50	45	990720	
90	Sylhet GT 150 MW	PDB	1*142	142	83	2457410	FGMO
91	Sylhet GT 20 MW	PDB	1*20	20	0	11000	
92	Sylhet (EPL) 50MW	RPP	27*2	50	46	1037220	
93	Shahjahanulla 25 MW	SIIPP, REB	3*9.34	25	24	515976	
94	Summit Bibiana- 2	IPP	1*222+1*119	341	240	5902028	FGMO
	Bibiyan-3 285 MW	PDB	285 MW	0	250	6196000	On test
95	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	234540	
Sylhet Area Total				1549	1294	39427133	
96	Bheramara GT-1,2,3	PDB	3*20	46	32	170900	
**	Bheramara (HVDC)	Imported power	2*500	1000	940	22566363	
	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
97	Khulna (KPCL-2)	QRPP	7*17	115	115	1567680	
98	Fardpur Peaking	PDB	8*6.89	54	33	227520	
99	Khulna CCPP 225MW	NWPGCL	1*150+1*175	230	70	1361280	Low demand
100	Gopalganj Peaking	PDB	16*6.98	109	60	280064	Low demand
101	Bheramara 360 MW	NWPGCL	1*278+1*132	410	0	0	Under maint.
102	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	523500	
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
103	Bangla Trak Noapara	IPP	70*1.4	100	97	634560	
104	Labon Chora 105 MW	IPP	6*18.445	105	105	1771680	
105	Madhumati Power Plant	IPP	100 MW	105	102	2089008	
Khulna Area Total				2314	1594	31182555	
106	Summit Barisal 110 MW	IPP	7*17.076	110	110	1415040	
107	Barisal GT: Unit-1, 2	PDB	2*20	30	12	61228	Low demand
108	Bhola (Venture) 33MW	RPP	1*34.50	33	34	718122	
109	Bhola CCPP 194MW	PDB	2*63+1*68	194	144	3496160	FGMO
110	Bhola Aggreko 95MW	QRPP	96*1.10	95	97	2233067	
Barisal Area Total				462	397	7923617	
111	Baghabari GT 71MW	PDB	1*71	71	60	1385000	
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
112	Baghabari Peaking 50MW	PDB	6*8.9	52	43	284936	
113	Bera Peaking	PDB	9*8.29	71	33	132128	
114	Amnura 50MW	QRPP	7*7.79	50	40	362600	Engine problem
115	Katakali (Northern)	QRPP	6*8.9	50	16	307450	Low demand
116	Katakali Peaking	PDB	6*8.7	50	0	121594	Reserve
117	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	181	4625109	FGMO
118	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	172	4538145	FGMO
119	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	171	4581182	FGMO
120	Sirajgonj Unit-4 414 MW(Gas)	SNWPGCL	1*282+1*132	41			