

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	806000	Gas shortage
	Ghorasal GT: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal ST: Unit-4	PDB	1*210	180	150	3898000	
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Gas shortage
2	Ghorasal 78MW (MAX)	PDB	1*243+1*122	365	280	790818	Low demand
4	Ghorasal (Regent)	QRPP	2*40	78	50	120265	TF OIL
5	Hairpur GT: Unit-1, 2	IPB, PDB	3*43.35	108	73	1819090	Gas shortage
6	Hairpur 412 MW CCPP	EGCB	1*273+1*139	412	330	8091650	FGMO
7	Hairpur NEPC 110MW	IPP	8*15	110	110	292200	
8	Hairpur Power CCPP 360MW	IPP	1*235+1*125	360	335	7726000	Frequency control
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	360	9296125	Frequency control
10	Meghnaghat (IEL)	QRPP	12*8.9	100	8	201600	Low demand
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	275	5932829	FGMO
12	Madanganj 102MW	QRPP	6*17	100	90	460272	
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	15	185254	Low demand
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	10	134696	Low demand
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	312264	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	0	0	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
18	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	50	184320	Low demand
19	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	200	4328184	
	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gagnagar (Orion)	IPP	12*8.924	102	64	942048	Low demand
21	Katpott 51 MW	IPP	7*7.9	51	49	675360	
22	Banco Energy 54MW	IPP	3*18	54	54	806760	
23	Kodda 149MW	BPDB-RPCL	9*17.06	149	130	1022880	Engine problem
24	Northern 55 MW	IPP	3*19.3	55	55	807351	
25	Southern 55MW	IPP	3*19.3	55	55	672330	
26	Bosha 108MW	IPP	12*8.775+1*13.5	108	73	1026240	Engine problem
27	Summit Power, (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	24	1086420	Engine problem
28	Summit Maona	SIPP, REB	4*8.73	33	25	649400	Engine problem
29	Summit Rugganj	SIPP, REB	4*8.73	33	33	789200	
30	Gazipur (RPCL)	IPP	6*8.9	52	47	759444	
31	Tongi GT	PDB	1*105	105	0	0	Gas shortage
32	Summit Gazipur -2	IPP	18*17.076	300	245	1134108	Low demand
33	APR Energy, Keraniganj	IPP	256*1.4	300	0	0	Reserve
34	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
35	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
36	Summit Gazipur-1 150MW	IPP	149	149	142	1733760	
37	Gazipur 100 MW	RPCL	100 MW	105	106	2169600	
<b>Dhaka area Total</b>				<b>5803</b>	<b>3495</b>	<b>6711659</b>	
38	Chattogram ST-1 (Raozan)	PDB	1*210	180	100	2200000	Gas shortage
	Chittgong ST-2 (Raozan)	PDB	1*210	180	120	2900000	Gas shortage
39	Raazan 25 MW (RPCL)	IPP	3*8.9	25	25	306525	
40	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	97470	
41	Patenga 50MW	IPP	8*6.98	50	47	756480	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	32	835600	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	3908412	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Gas shortage
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*11.5	51	33	483840	Engine problem
47	Baraka Sikalbaha PL	IPP	105 MW	105	17	186508	Low demand
48	Hathazari peaking	PDB	11*8.9	98	24	98016	
49	Dohazari Peaking	PDB	6*17	102	68	442248	
50	Judaih (Acom)	QRPP	8*13.45	100	100	982230	
51	Judaih 100 MW Unit-3	IPP	0	100	100	243840	
52	Barakunda (Regent)	SIPP, PDB	8*2.90	22	21	484124	
**	Malancha, Ctg, EPZ (United)		5*8.73+3*9.34	0	30	456480	
53	Chattogram ECPV 108 MW	IPP	16*7	108	88	1182720	Engine problem
	Kaptai Solar	PDB	7.4 MW	0	0	33600	
	Anwara United	United Group	300 MW	0	304	4298072	on test
<b>Chattogram area Total</b>				<b>1786</b>	<b>1109</b>	<b>19876215</b>	
54	Ashuganj ST: Unit- 3	APSCL	1*150	135	100	2461614	
	Ashuganj ST: Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	0	0	Gas shortage
55	Ashuganj CCPP 225 MW	APSCL	1*142+1*75	221	215	4919000	FGMO
56	Ashuganj CCPP(North)	APSCL	1*360	360	310	2684900	
57	Ashuganj CCPP(South)	APSCL	1*360	360	260	7698000	Frequency control
58	Ashuganj Engines TSK	APSCL	14*3.968	45	0	0	Gas Line maint.
59	Ashuganj (Precision) 55MW	RPP	15*4	55	54	1257600	
60	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Engine problem
61	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	16	1538909	Gas shortage
62	Ashuganj (Midland) 51MW	IPP	6*9.34	51	40	743428	
63	Midland 150MW	IPP	23*7.015	150	0	647350	Low demand
64	B.Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
65	Daukandi Peaking 52MW	PDB	6*8.92	52	0	63976	
66	Chandpur CCPP	PDB	1*106+1*57	163	100	1895540	
67	Chandpur Desh 200MW	IPP	0	200	200	2944800	
68	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	21	420084	
69	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	127080	
**	Tripura	Imported power	0	160	138	2932800	
70	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	33	667600	
71	Lakdhanvi 52 MW	IPP	6*8.92	52	52	707208	
72	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	20	358170	Engine problem
73	Daukandi bangla trak	IPP	15*4.14	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1572</b>	<b>32180059</b>	
74	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	141	3337090	GT-1 Under maint
75	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	21	345924	
76	Jamalpur 95MW	IPP	12*8.924	95	85	1181760	Engine problem
77	Saishabari (Solar)	IPP	1*3	3	0	12850	
78	United Mymensingh PPL	IPP	200	200	200	1586400	
79	United Jamalpur PPL	IPP	115 MW	115	93	2043600	Engine problem
<b>Mymensingh Area Total</b>				<b>637</b>	<b>540</b>	<b>8557614</b>	
80	Fenchugonj CCPP-1	PDB	2*32+1*33	70	56	1322000	
81	Fenchugonj CCPP-2	PDB	2*35+1*35	90	58	1374309	
82	Kushlaria 163 MW CCPP GT	IPP	1*109+1*54	163	130	3133415	Frequency control
83	Shajibazar 330 MW	PDB	3*110	330	200	2922000	FGMO
84	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	871800	
85	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	49	901872	
86	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	262992	
87	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	61	1440000	FGMO
88	Shajibazar 86MW	RPP	32*2.90	86	82	1535040	
89	Shajibazar (EPL) 50MW	RPP	27*2.0	50	46	831600	
90	Sylhet GT 150 MW	PDB	1*142	142	120	2486730	FGMO
91	Sylhet GT 20 MW	PDB	1*20	20	0	0	
92	Sylhet (EPL) 50MW	RPP	27*2	50	46	854700	
93	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	24	406752	
94	Summit Bibiana- 2	IPP	1*222+1*119	341	260	6861300	FGMO
	Bibiana-3 285 MW	PDB	285 MW	0	289	5648000	On test
95	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	172820	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>1495</b>	<b>31028130</b>	
96	Bheramara GT-1,2,3	PDB	3*20	46	30	185300	
**	Bheramara (HVDC)	Imported power	2*500	1000	929	22376727	
	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
97	Khulna (KPCL-2)	QRPP	7*17	115	115	1622400	
98	Faridpur Peaking	PDB	8*6.89	54	39	332840	
99	Khulna CCPP 225MW	NWPGCL	1*150+1*75	230	100	723940	Low demand
100	Gopalganj Peaking	PDB	16*6.98	109	50	238948	Low demand
101	Bheramara 360 MW	NWPGCL	1*278+1*132	410	0	0	Under maint.
102	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	724500	
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
103	Bangla Trak Noapara	IPP	70*1.4	100	100	1008960	
104	Labon Chora 105 MW	IPP	6*18.445	105	105	1854240	
105	Madhumati Power Plant	IPP	100 MW	105	88	1635264	
<b>Khulna Area Total</b>				<b>2314</b>	<b>1596</b>	<b>30702719</b>	
106	Summit Barisal 110 MW	IPP	7*17.076	110	110	857080	
107	Barisal GT: Unit-1, 2	PDB	2*20	30	0	0	Low demand
108	Bhola (Venture) 33MW	RPP	1*34.50	33	38	581502	
109	Bhola CCPP 194MW	PDB	2*63+1*68	194	172	3748309	FGMO
110	Bhola Aggreko 95MW	QRPP	96*1.10	95	98	1966083	
<b>Barisal Area Total</b>				<b>462</b>	<b>418</b>	<b>7152974</b>	
111	Baghabari GT 71MW	PDB	1*71	71	60	1395000	
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
112	Baghabari Peaking 50MW	PDB	6*8.9	52	43	235352	
113	Bera Peaking	PDB	9*8.29	71	32	173057	
114	Amnura 50MW	QRPP	7*7.79	50	40	200490	Engine problem
115	Katakhali (Northern)	QRPP	6*8.9	50	43	374852	
116	Katakhali Peaking	PDB	6*8.7	50	44	211130	
117	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	182	4705618	FGMO
118	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	185	4542256	FGMO
119	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	195	4905118	FGMO
120	Sirajgonj Unit-4 414 MW(Gas)	SNWPGCL	1*282+1*132	414	320	8401272	Frequency control
121	Santahar Peaking	PDB	6*8.7	50	28	153193	
122	Bogra (GBB)	RPP	6*4				