

Date : 19-Jun-19			Page -2				
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	65	1102000	Gas shortage
	Ghorasal GT: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal GT: Unit-4	PDB	1*210	180	190	4164000	Gas shortage
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Gas shortage
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	320	5945454	Gas shortage
3	Ghorashal 78MW (MAX)	QRPP	2*40	78	63	1378272	
4	Ghorashal (Regent)	IPP	34*3.35	108	106	2240409	
5	Harpur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Harpur 412 MW CCPP	EGCB	1*273+1*139	412	347	8290300	FGMO
7	Harpur NEPC 110MW	IPP	8*15	110	55	544600	Low demand
8	Harpur Power CCPP 360MW	IPP	1*235+1*125	360	338	7414000	Frequency control
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	450	9498500	
10	Meghnaghat (IEL)	QRPP	12*8.9	100	55	777600	Low demand
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	260	5835142	FGMO
12	Madanganj 102MW	QRPP	6*17	100	0	223464	Reserve
13	Madanganj-55 MW	(IPP)	3*17,08+1*11.3	55	55	575520	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	50	491832	Low demand
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	429264	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	0	0	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
18	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	50	309120	Low demand
19	Siddhirgonj CCPP-335 MW	EGCB	1*217	180	180	4364147	Low demand
	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gagnagar (Orion)	IPP	12*8.924	102	70	1108944	Low demand
21	Katpotti 51 MW	IPP	7*7.9	51	48	352032	
22	Banco Energy 54MW	IPP	3*18	54	54	1201320	
23	Kodda 149MW	BPDB-RPCL	9*17.06	149	125	1902240	Engine problem
24	Northern 55 MW	IPP	3*19.3	55	35	796520	
25	Southern 55MW	IPP	3*19.3	55	55	862000	
26	Bosila 108MW	IPP	12*8.775+1*3.5	108	70	1419840	Engine problem
27	Summit Power,(Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	53	1180500	Engine problem
28	Summit Maona	SIPP, REB	4*8.73	33	33	624000	
29	Summit Rugganj	SIPP, REB	4*8.73	33	33	828800	
30	Gazipur (RPCL)	IPP	6*8.9	52	0	816192	Reserve
31	Tongi GT	PDB	1*105	105	0	0	Gas shortage
32	Summit Gazipur -2	IPP	18*17.076	300	114	659890	Low demand
33	APR Energy, Keraniganj	IPP	256*1.4	300	0	0	Reserve
34	Bramhangano 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
35	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
36	Summit Gazipur-1 150MW	IPP	149	149	149	2177280	
37	Gazipur 100 MW	RPCL	100 MW	105	106	2535600	
Dhaka area Total				5803	3551	70068582	
38	Chattogram ST-1 (Raozan)	PDB	1*210	180	5	2300000	Gas shortage
	Chittong ST-2 (Raozan)	PDB	1*210	180	120	3000000	Gas shortage
39	Raozan 25 MW (RPCL)	IPP	3*8.9	25	8	401079	Machine problem
40	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	107190	
41	Patenga 50MW	IPP	8*6.98	50	47	1028160	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	38	799980	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	204	4796114	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	90	2362467	Gas shortage
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	33	767040	Engine problem
47	Baraka Sikalbaha PL	IPP	105 MW	105	0	0	Reserve
48	Hathazari peaking	PDB	11*8.9	98	70	386760	
49	Dohazari Peaking	PDB	6*17	102	68	440698	
50	Juldah (Acom)	QRPP	8*13.45	100	10	524760	Line O/L
51	Juldah 100 MW Unit-3	IPP	0	100	100	223584	
52	Barakunda (Regent)	SIPP, PDB	8*2.90	22	21	485860	
*	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	30	478560	
53	Chattogram ECPV 108 MW	IPP	16*7	108	32	1012800	Line O/L
	Kaptai Solar	PDB	7.4 MW	0	0	36960	
	Anwara United	United Group	300 MW	0	304	7293927	on test
Chattogram area Total				1786	1160	26445835	
54	Ashuganj ST: Unit- 3	APSCL	1*150	135	100	2471500	
	Ashuganj ST: Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	0	0	Gas shortage
55	Ashuganj CCPP 225 MW	APSCL	1*142+1*75	221	200	4797000	FGMO
56	Ashuganj CCPP(North)	APSCL	1*360	360	360	8192100	
57	Ashuganj CCPP(South)	APSCL	1*360	360	300	7274500	Frequency control
58	Ashuganj Engines TSK	APSCL	14*3.968	45	0	0	Gas Line maint.
59	Ashuganj (Precision) 55MW	RPP	15*4	55	53	1215360	
60	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Engine problem
61	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	16	434909	Gas shortage
62	Ashuganj (Midland) 51MW	IPP	6*9.34	51	40	959200	
63	Midland 150MW	IPP	23*7.015	150	133	1669382	Engine problem
64	B.Barua (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
65	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	87656	Reserve
66	Chandpur CCPP	PDB	1*106+1*57	163	50	1725610	
67	Chandpur Desh 200MW	IPP	0	200	200	3661440	
68	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	495720	
69	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	183060	
**	Tripura	Imported power	0	160	152	3580800	
70	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	33	796300	
71	Lakdhanvi 52 MW	IPP	6*8.92	52	52	898090	
72	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	19	457080	Engine problem
73	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1743	39019707	
74	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	140	3320400	GT-1 Under maint
75	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	461736	
76	Jamalpur 50MW	IPP	12*8.924	95	85	2010240	Engine problem
77	Sarishabari (Solar)	IPP	1*3	0	0	12960	
78	United Mymensingh PPL	IPP	200	200	180	3273600	
79	United Jamalpur PPL	IPP	115 MW	115	93	2229600	Engine problem
Mymensingh Area Total				637	620	11308626	
80	Fenchugonj CCPP-1	PDB	2*32+1*33	70	56	1322000	
81	Fenchugonj CCPP-2	PDB	2*35+1*35	90	57	1384520	
82	Kushliara 163 MW CCPP GT	IPP	1*109+1*54	163	100	3191375	Frequency control
83	Shahjibazar 330 MW	PDB	3*110	330	251	4136000	FGMO
84	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	1146600	
85	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	49	1157328	
86	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	256896	FGMO
87	Shahjibazar GT: Unit- 8, 9	PDB	2*35	66	59	1333056	
88	Shahjibazar 86MW	RPP	32*2.90	86	80	1852800	
89	Shahjibazar (EPL) 50MW	RPP	27*2.0	50	45	983880	
90	Syhet GT 150 MW	PDB	1*142	142	120	2558140	FGMO
91	Syhet GT 20 MW	PDB	1*20	20	0	0	Reserve
92	Syhet (EPL) 50MW	RPP	27*2	50	47	912540	
93	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	16	475776	
94	Summit Bibiana- 2	IPP	1*222+1*119	341	300	7120700	FGMO
95	Bibyana-3 285 MW	PDB	285 MW	0	288	6525000	On test
95	Syhet (Desh) 10MW	RPP	6*1.95	10	10	229320	
Syhet Area Total				1549	1542	34565931	
96	Bheramara GT-1,2,3	PDB	3*20	46	28	163500	
**	Bheramara (HVDC)	Imported power	2*500	1000	925	22279272	
	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
97	Khulna (KPCL-2)	QRPP	7*17	115	99	1350720	Engine problem
98	Faridpur Peaking	PDB	8*6.89	54	32	290400	
99	Khulna CCPP 225MW	NWPGCL	1*150+1*75	230	120	2614080	Low demand
100	Gopalganj Peaking	PDB	16*8.98	109	40	317312	Low demand
101	Bheramara 360 MW	NWPGCL	1*278+1*132	410	0	0	Under maint.
102	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	676125	
	Khulna (Aggreko) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
103	Bangla Trak Noapara	IPP	70*1.4	100	100	803520	
104	Labon Chora 105 MW	IPP	6*18.445	105	105	1460160	
105	Madhumali Power Plant	IPP	100 MW	105	87	1859760	
Khulna Area Total				2314	1576	31814849	
106	Summit Barisal 110 MW	IPP	7*17.076	110	110	1008960	
107	Barisal GT: Unit-1, 2	PDB	2*20	30	12	69099	Low demand
108	Bhola (Venture) 33MW	RPP	1*34.50	33	37	717664	
109	Bhola CCPP 194MW	PDB	2*63+1*68	194	172	4204225	FGMO
110	Bhola Aggreko 95MW	QRPP	96*1.10	95	98	256226	
Barisal Area Total				462	429	8256174	
111	Baghabari GT 71MW	PDB	1*71	71	55	1345000	
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
112	Baghabari Peaking 50MW	PDB	6*8.9	52	50	412768	
113	Bera Peaking	PDB	9*8.29	71	27	157621	
114	Amnura 50MW	QRPP	7*7.79	50	33	236820	Engine problem
115	Katakhali (Northern)	QRPP	6*8.9	50	8	446683	
116	Katakhali Peaking	PDB	6*8.7	50	44	384100	
117	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	169	4609127	FGMO
118	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	160	4449091	FGMO
119	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	181	4742173	FGMO
120	Sirajgonj Unit-4 414 MW(Gas)	NWPGCL	1*282+1*132	414	408	8990909	
121	Santahar Peaking	PDB	6*8.7	50	28	295290</	