

Date : 5-Aug-19		Page -2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
			Unit No. X Capacity	MW	Generation	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	35	790000	#2 Under maint.
	Ghorasal Repowered CCPP Unit-	PDB	1*210	170	189	4486000	
	Ghorasal Repowered CCPP Unit-	PDB	1*210	180	220	4912000	
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
3	Ghorashal 78.5 MW PP(MAX)	QRPP	2*40	78	65	1481760	Engine problem
4	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	96	2093000	
5	Hartpur GTTP	SBU, PDB	2*32	40	0	148000	Gas shortage
6	Hartpur 412 MW CCPP	EGCB	1*273+1*139	412	345	8645630	FGMO
7	Hartpur 360MW CCPP(HPL)	IPP	1*235+1*125	360	345	6960000	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	450	9173500	
9	Meghnaghat 100 MW(IEL)	QRPP	12*8.9	100	100	1182720	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	260	6714996	FGMO
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	81	851472	Engine problem
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	1014167	
13	Keraniganj 100 MW PP (Powerpa	QRPP	8*13.45	100	100	1591377	
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	402264	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	712000	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
17	Siddhirgonj 100 PP(Dutch Bangla	QRPP	12*8.9	100	100	900960	
18	Siddhirgonj 335 MW CCPP	EGCB	1*217	217	0	0	Testing
	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
19	Gagnagar 102 MW PP (Digital Po	IPP	12*8.924	102	101	1797840	
20	Katpott 52 MW PP (Sinha)	IPP	7*7.9	51	20	436032	Engine problem
21	Kamalaghat 54 MW PP(Banco Er	IPP	3*18	54	53	1303920	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	149	2753280	
23	Manikganj 55 MW PP (Northern	IPP	3*19.3	55	55	1146361	
24	Nababganj 55 MW PP (Southern	IPP	3*19.3	55	55	1257698	
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	80	72	1719360	Engine problem
26	Summit Power,(Madhabdi+Ashul	SIPP, REB	3*3.67+4*8.73	108	52	1261500	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	620300	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	582100	Engine problem
29	Gazipur 52 MW PP	IPP	6*8.9	52	42	863856	Engine problem
30	Tongi 80 MW GTTP	PDB	1* 105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	210	2386144	Low demand
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	212	1861394	Low demand
33	Bramhangaoan 100 MW PP (Aggr	IPP	100	100	98	1041940	
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	102	1069131	
35	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	149	2623680	
36	Gazipur 100 MW PP	RPCL	100 MW	105	103	2477214	
Dhaka area Total				5693	3995	77261794	
37	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
	Chattogram TPP-2	PDB	1*210	180	0	2600000	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	25	592689	
39	Teknaf 20MW PP (Solartech)Tefnaf Solartech Energ	IPP	20	20	0	140670	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	1004160	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	177	4830576	
42	Sikalbaha 225MW	PDB	1*150+1*175	225	204	4915009	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	135	2777253	FGMO
44	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	0	0	Contract Expired
45	Sikalbaha 105 MW PP (Baraka Si	IPP	105 MW	105	0	0	Reserve
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
47	Dohazari -Kalaish 100 MW Peakir	PDB	6*17	102	68	495774	
48	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	85	739080	Engine problem
49	Juldah 100 MW PP Unit-3 (Acorn	IPP	0	100	100	2433600	
50	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	451008	
	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	19	432480	
51	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	96	1233600	Engine problem
52	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	35160	
53	Anwara 300 MW PP (United)	IPP	300 MW	300	103	1839764	Transformer over load
	Jodiac Power	IPP	54.36	0	0	107890	on test
	Kamragnuli Power Lid.	IPP	110	0	22	2325917	on test
Chattogram area Total				2053	1103	26954630	
54	Ashuganj TPP Unit-3	APSCl	1*150	135	120	2333096	
	Ashuganj TPP Unit-4	APSCl	1*150	120	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCl	1*150	134	0	0	Gas shortage
55	Ashuganj 225 MW CCPP	APSCl	1*142+1*75	221	181	4645000	FGMO
56	Ashuganj 450 MW CCPP(North)	APSCl	1*360	360	320	7589900	FGMO
57	Ashuganj 450 MW CCPP(South)	APSCl	1*360	360	305	7142000	FGMO
58	Ashuganj 50 MW PP	APSCl	14*3.968	45	33	724896	Engine problem
59	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	50	1199040	
60	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
61	Ashuganj 195MW PP (APSCl-Ur	IPP	20*9.73+1*16	195	68	1689454	Gas shortage
62	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	877362	Engine problem
63	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	120	1980509	
64	B.Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
65	Tilas 50 MW Peaking PP	PDB	6*8.92	52	50	256792	
66	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	135	3256370	
67	Chandpur 200MW (Desh energy)	IPP	0	200	200	4117920	
68	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	17	376560	Engine problem
69	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	245160	
**	Impoprt (Tripura)	Imported power	0	160	146	3518400	
70	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	25	658800	
71	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	950630	
72	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	442600	
73	Daudkandi 200 MW PP (B.Trac	IPP	154*1.4	200	100	541440	Low demand
Cumilla Area Total				2891	1996	42545929	
74	RPCL 210MW CCPP	IPP	4*35+1*70	202	139	3302400	Gas shortage
75	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	463656	
76	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	91	2177280	
77	Saishabari 3 MW Solar Plant	IPP	1*3	3	0	12250	
78	Mymensingh 200 MW PP (Unite	IPP	200	200	180	2800800	Engine problem
79	Jamalpur 115 MW PP (United)	IPP	115 MW	115	114	2619600	
Mymensingh Area Total				637	545	3753596	
80	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	52	1261000	
81	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	65	1597440	
82	Kushinara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3162771	
83	Shahibazar 330 MW CCPP	PDB	3*110	330	262	6041000	FGMO
84	Fenchuganj 51 MW PP (Barakat	RPP	19*2.90	51	50	1114200	
85	Fenchuganj 44MW (Energyprima	RPP	12*3.3+5*2	44	48	1103328	
86	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	224112	
87	Shahibazar GTTP Unit- 8 & 9	PDB	2*35	66	58	1433856	FGMO
88	Shahibazar 86MW PP (Shahibaz	RPP	32*2.90	86	73	1594560	Engine problem
89	Shahibazar 50MW PP (EPL)	RPP	27*2.0	50	35	963720	Engine problem
90	Sylhet 150 MW CCPP	PDB	1*142	142	105	2468550	FGMO
91	Sylhet 20 MW GTTP	PDB	1*20	20	0	110720	
92	Sylhet 50MW PP (EPL)	RPP	27*2	50	41	929000	
93	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	488784	
94	Bibiana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	280	7518200	FGMO
95	Bibiana-III 400 MW CCPP	PDB	285 MW	285	85	2028000	FGMO
96	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	249300	
Sylhet Area Total				1834	1366	32288541	
97	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	9000	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	924	21792727	
	Khulina 115 MW PP (KPCL-1 & 2)	IPP	19*6.5	0	0	0	Contract Expired
98	Khulina 115 PP MW (KPCL-2)	QRPP	7*17	115	110	2216640	
99	Fariapur 50 MW Peaking PP	PDB	8*6.89	54	36	365280	
100	Khulina 225 MW CCPP	NWPGCL	1*150+1*75	230	140	435443	Low demand
101	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	50	409344	
102	Bheramara 360 MW CCPP	NWPGCL	1*278+1*132	410	200	5389344	Gas shortage
103	Noapara 40 MW PP (Khanjahan	QRPP	5*8.5	40	40	816750	
	Khulina (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
104	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	99	1573360	
105	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	2424960	
106	Madhumali 100 MW PP	IPP	100 MW	105	88	2109204	Engine problem
Khulina Area Total				2314	1792	37543872	
107	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	48	570240	Line OIL
108	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve
109	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	35	696178	
110	Bhola 225 MW CCPP	PDB	2*63+1*68	194	179	4343351	
111	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	97	1857690	
Barisal Area Total				462	359	7467459	
112	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
113	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	539472	
114	Bera 70 MW Peaking PP	PDB	9*8.29	71	25	310937	
115	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50	40	403420	Engine problem
116	Katakhali 50 MW PP (Northern	QRPP	6*8.9	50	50	1180633	
117	Katakhali 50 MW Peaking PP	PDB	6*8.7	50	47	703646	
118	Sirajonj Unit-1 225MW	NWPGCL	1*150+1*75	210	130	3547909	FGMO
119	Sirajonj Unit-2 225MW	NWPGCL	1*150+1*75	220</			