

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	70	1578000	
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	189	4527000	
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	320	7441363	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	50	976864	Transformer overload.
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	91	1628818	Engine problem
5	Haripur GTPP	SBU, PDB	2*32	40	0	162000	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	344	8665432	FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	353	7812000	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	360	8423625	Machine problem
9	Meghnaghat 100 MW (IEL)	QRPP	1*2*9	100	100	265920	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	250	6299153	FGMO
11	Madangan 102 PP(Summit)	QRPP	6*17	100	100	1203360	Low demand
12	Madangan-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	276161	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	50	170702	Low demand
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	440856	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	145	3643000	
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	30	99283	Low demand
18	Siddhirgonj 335 MW CCPP	EGCB	1*217	217	0	0	
	Paqia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
19	Gaganraj 102 MW PP (Digital Power)	IPP	12*8.924	102	101	741024	
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	47	489552	
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	53	1092240	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	149	3224160	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	844894	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	35	256678	Engine problem
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	72	1170240	Engine problem
26	Summit Power,(Madhabdi+Ashulia)	SIPP,REB	3*3.67+4*8.73	80	53	1062600	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	811400	
28	Ruggan 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	803100	
29	Gazipur 52 MW PP	IPP	6*8.9	52	51	697596	
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	195	102364	Low demand
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve
33	Bramhanganj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve
34	Aunshi 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	2298240	
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	2453040	
Dhaka area Total				8693	3575	68596665	
37	Chattogram TPP-1	PDB	1*210	180	100	2400000	Gas shortage
	Chattogram TPP-2	PDB	1*210	180	0	0	Under maint.
38	Raczan 25 MW PP	IPP	3*8.9	25	25	161470	
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	121770	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	646080	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	216	4947080	
42	Sikalbaha 225MW	PDB	1*150+1*175	225	203	4914568	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	130	3156322	FGMO
44	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	0	0	Contract Expired
45	Sikalbaha 105 MW PP (Baraka Sikalba)	IPP	105 MW	105	34	173126	Low demand
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Reserve
47	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	85	650168	
48	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	50	377280	Low demand
49	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1771200	
50	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	520032	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	37	502080	
51	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	92	586560	Engine problem
52	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	34080	
53	Anwara 300 MW PP (United)	IPP	300 MW	300	161	1668545	Transformer overload.
	Jodiac Power	IPP	54.36	0	0	53530	on test
	Karnaphuli Power Ltd.	IPP	110	0	0	2008100	Tripped
Chattogram area Total				2053	1305	24691991	
54	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit- 5	APSCL	1*150	134	80	2484464	Gas shortage
55	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	140	1323000	FGMO
56	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	270	8199500	FGMO
57	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	270	7108000	FGMO
58	Ashuganj 50 MW PP	APSCL	14*3.968	45	33	765072	Engine problem
59	Ashuganj 55 MW PP (Precision)	RPP	18*4	55	50	1200480	
60	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
61	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	26	652363	Gas shortage
62	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	957108	Engine problem
63	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	10	105381	Transformer overload.
64	B.Barja (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
65	Titas 50 MW Peaking PP	PDB	6*8.92	52	42	77792	
66	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	140	3268230	
67	Chandpur 200MW (Desh energy)	IPP	0	200	199	3638400	
68	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	440244	
69	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	129060	
**	Impoort (Tripura)	Imported power	0	160	182	3847680	
70	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	790200	
71	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	16	321922	Engine problem
72	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	437020	Engine problem
73	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	63360	Reserve
Cumilla Area Total				2891	1584	35809276	
74	RPCL 210MW CCPP	IPP	4*35+1*70	202	161	4071680	Gas shortage
75	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	451296	
76	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	95	2141760	
77	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	10200	
78	Mymensingh 200 MW PP (United)	IPP	200	200	187	2311200	Engine problem
79	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2670000	
Mymensingh Area Total				637	578	11658136	
80	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	60	1426000	
81	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	48	1266960	
82	Kushiara 163 MW CCPP (KP)	IPP	1*109+1*54	163	100	3431495	Frequency control
83	Shajibazar 330 MW CCPP	PDB	3*110	330	144	3385000	GT-2 under maint.
84	Fenchuganj 51 MW PP (Barakatalullah)	RPP	19*2.90	51	50	1098000	
85	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	50	1118808	
86	Hobiganj 11MW PP (Cofidence-E)	SIPP, REB	4*2.90	11	8	184800	Engine problem
87	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	63	1471296	FGMO
88	Shajibazar 86MW PP (Shajibazar)	RPP	32*2.90	86	75	1635840	Engine problem
89	Shajibazar 50MW PP (EPL)	RPP	27*2.0	50	44	970560	Engine problem
90	Syhet 150 MW CCPP	PDB	1*142	142	0	0	Under S/D
91	Syhet 20 MW GTTP	PDB	1*20	20	18	440330	
92	Syhet 50MW PP (EPL)	RPP	27*2	50	43	962840	Engine problem
93	Shahjanulla 25 MW PP	SIPP, REB	3*9.34	25	24	521256	
94	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	290	7470250	FGMO
95	Bibiana-III 400 MW CCPP	PDB	285 MW	285	80	1913000	Test
96	Syhet 10MW PP (Desh)	RPP	6*1.95	10	10	251820	
Syhet Area Total				1834	1107	27548255	
97	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	925	22226909	
	Khulna 115 MW PP (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
98	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	1006800	
99	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	37	354720	
100	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve
101	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	54	419840	
102	Bheramara 360 MW CCPP	NWPGCL	1*278+1*132	410	300	7915104	Frequency control
103	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	40	562875	
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
104	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	100	805440	
105	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	105	1615680	
106	Madhumati 100 MW PP	IPP	100 MW	105	88	1659168	Engine problem
Khulna Area Total				2314	1764	36568816	
107	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	953280	
108	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve
109	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	37	735958	
110	Bhola 225 MW CCPP	PDB	2*63+1*68	194	180	4367695	
111	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	95	2313868	
Barisal Area Total				462	423	8370801	
112	Baghabari 71 MW GTTP	PDB	1*71	71	55	1325000	
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
113	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	43	189216	
114	Bera 70 MW Peaking PP	PDB	9*8.26	71	0	62946	
115	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50	50	460360	
116	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	42	584718	Engine problem
117	Katakhal 50 MW Peaking PP	PDB	8*8.7	50	47	187410	
118	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	181	4736927	FGMO
119	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220			