

**EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Date : **6-Sep-19**

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	73	1596000	
	Ghorasal Repowered CCGP Unit-3	PDB	1*210	170	0	0	Gas shortage
	Ghorasal Repowered CCGP Unit-4	PDB	1*210	180	230	5104000	
	Ghorasal TPP Unit-5	PDB	1*210	190	190	4536000	
2	Ghorasal 365 MW CCGP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	70	1172864	Engine problem
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	94	1537863	Engine problem
5	Haripur G1PP	SBU, PDB	2*32	40	0	0	Engine problem
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	362	8604670	FGMO
7	Haripur 360MW CCGP(HPL)	IPP	1*235+1*125	360	350	7278500	
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	420	7867000	Gas shortage
9	Meghnaghat 100 MW (IEL)	QRPP	12*8.9	100	50	460800	Low demand
10	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	150	3077818	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	0	80712	Reserve
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	30	273058	High voltage
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	0	101095	Reserve
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	354204	
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Gas shortage
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
	Siddhirganj Desh	QRPP	96*1.2	0	0	0	Contract Expired
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	0	15360	Reserve
18	Siddhirganj 335 MW CCGP	EGCB	1*217	217	334	5265548	
19	Papia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gaganagar 102 MW PP (Digital Po)	IPP	12*8.924	102	48	676800	Low demand
21	Katpochi 52 MW PP (Sinha)	IPP	7*7.9	51	47	619632	
22	Karnalaghat 54 MW PP(Banco En)	IPP	3*18	54	53	974520	
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	133	1967040	Engine problem
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	814238	
25	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	789703	
26	Bosila 108MW PP(ELC)	IPP	12*8.775+1*3.5	108	72	1235520	Engine problem
27	Summit Power (Madhabadi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	50	1135860	Engine problem
28	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	791400	
29	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	28	794000	
30	Gazipur 52 MW PP	IPP	6*8.9	52	43	1031508	Engine problem
31	Tongi 90 MW GTTP	IPP	1*105	105	0	0	Gas shortage
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	15	301090	Low demand
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	45861	Reserve
34	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	0	0	Reserve
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	115	1306080	Engine problem
	Gazipur 100 MW PP	RPCL	100 MW	105	70	1535568	Engine problem
<b>Dhaka area Total</b>				<b>5693</b>	<b>3191</b>	<b>61335312</b>	
37	Chattoogram TPP-1	PDB	1*210	180	95	2200000	Gas shortage
	Chattoogram TPP-2	PDB	1*210	180	120	2900000	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	25	255742	
39	Teknaf 20MW PP (Solartech)Tefnaf Solartech Energy		20	20	0	69525	
40	Patenga 50MW PP (Baraka)	IPP	6*6.98	50	50	801600	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	210	4396205	
42	Sikalbaha 228MW	PDB	1*150+1*175	225	203	4752559	
43	Sikalbaha Peaking GT	PDB	1*150	150	130	2831964	FGMO
44	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+1*3+1*11.5	0	0	0	Contract Expired
45	Sikalbaha 105 MW PP (Baraka Sil)	IPP	105 MW	105	17	490106	Transformer overload.
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	51512	
47	Dohazari -Kalash 100 MW Peakin	PDB	6*17	102	51	334238	
48	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	10	287880	Line O/L
49	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1560960	
50	Barabankunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	518208	
	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	40	959360	
51	Chattoogram 108 MW PP (ECPV)	IPP	16*7	108	51	457920	Line O/L
52	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	37320	
53	Anwara 300 MW PP (United)	IPP	300 MW	300	106	2075018	Transformer overload.
54	Jodac Power	IPP	3*18.55+1*3.6	54	54	1183098	
	Kanapathuli Power Ltd	IPP	1*10	17	17	440781	
<b>Chattoogram area Total</b>				<b>2166</b>	<b>1301</b>	<b>26603976</b>	
55	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	100	2444392	Gas shortage
56	Ashuganj 225 MW CCGP	APSCL	1*142+1*75	221	216	3717000	
57	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	335	7859000	FGMO
58	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	315	7268500	Engine problem
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	30	670320	Engine problem
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	46	1166880	
61	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
62	Ashuganj 195MW PP (APSCL-Ur)	IPP	20*9.73+1*16	195	16	1137454	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	734228	Engine problem
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	80	324509	Transformer overload.
65	B Bara (Aggreko)	QRPP	86*1.10	85	0	0	Contract Expired
66	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve
67	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	0	247370	Under maint.
68	Chandpur 200MW (Desh energy)	IPP	0	200	200	2731680	
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	498096	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	196560	
**	Imoport (Tripura)	Imported power	0	160	174	3574080	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	0	544100	Engine problem
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	812141	
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	0	441830	Engine problem
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1639</b>	<b>34368140</b>	
75	RPCL 210MW CCGP	IPP	4*35+1*70	202	152	3543880	Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	469872	
77	Fariapur 95 MW PP(Powerpac)	IPP	12*8.924	95	95	1860480	
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12400	
79	Mymensingh 200 MW PP (United)	IPP	200	200	190	2114400	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2652000	
<b>Mymensingh Area Total</b>				<b>637</b>	<b>552</b>	<b>10653032</b>	
81	Fenchuganj CCGP Phase-1	PDB	2*32+1*33	70	60	1410000	
82	Fenchuganj CCGP Phase-2	PDB	2*35+1*35	90	42	925440	
83	Kushiara 163 MW CCGP (KP)	IPP	1*109+1*54	163	163	3059460	
84	Shajibazar 330 MW CCGP	PDB	3*110	330	242	5465000	GT-2 under maint.
85	Fenchuganj 51 MW PP (Barakati)	RPP	19*2.90	51	50	813600	
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	45	838152	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	264000	
88	Shajibazar G1PP Unit- 8 & 9	PDB	2*35	66	65	1568480	FGMO
89	Shajibazar 86MW PP (Shajibaz)	RPP	32*2.90	86	75	1306580	Engine problem
90	Shajibazar 66MW PP (EPL)	RPP	27*2.0	46	0	837360	Engine problem
91	Sylhet 150 MW CCGP	PDB	1*142	142	0	0	Under maint.
92	Sylhet 20 MW GTTP	PDB	1*20	20	18	431000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	45	873320	Engine problem
94	Shahjanulla 25 MW PP	SIPP, REB	3*9.34	25	24	570624	
95	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	310	7188700	FGMO
96	Bibiana-III 400 MW CCGP	PDB	285 MW	285	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	250740	
<b>Sylhet Area Total</b>				<b>1834</b>	<b>1206</b>	<b>25802436</b>	
98	Bheramara GTPP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	910	21847272	
	Khulna 115 MW PP (KPCL-1 & 2)	IPP	19*6.5	0	0	0	Contract Expired
99	Khulna 115 MW PP (KPCL-2)	QRPP	7*17	115	115	1105820	
100	Fariapur 50 MW Peaking PP	PDB	8*6.89	54	31	242400	
101	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	0	0	Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	100	55	422144	
103	Bheramara 360 MW CCGP	NWPGCL	1*278+1*132	410	410	8191584	
104	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	40	366750	
	Khulna (Aggreko) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
105	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	100	473280	
106	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	1726080	
107	Madhumati 100 MW PP	IPP	100 MW	105	103	1797840	
<b>Khulna Area Total</b>				<b>2314</b>	<b>1869</b>	<b>36173270</b>	
108	Barisal 110 MW PP (Summit )	IPP	7*17.076	110	110	908160	
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	38	675256	
111	Bhola 225 MW CCGP	PDB	2*63+1*68	194	180	4274770	
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	95	2133364	
<b>Barisal Area Total</b>				<b>462</b>	<b>423</b>	<b>7991550</b>	
113	Baghabari 71 MW GTTP	PDB	1*71	60	60	1370000	
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	288620	
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	35	130834	
116	Ammura 50 MW PP(Sinha)	QRPP	7*7.79	50	6	161400	Engine problem
117	Katakhalai 50 MW PP (Northern)	QRPP	6*8.9	50	42	792833	Engine problem
118	Katakhalai 50 MW Peaking PP	PDB	6*8.7	50	42	443100	
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	205	4783264	FGMO
120	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	0	0	Gas shortage
121	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	205	4806000	FGMO
122	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1*282+1*132	414	94	5603636	Synchronized at 19:02.
123	Santanar 50 MW Peaking PP	PDB	6*8.7	50	20	174076	
124	Bojra 22 MW PP (SBB)	RPP	6*4	22	22	589040	
125	Bojra 20 MW PP (Energyprima)	RPP	5*3.3+5*2	10	7	156872	Engine problem
126	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	212652	
127	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	998240	
128	Chapainawabganj 100 MW Peakin	PDB	12*8.924	104	95	702320	
129	Baghabari 200 MW PP (Paramou	IPP	200 MW	200	0	0	Reserve
130	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	113	2080992	
<b>Rajshahi Area Total</b>				<b>2070</b>	<b>1059</b>	<b>23213679</b>	
131	Barapukuria TPP Unit-1	PDB	1*125	85	68	1515490	
	Barapukuria TPP Unit-2	PDB	1*125	85	0	0	Under maint.
132	Barapukuria 275 MW TPP Unit-3	PDB	1*275	274	260	6445600	
133	Rangpur 20 MW GTTP	PDB	1*20	20	0	0	Under maint.
134	Saidpur 20 MW GTTP	PDB	1*20	20	0	0	
135	Rangpur 113 MW PP (Confidence)	IPP	113 MW	113	106	1560960	
	Sympa Solar Power 8MW	IPP	8 MW	8	0		