

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	73	1578000	
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	218	5356600	
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	310	6874709	Frequency control
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur GTPP	SBU, PDB	2*32	40	0	0	Engine problem
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	355	506610	FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	352	7239000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	370	8581500	Gas shortage
9	Meghnaghat 100 MW (IEL)	QRPP	12*8.9	100	50	136320	Low demand
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	150	3358167	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	15	50424	Low demand
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	25	56957	Low demand
13	Keraniganj 100 MW PP (Powerpal)	QRPP	8*13.45	100	10	63153	Low demand
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	368748	
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Gas shortage
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
	Siddhirganj Desh	QRPP	96*1.2	0	0	0	Contract Expired
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	50	92160	Low demand
18	Siddhirganj 335 MW CCPP	EGCB	1*217	217	0	1378960	
19	Papia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gaganagar 102 MW PP (Digital Po)	IPP	12*8.924	102	58	520560	Low demand
21	Katpochi 52 MW PP (Sinha)	IPP	7*7.9	51	6	351312	Low demand
22	Karnalaghat 54 MW PP(Banco En)	IPP	3*18	54	53	896400	
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	149	1481280	
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	458964	
25	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	621346	
26	Bosila 108MW PP(ELC)	IPP	12*8.775+1*3.5	108	69	1048320	Engine problem
27	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	50	1264380	Engine problem
28	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	812700	
29	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	777500	
30	Gazipur 52 MW PP	IPP	6*8.9	52	43	669900	Engine problem
31	Tongi 90 MW GTTP	IPP	1*105	105	0	0	Gas shortage
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	95	150545	Low demand
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve
34	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	0	0	Reserve
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	119	506880	Machine problem
	Gazipur 100 MW PP	RPCL	100 MW	105	105	1866168	
Dhaka area Total				5693	2917	51620563	
37	Chattoogram TPP-1	PDB	1*210	180	75	1800000	Gas shortage
	Chattoogram TPP-2	PDB	1*210	180	0	0	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	25	163508	
39	Teknaf 20MW PP (Solartech)Teknaf Solartech Energy	IPP	20	20	0	82215	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	46	850080	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	177	3822440	
42	Sikalbaha 228MW	PDB	1*150+1*175	225	204	4978446	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	130	2706668	
44	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	0	0	0	Contract Expired
45	Sikalbaha 105 MW PP (Baraka Sil)	IPP	105 MW	105	17	124617	Low demand
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Reserve
47	Dohazari -Kalash 100 MW Peakin	PDB	6*17	102	68	346911	
48	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	10	158640	Transformer overload.
49	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1731840	
50	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	16	365712	
	* Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	25	539520	
51	Chattoogram 108 MW PP (ECPV)	IPP	16*7	108	48	205060	Low demand
52	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	0	
53	Anwara 300 MW PP (United)	IPP	300 MW	300	106	2155309	Transformer overload.
54	Jodioc Power	IPP	3*18.55+1*3.6	54	52	459107	
	Kanapathuli Power Ltd	IPP	1*10	17	17	118783	Transformer overload.
Chattoogram area Total				2166	1116	20654336	
55	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	100	2183924	Gas shortage
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	181	4442000	FGMO
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	300	8205300	FGMO
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	270	7345500	FGMO
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	27	591840	Engine problem
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	54	684480	
61	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
62	Ashuganj 195MW PP (APSCL-Ur)	IPP	20*9.73+1*16	195	8	217454	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	693840	Transformer overload.
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	63	187346	Transformer overload.
65	B Bara (Aggreko)	QRPP	86*1.10	85	0	0	Contract Expired
66	Titas 50 MW Peaking PP	PDB	6*8.92	50	0	0	Reserve
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	95	1458310	
68	Chandpur 200MW (Desh energy)	IPP	0	200	145	2018400	Machine problem
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	497484	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	5	160560	
**	Impoort (Tripura)	Imported power	0	160	160	3163200	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	539000	
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	45	437693	
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	462950	
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1563	33289281	
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	109	2517960	Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	478440	
77	Fariapur 95 MW PP(Powerpac)	IPP	12*8.924	95	91	718980	
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12150	
79	Mymensingh 200 MW PP (United)	IPP	200	200	140	1015200	Line O/L
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2018400	
Mymensingh Area Total				637	477	6760230	
81	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	60	1421000	
82	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	41	984000	
83	Kushiara 163 MW CCPP (KP)	IPP	1*109+1*54	163	130	3136803	Low demand
84	Shajibazar 330 MW CCPP	PDB	3*110	330	192	4223000	FGMO
85	Fenchugonj 51 MW PP (Barakati)	RPP	19*2.90	51	50	802800	
86	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	46	813384	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	8	198000	Engine problem
88	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	67	1601856	FGMO
89	Shajibazar 85MW PP (Shajibaz)	RPP	32*2.90	86	78	1133760	
90	Shajibazar 50MW PP (EPL)	RPP	27*2.0	50	47	822960	
91	Sylhet 150 MW CCPP	PDB	1*142	142	85	2199500	FGMO
92	Sylhet 20 MW GTTP	PDB	1*20	20	18	444000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	45	774380	Engine problem
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	529728	
95	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	265	7351250	FGMO
96	Bibiana-III 400 MW CCPP	PDB	285 MW	285	428	10213000	
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	251460	
Sylhet Area Total				1834	1594	36900881	
98	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	915	21979718	
99	Khulna 115 MW PP (KPCL-1 & 2)	IPP	19*6.5	0	0	0	Contract Expired
100	Khulna 115 MW PP (KPCL-2)	IPP	7*17	115	83	381120	
101	Fariapur 50 MW Peaking PP	PDB	8*6.89	54	45	208880	
102	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve
103	Gopalganj 100 MW Peaking PP	PDB	16*6.98	100	55	124900	
104	Bheramara 360 MW CCPP	NWPGCL	1*278+1*132	410	300	7851168	Frequency control
105	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	40	198750	
	Khulna (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
106	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	0	864	Reserve
107	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	53	403200	Low demand
108	Madhumati 100 MW PP	IPP	100 MW	105	85	761472	Engine problem
Khulna Area Total				2314	1576	31726072	
109	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	64	190368	Low demand
110	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve
111	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	28	582857	
112	Bhola 225 MW CCPP	PDB	2*63+1*68	194	116	3128000	
113	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	95	1684548	
Barisal Area Total				462	303	5565773	
114	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
115	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under shut down.
116	Baghabari 50 MW Peaking PP	PDB	6*8.9	50	50	75653	
117	Bera 70 MW Peaking PP	PDB	9*8.29	71	38	89723	
118	Amnura 50 MW PP(Sinha)	QRPP	7*7.9	50	18	199120	Engine problem
119	Katakhalai 50 MW PP (Northern)	QRPP	6*8.9	50	42	199237	Engine problem
120	Katakhalai 50 MW Peaking PP	PDB	6*8.7	50	43	104060	
121	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	173	4532818	FGMO
122	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220			