

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Generation		Remarks
						MW	MW	
<b>Unit No. X Capacity</b>								
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	73	1566000		
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	158	4319900		Gas shortage
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0		Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0		Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	300	7049555		Frequency control
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0		Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0		Gas shortage
5	Haripur GTPP	SBU, PDB	2*32	40	0	0		Engine problem
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	348	8321030		FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	314	7247000		Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	350	8797250		Gas shortage
9	Meghnaghat 100 MW (IEL)	QRPP	12*8.9	100	0	30720		Reserve
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	120	3309324		Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	15	90600		Low demand
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	0	33891		Reserve
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	0	10743		Reserve
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	395892		Engine problem
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0		Gas shortage
16	Siddhirganj 2*120 MW GTPP	EGCB	2*105	210	0	0		Gas shortage
	Siddhirganj Desh	QRPP	96*1.2	0	0	0		Contract Expired
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	0	5760		Reserve
18	Siddhirganj 335 MW CCPP	EGCB	1*217	217	0	0		
19	Papia (DPA)	QRPP	100*0.5	0	0	0		Contract Expired
20	Paipara 102 MW PP (Digital Po)	IPP	12*8.924	102	0	37008		Reserve
21	Katpochi 52 MW PP (Sinha)	IPP	7*7.9	51	22	359952		Low demand
22	Karnalaghat 54 MW PP(Banco En)	IPP	3*18	54	53	839880		
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	25	98880		Low demand
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	17	240669		Low demand
25	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	17	479688		Low demand
26	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	70	794880		Engine problem
27	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	56	1190400		Engine problem
28	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	808400		
29	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	28	755000		
30	Gazipur 52 MW PP	IPP	6*8.9	52	34	351264		Engine problem
31	Tongi 90 MW GTPP	IPP	1*105	105	0	0		Gas shortage
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	0	52891		Reserve
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0		Reserve
34	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	0	0		Reserve
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0		Reserve
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	136	813600		Machine problem
	Gazipur 100 MW PP	RPCL	100 MW	105	105	1975788		
<b>Dhaka area Total</b>				<b>5693</b>	<b>2290</b>	<b>49975765</b>		
37	Chattogram TPP-1	PDB	1*210	180	75	1800000		Gas shortage
	Chattogram TPP-2	PDB	1*210	180	0	0		Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	25	175954		
39	Teknaf 20MW PP (Solartech)Teknaf Solartech Energy			20	0	78975		
40	Patenga 50MW PP (Baraka)	IPP	6*6.98	50	50	576000		
41	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	211	4499224		
42	Sikalbaha 225MW	PDB	1*150+1*175	225	204	4749178		FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	100	2704504		
44	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	0	0	0		Contract Expired
45	Sikalbaha 105 MW PP (Baraka Sil)	IPP	105 MW	105	0	0		Reserve
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0		Reserve
47	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	68	260415		
48	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	10	153720		Transformer overload.
49	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1309440		
50	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	18	388944		
	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	42	853440		
51	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	12	92160		Low demand
52	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	0		
53	Anwara 300 MW PP (United)	IPP	300 MW	300	143	2338473		Transformer overload.
54	Jodac Power	IPP	3*18.55+1*3.6	54	17	227081		Low demand
	Kanapathuli Power Ltd	IPP	110	0	0	20909		Transformer overload.
<b>Chattogram area Total</b>				<b>2166</b>	<b>1076</b>	<b>2023217</b>		
55	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0		Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0		Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	100	2394302		Gas shortage
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	0	231000		Under maint.
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	260	7490500		FGMO
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	265	6784000		FGMO
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	27	612648		Engine problem
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	55	1143360		
61	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0		Contract Expired
62	Ashuganj 195MW PP (APSCL-Ur)	IPP	20*9.73+1*16	195	16	451636		Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	589854		Transformer overload.
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	0	153890		Transformer overload.
65	B Bara (Aggreko)	QRPP	86*1.10	85	0	0		Contract Expired
66	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	39840		Reserve
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	100	2043730		
68	Chandpur 200MW (Desh energy)	IPP	0	200	181	2460000		Machine problem
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	422388		
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	149220		
**	Impoport (Tripura)	Imported power	0	160	166	3148800		
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	725600		
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	8	198010		Low demand
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	486330		
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0		Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1296</b>	<b>29525108</b>		
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	158	2819000		Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	509112		
77	Tangail 95 MW PP(Powerpac)	IPP	12*8.924	95	99	1621440		
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	14300		
79	Mymensingh 200 MW PP (United)	IPP	200	200	147	1406400		Low demand
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	107	2232000		
<b>Mymensingh Area Total</b>				<b>637</b>	<b>524</b>	<b>8602252</b>		
81	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	60	1422000		
82	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	30	759600		
83	Kushiara 163 MW CCPP (KP)	IPP	1*109+1*54	163	100	2996607		Frequency control
84	Shajibazar 330 MW CCPP	PDB	3*110	330	191	4162000		FGMO
85	Fenchugonj 51 MW PP (Barakati)	RPP	19*2.90	51	42	900600		
86	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	49	1042488		
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	8	198000		Engine problem
88	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	65	1515168		FGMO
89	Shajibazar 85MW PP (Shajibaz)	RPP	32*2.90	86	78	1408320		
90	Shajibazar 50MW PP (EPL)	RPP	27*0.2	47	0	960120		
91	Sylhet 150 MW CCPP	PDB	1*142	142	110	2226830		FGMO
92	Sylhet 20 MW GTTP	PDB	1*20	20	17	444000		
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	45	895060		Engine problem
94	Shahjanulla 25 MW PP	SIPP, REB	3*9.34	25	24	579408		
95	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	275	7125250		FGMO
96	Bibiana-III 400 MW CCPP	PDB	285 MW	285	425	10197000		
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	171540		
<b>Sylhet Area Total</b>				<b>1834</b>	<b>1576</b>	<b>37003991</b>		
98	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0		Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	921	12866909		
99	Khulna 115 MW PP (KPCL-1 & 2)	IPP	19*6.5	0	0	0		Contract Expired
100	Khulna 115 MW PP (KPCL-2)	QRPP	7*17	115	99	767040		Engine problem
101	Fariapur 50 MW Peaking PP	PDB	8*6.89	54	38	252960		
102	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0		Reserve
103	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	75	435712		
104	Bheramara 360 MW CCPP	NWPGCL	1*278+1*132	410	300	8830368		Frequency control
105	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	40	242625		
	Khulna (Aggreco) 55MW	QRPP	7*10.85	0	0	0		Contract Expired
106	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	0	36480		Reserve
107	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	70	817440		Low demand
	Madhumati 100 MW PP	IPP	100 MW	105	86	945216		Engine problem
<b>Khulna Area Total</b>				<b>2314</b>	<b>1629</b>	<b>25194750</b>		
108	Barisal 110 MW PP (Summit )	IPP	7*17.076	110	64	316992		Low demand
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0		Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	36	622733		
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	150	3184630		
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	97	1651810		
<b>Barisal Area Total</b>				<b>462</b>	<b>347</b>	<b>5776165</b>		
113	Baghabari 71 MW GTTP	PDB	1*71	0	0	0		Gas shortage