

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	36	827000	#1 under maint.
	Ghorasal Repowered CCGP Unit-3	PDB	1*210	170	198	4549200	
	Ghorasal Repowered CCGP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCGP Unit-7	QRPP	1*243+1*122	365	330	8609827	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	2*40	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	3*43.35	108	0	0	Gas shortage
5	Haripur GTPP	SBU, PDB	2*2	40	0	0	Engine problem
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	348	8583790	FGMO
7	Haripur 360MW CCGP(HPL)	IPP	1*235+1*125	360	304	8011000	
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	0	61500	Under maint.
9	Meghnaghat 100 MW (IEL)	QRPP	12*8.9	100	100	388900	
10	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	150	3532131	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	100	2073792	
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	797684	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	40	216658	Low demand
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	369900	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Gas shortage
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	36	900000	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	90	701760	Engine problem
18	Siddhirgonj 335 MW CCGP	EGCB	1*217+118	335	2	38890	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	101	750816	
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	24	197136	Engine problem
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	53	803160	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	149	583200	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	773318	Engine problem
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	900124	
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	69	1321920	Engine problem
26	Summit Power, (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	53	1232880	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	708900	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	700100	
29	Sasipur 52 MW PP	IPP	6*8.9	52	43	469860	Engine problem
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	1595781	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	87321	Reserve
33	Bramhangonj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve
34	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3191040	
36	Gazipur 100 MW PP	RPCL	100 MW PP	105	105	1036848	
<b>Dhaka area Total</b>				<b>5811</b>	<b>3010</b>	<b>54014336</b>	
37	Chattogram TPP-1	PDB	1*210	180	75	1700000	Gas shortage
38	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
39	Razcan 25 MW PP	IPP	3*8.9	25	25	234124	Low demand
40	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	8235	
41	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	47	610560	
42	Kapali Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	137	4071945	
43	Sikalbaha 225MW	PDB	1*150+1*175	225	216	4886604	FGMO
44	Sikalbaha Peaking GT	PDB	1*150	150	135	3027454	
45	Sikalbaha 105 MW PP (Baraka Sikalba)	IPP	105 MW	105	17	113744	Low demand
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D.
47	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	85	398397	
48	Juidah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	100	1046040	
49	Juidah 100 MW PP Unit-3 (Acom)	IPP	0	100	100	1932480	
50	Arabakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	16	260400	Engine problem
51	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	14	553440	
52	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	97	2249280	Engine problem
53	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	25680	
54	Anwara 300 MW PP (United)	IPP	300 MW	300	142	4077272	Low demand
55	Jodiac Power	IPP	3*18.55+1*3.6	54	17	123769	Low demand
56	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve
<b>Chattogram area Total</b>				<b>2166</b>	<b>1223</b>	<b>25319424</b>	
57	Ashuganj TPP Unit- 3	APSCCL	1*150	135	0	0	Gas shortage
58	Ashuganj TPP Unit- 4	APSCCL	1*150	129	0	0	Gas shortage
59	Ashuganj TPP Unit- 5	APSCCL	1*150	134	100	2404320	
60	Ashuganj 225 MW CCGP	APSCCL	1*142+1*75	221	199	4707000	FGMO
61	Ashuganj 450 MW CCGP(North)	APSCCL	1*360	360	360	8223000	FGMO
62	Ashuganj 450 MW CCGP(South)	APSCCL	1*360	360	305	7135000	FGMO
63	Ashuganj 50 MW PP	APSCCL	14*3.968	45	23	519912	Engine problem
64	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	53	1281600	
65	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
66	Ashuganj 195MW PP (APSCCL-United)	IPP	20*9.73+1*16	195	83	2007722	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	824396	Engine problem
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	150	1057163	
69	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
70	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve
71	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	51	1193340	
72	Chandpur 200MW (Desh energy)	IPP	0	200	200	3594240	
73	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	447912	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	168840	
75	Impoort (Tripura)	Imported power	0	160	140	2952000	
76	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	817100	
77	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	303662	
78	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	14	332670	Engine problem
79	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1628</b>	<b>37969427</b>	
80	RPCL 210MW CCGP	IPP	4*35+1*70	202	146	4059720	
81	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	521316	
82	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	95	2145600	
83	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	10650	
84	Mymensingh 200 MW PP (United)	IPP	200	200	180	1365600	Low demand
85	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1492800	
<b>Mymensingh Area Total</b>				<b>637</b>	<b>558</b>	<b>9595860</b>	
86	Fenchuganj CCGP Phase-1	PDB	2*32+1*33	70	60	1429000	
87	Fenchuganj CCGP Phase-2	PDB	2*35+1*35	90	30	687900	
88	Kushaura 163 MW CCGP (KP)	IPP	1*109+1*54	163	130	3099919	Frequency control.
89	Shahbazar 330 MW CCGP	PDB	3*110	330	140	4060000	ST under S/D
90	Fenchuganj 51 MW PP (Barakatalullah)	RPP	19*2.90	51	53	931800	
91	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	46	1111752	
92	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	231120	
93	Shahbazar GTTP Unit- 8 & 9	PDB	2*35	66	65	1587840	FGMO
94	Shahbazar 86MW PP (Shahbazar)	RPP	32*2.90	86	76	1223040	
95	Shahbazar 50MW PP (EPL)	RPP	27*2.0	50	46	1027440	
96	Syhet 150 MW CCGP	PDB	1*142	142	115	2256630	FGMO
97	Syhet 20 MW GTTP	PDB	1*20	20	17	441000	
98	Syhet 50MW PP (EPL)	RPP	27*2	50	43	969400	Engine problem
99	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	577872	
100	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	320	7570500	FGMO
101	Bibiana-III 400 MW CCGP	PDB	400 MW	400	0	0	Under S/D
102	Syhet 10MW PP (Desh)	RPP	6*1.95	10	10	229140	
<b>Syhet Area Total</b>				<b>1949</b>	<b>1186</b>	<b>27434053</b>	
103	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
104	Bheramara (HVDC )	Imported power	2*500	1000	718	21161454	
105	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	831360	
106	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	27	238560	
107	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	0	0	Reserve
108	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	65	159424	
109	Bheramara 360 MW CCGP	NWPGCL	1*278+1*132	410	355	8229600	Frequency control.
110	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	40	348375	
111	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	20	65280	Low demand
112	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	105	1344480	
113	Madhumati 100 MW PP	IPP	100 MW	105	67	943776	Low demand
<b>Khulna Area Total</b>				<b>2314</b>	<b>1512</b>	<b>33322309</b>	
114	Barisal 110 MW PP (Summit )	IPP	7*17.076	110	64	904704	Low demand
115	Barisal GT PP Unit-1&2	PDB	2*20	30	0	0	Reserve
116	Bhida 33 MW PP (Venture)	RPP	1*34.50	33	31	557520	
117	Bhida 225 MW CCGP	PDB	2*63+1*68	194	159	4061016	
118	Bhida 95 MW PP (Aggreko)	QRPP	96*1.10	95	97	1831988	
<b>Barisal Area Total</b>				<b>462</b>	<b>351</b>	<b>7355228</b>	
119	Baghabari 71 MW GTTP	PDB	1*71	71	60	1390000	
120	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under shut down.
121	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	40	242137	
122	Bera 70 MW Peaking PP	PDB	9*8.29	71	39	33562	
123	Amnura 50 MW PP(Sinha)	QRPP	7*7.9	50	18	212340	Engine problem
124	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	50	468596	
125	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	46	144636	
126	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	186	4532463	FGMO
127	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	190	4346864	FGMO
128	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	86	890745	Gas shortage
129	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1*282+1*132	414	398	9340091	
130	Santahar 50 MW Peaking PP	PDB	6*8.7	50	30	140201	