

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	32	680000	#1 under maint.
	Ghorasal Repowered CCGP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCGP Unit-4	PDB	1*210	180	150	3693000	Gas shortage
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCGP Unit-7	PDB	1*243+1*122	365	340	8607627	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	3*43.35	108	0	0	Gas shortage
5	Haripur GTPP	SBU, PDB	2*32	40	0	0	Engine problem
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	349	8785110	FGMO
7	Haripur 360MW CCGP(HPL)	IPP	1*235+1*125	360	353	8202000	
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	450	7500000	
9	Meghnaghat 100 MW(EL)	QRPP	12*8.9	100	100	239040	
10	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	96	1823808	
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	53	659691	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	95	156684	
14	Narshingdi 22 MW PP (Doreen)	SIIPP, REB	8*2.90	22	22	455904	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Gas shortage
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	1364000	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	90	918800	
18	Siddhirgonj 335 MW CCGP	EGCB	1*217+118	335	0	180926	GT sync at 18.52 & ST under maint.
19	Gaganraj 102 MW PP (Digital Power)	IPP	12*8.924	102	58	170928	Low demand
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	47	110064	Engine problem
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	53	754920	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	0	390720	Reserve
23	Maniganj 55 MW PP (Northern)	IPP	3*19.3	55	55	543446	
24	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	592555	
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	62	847860	Engine problem
26	Summit Power (Madhabdi+Ashulia)	SIIPP, REB	3*3.67+4*8.73	80	55	1263120	Engine problem
27	Maona 33 MW PP(Summit)	SIIPP, REB	4*8.73	33	25	737100	
28	Rangpur 33 MW PP(Summit)	SIIPP, REB	4*8.73	33	33	784600	
29	Gazipur 52 MW PP	IPP	8*9.9	52	35	219480	Engine problem
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	189	1364000	Low demand
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	120255	Reserve
33	Branhanganj 100 MW PP (Aggreko)	IPP	100	100	0	20171	Reserve
34	Aurahi 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	24309	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3002400	
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	1510224	
<b>Dhaka area Total</b>				<b>5811</b>	<b>3051</b>	<b>5772052</b>	
37	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
	Chattogram TPP-2	PDB	1*210	180	120	2900000	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	25	135245	
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy L	20	20	0	140535	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	405600	
41	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	92	2082240	Low water level
42	Sikalbaha 225MW	PDB	1*150+1*175	225	205	4936832	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	135	3069207	FGMO
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	0	0	Transformer & Line overload
45	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D.
46	Dohazari -Kalaiash 100 MW Peaking	PDB	8*13.45	102	85	465874	
47	Juldah 100 MW Unit-1 (Acorn)	QRPP	6*17.076	100	100	1162080	
48	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1728960	
49	Barakunda 22 MW PP (Regent)	SIIPP, PDB	8*2.90	22	19	437372	Engine problem
	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	4	482480	
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	97	1734720	Engine problem
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	0	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	133	1435200	Transformer & Line overload
53	Jodiak Power	IPP	3*18.55+1*3.6	54	0	0	Transformer & Line overload
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Transformer & Line overload
<b>Chattogram area Total</b>				<b>2166</b>	<b>1165</b>	<b>21126345</b>	
55	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	100	2544572	Gas shortage
56	Ashuganj 225 MW CCGP	APSCL	1*142+1*75	221	217	4729000	FGMO
57	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	320	8431000	FGMO
58	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	260	7536000	FGMO
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	20	444960	Engine problem
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	52	1290240	
	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
62	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	55	1338181	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	28	672208	Low demand
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	0	0	Transformer overload
	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
66	Tilas 50 MW Peaking PP	PDB	6*8.92	52	0	0	
67	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	141	2802660	Machine problem
68	Chandpur 200MW (Desh energy)	IPP	0	200	200	3052320	
69	Feni 22MW PP (Doreen)	SIIPP, PDB	8*2.90	22	22	482436	
70	Feni 11 MW PP (Doreen)	SIIPP, REB	4*2.90	11	8	209520	
**	Impoport (Tripura)	Imported power	0	160	170	3279360	
71	Jangalia 33MW PP (Summit)	SIIPP, PDB	4*8.73	33	33	624200	
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	43	104419	Engine problem
73	Cumilla 25 MW PP (Summit)	SIIPP, PDB	3*3.67+2*6.97	25	21	483950	
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1690</b>	<b>38025026</b>	
75	RPCL 210MW CCGP	IPP	4*35+1*70	202	140	3716800	Gas shortage
76	Tangail 22 MW PP (Doreen)	SIIPP, PDB	8*2.90	22	20	454140	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	95	1580160	
78	Sanshabani 3 MW Solar Plant	IPP	1*3	3	0	0	
79	Mymensingh 200 MW PP (United)	IPP	200	200	136	804000	High Voltage
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1180800	
<b>Mymensingh Area Total</b>				<b>637</b>	<b>506</b>	<b>7735900</b>	
81	Fenchuganj CCGP Phase-1	PDB	2*32+1*33	70	60	1426000	
82	Fenchuganj CCGP Phase-2	PDB	2*35+1*35	90	62	1292840	
83	Kushiana 103 MW CCGP (KP)	IPP	1*109+1*54	163	100	3146400	Frequency control
84	Shahjibazar 330 MW CCGP	PDB	3*110	330	152	3473000	GT-1 under S/D
85	Fenchuganj 51 MW PP (Barakattullah)	RPP	19*2.90	51	50	871800	
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	49	991944	
87	Hobiganj 11MW PP Confidence-E	SIIPP, REB	4*2.90	11	11	264000	
88	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	67	1526088	FGMO
89	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	80	1489920	
90	Shahjibazar 50MW PP (EPL)	RPP	27*2.0	50	40	827280	Engine problem
91	Sylhet 150 MW CCGP	PDB	1*142	142	108	2412180	FGMO
92	Sylhet 20 MW GTPP	PDB	1*20	20	0	0	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	44	986360	Engine problem
94	Shahjahanulla 25 MW PP	SIIPP, REB	3*9.34	25	24	567744	
95	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	275	7483800	FGMO
96	Bibiana-III 400 MW CCGP	PDB	400 MW	400	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	250020	
<b>Sylhet Area Total</b>				<b>1949</b>	<b>1132</b>	<b>27015776</b>	
98	Bheramara GTPP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	906	21551273	
99	Khulina 115 PP MW (KPCL-2)	QRPP	7*17	115	115	426240	
100	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	45	212640	
101	Khulina 225 MW CCGP	NWPGCL	1*150+1*75	230	0	0	Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	22	122040	
103	Bheramara 360 MW CCGP	NWPGCL	1*278+1*132	410	340	8980704	FGMO
104	Noapara 40 MW PP (Khanjahan Ali)	QRPP	9*8.5	40	40	252375	
105	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	24	48960	Low demand
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	105	760320	
107	Madhumati 100 MW PP	IPP	100 MW	105	102	870048	
<b>Khulina Area Total</b>				<b>2314</b>	<b>1699</b>	<b>33224600</b>	
108	Bansal 110 MW PP (Summit)	IPP	7*17.076	110	48	482880	Low demand
109	Bansal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	30	540744	
111	Bhola 225 MW CCGP	PDB	2*63+1*98	194	166	4212333	FGMO
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	96	1565591	
<b>Bansal Area Total</b>				<b>462</b>	<b>340</b>	<b>6801538</b>	
113	Baghabari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage
	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Under shut down.
114	Baghabari 50 MW Peaking PP	PDB	8*8.9	52	50	261705	
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	40	146780	
116	Amnura 50 MW PP(Sinha)	QRPP	7*7.9	50	50	231390	
117	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	50	420804	
118	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	40	58490	
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	80791	Gas shortage
120	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	194	4251345	FGMO
121	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	204	4976909	FGMO
122	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1*282+1*132	414	398	10071491	FGMO
123	Santaha 50 MW Peaking PP	PDB	6*8.7	50	35	73209	
124	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	425040	
125	Bogra 20 MW PP (Energyprima)	RPP	5*3.3+5*2	10	16	389232	
126	Lilapara 11 MW PP (Summit)	SIIPP, REB	4*2.90	11	11	231444	
127	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	43	628800	Engine problem
128	Chapainawabganj 100 MW Peaking PP	PDB	12*8.94	104	100	214748	
129	Baghabari 200 MW PP (Paramount)	IPP	200 MW	200	0	0	Reserve
130	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	88	435840	Low demand
<b>Rajshahi Area Total</b>				<b>2070</b>	<b>1341</b>	<b>23624308</b>	
131	Barapukuria TPP Unit-1	PDB	1*125	85	0	0	Under maint.
	Barapukuria TPP Unit-2	PDB	1*125	85	0	0	Under maint.
132	Barapukuria 275 MW TPP Unit-3	PDB	1*275	274	280	6796000	
133	Rangpur 20 MW GTPP	PDB	1*20	20	0	0	
134	Saidpur 20 MW GTPP	PDB	1*20	20	15	58000	
135	Rangpur 113 MW PP (Confidence)	IPP	113 MW	113	107	871680	Engine problem
136	Sympa Solar Power 8MW	IPP	8 MW	8	0	44779	
<b>Rangpur Area Total</b>				<b>605</b>	<b>402</b>	<b>7770459</b>	
<b>Total</b>				<b>18905</b>	<b>11326</b>	<b>221044514</b>	
<b>Eastern Grid Total</b>				<b>13454</b>	<b>7544</b>	<b>149823609</b>	
<b>Western Grid Total</b>				<b>5451</b>	<b>3782</b>	<b>71423095</b>	
<b>National Grid Total</b>				<b>18905</b>	<b>11326</b>	<b>221044514&lt;/</b>	