

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
			Unit No. X Capacity	MW	Generation	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	35	757000	#1 under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	200	4754000	
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	350	8290945	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur G1PP	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	351	8636410	FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*236+1*125	360	323	7925000	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	450	9303625	
9	Meghnaghat 100 MW(IEI)	QRPP	12*8.9	100	100	260160	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	97	1701944	
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	883700	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	50	97825	Low demand
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	423396	
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Gas shortage
16	Siddhirganj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirganj 100 PP/Dutch Bangla	QRPP	12*8.9	100	100	959040	
18	Siddhirganj 335 MW CCPP	EGCB	1*217+1*118	335	204	5681629	Gas shortage
19	Gaganagar 102 MW PP (Digital Po	IPP	12*8.924	102	50	180144	Low demand
20	Kapotti 52 MW PP (Sibha)	IPP	7*7.9	52	45	184128	Engine problem
21	Karnalaghat 54 MW PP(Banco En	IPP	3*18	54	53	826560	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	149	777120	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	538978	
24	Nababaganj 55 MW PP (Southern)	IPP	3*19.3	55	55	744493	
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	65	938880	Engine problem
26	Summit Power,(Madhabadi+Ashuldi	SIPP,REB	3*3.67+4*8.73	80	55	1239360	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	768800	
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	800100	
29	Gazipur 52 MW PP	IPP	6*8.9	52	51	626664	
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	298	1071381	
32	Keraniganj 300 MW PP (APPR)	IPP	25*11.4	300	0	0	Reserve
33	Bramhaniganj 100 MW PP (Aggr	IPP	1*100	100	0	0	Reserve
34	Aurashahi 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
35	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	149	3147840	
36	Gazipur 100 MW PP	RPCL	100 MW	105	89	1274220	Engine problem
<b>Dhaka area Total</b>				<b>5811</b>	<b>3517</b>	<b>62793342</b>	
37	Chattogram TPP-1	PDB	1*210	180	80	700000	Gas shortage
	Chattogram TPP-2	PDB	1*210	180	120	2900000	Gas shortage
38	Racozan 25 MW PP	IPP	3*8.9	25	25	85248	
39	Teknaf 20MW PP (Solartech)Teknaf	Solartech Energy	20	20	0	146340	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	427200	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	141	3124731	Low water level
42	Sikalbaha 225MW	PDB	1*150+1*175	225	231	4980922	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	109	2884520	FGMO
44	Sikalbaha 108 MW PP (Baraka St	PDB	105 MW	105	0	0	Transformer & Line overload
45	Hafazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D.
46	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	51	266812	
47	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	100	836400	
48	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1776000	
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	451008	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	6	409920	
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	96	2012160	Engine problem
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	33360	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	145	1570690	Transformer & Line overload
53	Jodiak Power	IPP	3*18.55+1*3.6	54	0	3638	Transformer & Line overload
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Transformer & Line overload
<b>Chattogram area Total</b>				<b>2166</b>	<b>1273</b>	<b>22608949</b>	
55	Ashuganj TPP Unit-3	APSCL	1*150	135	120	2965800	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	180	4523000	FGMO
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	340	7961400	FGMO
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	280	7311500	FGMO
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	27	587160	Engine problem
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	52	1291680	
	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
62	Ashuganj 195MW PP (APSCL-Ur	IPP	20*9.73+1*16	195	55	1321454	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	743664	Engine problem
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	30	399781	Transformer overload
	B.Baria (Aggreko) 85MW	QRPP	8*6.110	85	0	0	Contract Expired
66	Titas 50 MW Peaking PP	PDB	6*6.92	52	25	24784	Low demand
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	140	3306270	
68	Chandpur 200MW (Desh energy)	IPP	0	200	180	2865600	
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	473112	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	187560	Engine problem
**	Impoort (Tripura)	Imported power	0	160	176	3483840	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	818300	
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	48	312274	
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	21	511210	Engine problem
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1772</b>	<b>39090389</b>	
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	102	2772120	Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	459972	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	95	2214720	
78	Sarisahabi 3 MW Solar Plant	IPP	1*3	3	0	11000	
79	Mymensingh 200 MW PP (United	IPP	200	200	150	916800	High Voltage
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	108	1550400	
<b>Mymensingh Area Total</b>				<b>637</b>	<b>476</b>	<b>7925912</b>	
81	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	60	1428000	
82	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	60	1344000	
83	Kushitara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3488326	
84	Shajibazar 330 MW CCPP	PDB	3*110	330	154	3584000	
85	Fenchugonj 51 MW PP (Barakati)	RPP	19*2.90	51	46	817800	
86	Fenchugonj 44MW (Energyprima	RPP	12*3.3+5*2	44	49	922608	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	225984	
88	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	67	1573920	FGMO
89	Shajibazar 86MW PP (Shajibaz	RPP	32*2.90	86	75	1599360	
90	Shajibazar 50MW PP (EPL)	RPP	27*2.0	50	40	839880	Engine problem
91	Sylhet 150 MW CCPP	PDB	1*142	142	70	2035750	
92	Sylhet 20 MW GTTP	PDB	1*20	20	17	442000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	42	848800	Engine problem
94	Shajibazaila 25 MW PP	SIPP, REB	3*9.34	25	24	581568	
95	Bibiana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	290	7374200	FGMO
96	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	244260	
<b>Sylhet Area Total</b>				<b>1949</b>	<b>1178</b>	<b>27386456</b>	
98	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	829	21564363	
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	486720	
100	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	43	239040	
101	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	40	91648	Low demand
103	Bheramara 360 MW CCPP	NWPGCL	1*278+1*132	410	345	8769312	FGMO
104	Noapara 40 MW PP (Karnajahan A	QRPP	5*8.5	40	40	3114200	
105	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	7	18240	Low demand
106	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	910880	
107	Madhumati 100 MW PP	IPP	100 MW	105	103	597312	
<b>Khulna Area Total</b>				<b>2314</b>	<b>1627</b>	<b>32987965</b>	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	1039680	
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	30	530512	Engine problem
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	150	4188078	FGMO
112	Bhola 95 MW PP (Aggreko)	QRPP	9*11.0	95	97	2246682	
<b>Barisal Area Total</b>				<b>462</b>	<b>387</b>	<b>8004952</b>	
113	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under shut down.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	270102	
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	46	105688	
116	Annura 50 MW PP(Sinha)	QRPP	7*7.79	50	50	293970	
117	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	50	852169	
118	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	48	80146	
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
120	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	199	4499373	FGMO
121	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	176	4741736	FGMO
122	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1*282+1*132	414	377	9463454	FGMO
123	Santahar 50 MW Peaking PP	PDB	6*8.7	50	21	110554	Low demand
124	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	513600	
125	Bogura 20 MW PP (Energyprima)						