

Till now the maximum generation is :- **12893 MW** **21:00 Hrs** on **29-May-19** Reporting Date : 17-Nov-19

The Summary of Yesterday's		16-Nov-19 Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	7148.1 MW	12:00		Min. Gen. at	5:00 6200 MW
Evening Peak Generation :	9295.0 MW	19:00		Available Max Generation	15352 MW
E.P. Demand (at gen end) :	9295.0 MW	19:00		Max Demand (Evening) :	9700 MW
Maximum Generation :	9295.0 MW	19:00		Reserve(Generation end)	5652 MW
Total Gen. (MKWH) :	175.2	System Load Factor	: 78.55%	Load Shed	: 0 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR					
Export from East grid to West grid :- Maximum		30 MW	at	7:00	Energy MKWHR.
Import from West grid to East grid :- Maximum		-	MW	at	- Energy - MKWHR.

Water Level of Kaptai Lake at 6:00 A M on	17-Nov-19				
Actual :	101.31	Ft.(MSL) ,	Rule curve :	107.40	Ft.(MSL)

Gas Consumed :	Total =	1162.76	MMCFD.	Oil Consumed (PDB) :	
				HSD :	Liter
				FO :	Liter
Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk133,106,412		Oil :	Tk88,911,947
	Coal :	Tk21,442,234		Total :	Tk243,460,593

Load Shedding & Other Information

Area	Yesterday		Estimated Demand (S/S end)		Today	
	MW		MW		Estimated Shedding (S/S end)	Rates of Shedding (On Estimated Demand)
Dhaka	0	0:00	3420		0	0%
Chittagong Area	0	0:00	1159		0	0%
Khulna Area	0	0:00	1038		0	0%
Rajshahi Area	0	0:00	938		0	0%
)	0	0:00	847		0	0%
Mymensingh Area	0	0:00	684		0	0%
Sylhet Area	0	0:00	387		0	0%
Barisal Area	0	0:00	176		0	0%
Rangpur Area	0	0:00	527		0	0%
Total	0		9177		0	

Information of the Generating Units under shut down.

Planned Shut- Down	Forced Shut- Down
	1) Barapukuria ST: Unit-1&2. 2) Sylhet-150 MW. 3) Ghorasal Unit-2,3 4) Ashuganj unit-4 & 5 5) Chandpur CCPP ST 6) Sylhet 150 MW 7) Sirajganj unit-2

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Comments on Power Interruption
a) Bakulia 132/33 kV T1 transformer was under shut down from 08:33 to 15:53 for A/M. b) Tangail 132/33 kV T2 transformer was under shut down from 08:33 to 16:12 for A/M. c) Hathazari-Baroihat 132 kV Ckt-2 was shut down at 08:41 for A/M. d) Mirpur 132 kV bus coupler was under shut down from 09:30 to 16:30 for A/M. e) Aminbazar-Hasnabad 230 kV Ckt-2 was under shut down from 08:44 to 16:32 for A/M. f) Tongi-Kabirpur 132 kV Ckt-1 was under shut down from 08:59 to 17:08 for A/M. g) Netrokona 132/33 kV T1 transformer was under shut down from 08:02 to 15:27 for A/M. h) Jamalpur S/S-UMPL P/S 132 kV Ckt-2 was under shut down from 08:45 to 16:16 for A/M. i) Kishoreganj-Mymensingh 132 kV Ckt-2 was under shut down from 09:04 to 16:54 for A/M. j) Bhulta 132/33 kV T1 transformer was under shut down from 09:18 to 19:08 for A/M. k) Rangpur-Barapukuria 132 kV Ckt-1 was under shut down from 08:38 to 15:50 for A/M. l) Barapukuria-Bogura 230 kV Ckt-2 was under shut down from 08:06 to 16:24 for A/M. m) Natore-Rajshahi 132 kV Ckt-1 was under shut down from 09:05 to 13:10 for A/M. n) Rajshahi-Amnura 132 kV Ckt-1 was under shut down from 08:16 to 14:42 for A/M. o) Khulna(S)-Bheramara HVDC 230 kV Ckt-2 was under shut down from 08:13 to 16:36 for A/M. p) Noapara 132/33 kV T4 transformer was under shut down from 09:02 to 16:03 for A/M. q) Barisal(N) 132/33 kV T4 transformer was under shut down from 08:07 to 16:28 for A/M. r) Tongi-Kabirpur 132 kV Ckt-2 tripped at 10:25 from Kabirpur end showing Dist Z1 relays and was switched on at 10:36. s) Faridpur 132/33 kV T1 & T2 transformers tripped at 08:45 showing E/F relay at 33 kV end and were switched on at 08:57,10:09 respectively. t) Dohazari-Cox'sbazar 132 kV Ckt-1 was under shut down from 07:21 to 13:09 for A/M. u) Bhulta 132/33 kV T2 transformer tripped at 18:35 showing O/C relay at 33 kV end and was switched on at 18:38. v) Feni Lanka 114 MW was shut down at 17:43. w) Ghorasal-Ishurdi 230 kV Ckt-1 was shut down at 07:00(17/11/2019) for C/M. x) Sirajganj-Shahzadpur 132 kV Ckt was shut down at 06:52(17/11/2019) for A/M.	About 99 MW power interruption occurred under Kodda S/S area from 10:25 to 10:36. About 80 MW power interruption occurred under Faridpur S/S area from 08:45 to 08:57. About 67 MW power interruption occurred under Bhulta S/S area from 18:35 to 18:38.

Sub Divisional Engineer
Network Operation Division

Executive Engineer
Network Operation Division

Superintendent Engineer
Load Despatch Circle