

Date : 28-Nov-19

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	Generation	MW		
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	35	79000		#2 Under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	130	3195000		
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0		Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0		Gas shortage.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	240	4969127		ST under maint.
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0		Gas shortage.
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0		Gas shortage.
5	Haripur GTPP	SBU, PDB	2*32	40	0	0		Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	351	8683520		FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*236+1*125	360	361	7921000		
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	450	9573375		
9	Meghnaghat 100 MW (IEL)	QRPP	12*8.9	100	0	0		Reserve
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0		Gas shortage.
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	0	0		Reserve.
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	15	281086		Low demand
13	Keranganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	0	0		Reserve
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	207036		
15	210 MW Siddhirganj TTP	PDB	1*210	115	0	0		Gas shortage.
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	97	1904000		Gas shortage.
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	0	0		Reserve
18	Siddhirganj 335 MW CCPP	EGCB	1*217+118	335	0	0		Under maint.
19	Gaganagar 102 MW PP (Digital Power)	IPP	12*8.924	102	0	0		Reserve
20	Kaptai 52 MW PP (Sinha)	IPP	7*7.9	51	47	326112		
21	Kamalabari 54 MW PP(Banco En)	IPP	3*18	54	0	0		Reserve
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	48	112900		Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	17	122490		Low demand
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	17	296364		Low demand
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	72	481920		Engine problem
26	Summit Power,(Madhabdi+Ashuldi)	SIPP,REB	3*3.67+4*8.73	80	55	1298760		Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	825700		
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	813900		
29	Gazipur 52 MW PP	IPP	6*8.9	52	51	245016		
30	Tongi 80 MW GTTP	PDB	1* 105	105	0	0		Gas shortage.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	50	263527		Low demand
32	Keranganj 300 MW PP (APR)	IPP	25*11.4	300	0	0		Reserve
33	Bramhanganj 100 MW PP (Aggr)	IPP	1*100	100	0	0		Reserve
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0		Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	0	0		Reserve
36	Gazipur 100 MW PP	RPCL	100 MW	105	17	486408		Low demand
Dhaka area Total				5811	2138	42828411		
37	Chattogram TPP-1	PDB	1*210	180	0	0		Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	120	2900000		Gas shortage.
38	Raozan 25 MW PP	IPP	3*8.9	25	0	15338		Reserve
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	133110		
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	19	59520		Low demand
41	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	90	2155084		Low water level
42	Sikalbaha 225MW	PDB	1*150+1*175	225	211	4883518		FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	145	3367612		FGMO
44	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	105	1247018		
45	Hatibari 100 MW Peaking PP	PDB	11*8.9	98	0	0		Reserve
46	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	26	88185		Low demand
47	Julhadi 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	100	649200		
48	Julhadi 100 MW PP Unit-3 (Acorn)	IPP	0	100	0	0		Reserve
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	432384		
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	11	311040		
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	50	288960		Low demand
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	27840		
52	Anwara 300 MW PP (United)	IPP	300 MW	300	0	0		Reserve
53	Jodiac Power	IPP	3*18.55+1*3.6	54	0	0		Reserve
54	Karnaphuli Power Ltd.	IPP	110	110	0	0		Reserve
Chattogram area Total				2166	896	16558809		
55	Ashuganj TPP Unit-3	APSCL	1*150	135	120	2758194		Gas shortage.
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0		Gas shortage.
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0		Gas shortage.
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	217	175	4468000		FGMO
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	0	0		Under maint.
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	330	7749500		FGMO
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	37	670392		Engine problem
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	50	819840		
	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0		Contract Expired
62	Ashuganj 195MW PP (APSCL-Ur)	IPP	20*9.73+1*16	195	195	1722909		
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	784492		Engine problem
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	50	222472		Low demand
	B.Barra (Aggreko) 85MW	QRPP	8*6*1.10	85	0	0		Contract Expired
66	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0		Reserve
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	95	2197930		
68	Chandpur 200MW (Desh energy)	IPP	0	200	70	261120		Low demand
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	290240		
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	117720		
**	Impoort (Tripura)		0	160	124	2389440		
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	420800		
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	0	0		Reserve
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	21	427570		Engine problem
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0		Reserve
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0		On test
Cumilla Area Total				3005	1376	25400619		
75	RPCL 210MW CCPP	IPP	4*36+1*70	202	153	3366800		Gas shortage.
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	354564		
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	16	91200		Low demand
78	Sarisahabi 3 MW Solar Plant	IPP	1*3	3	0	13150		
79	Myrmenisingh 200 MW PP (United)	IPP	200	200	170	1908000		
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	0	0		Reserve
Myrmenisingh Area Total				637	361	5733714		
81	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	60	1127000		
82	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	58	1031280		
83	Kushibara 163 MW CCPP (KP)	IPP	1*109+1*54	163	100	2732400		ST Synchronized at 18:45.
84	Shahbazar 330 MW CCPP	PDB	3*110	330	244	4953000		
85	Fenchuganj 51 MW PP (Barakati)	RPP	19*2.90	51	53	654600		
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	50	740952		
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	264000		
88	Shahbazar GTTP Unit- 8 & 9	PDB	2*35	66	67	1362048		FGMO
89	Shahbazar 86MW PP (Shahbazar)	RPP	32*2.90	86	76	1052560		
90	Shahbazar 50MW PP (EPL)	RPP	27*2.0	50	0	0		Contact expired
91	Sylhet 150 MW CCPP	PDB	1*142	142	0	0		Under shut down.
92	Sylhet 20 MW GTTP	IPP	1*20	20	17	123900		
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	39	546860		Engine problem
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	308520		
95	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	315	7654750		FGMO
96	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	375	8987000		FGMO
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	142560		
Sylhet Area Total				1949	1499	31679730		
98	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0		Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	789	11910545		
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	0	0		Reserve
100	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	0	0		Reserve
101	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0		Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0		Reserve
103	Bheramara 360 MW CCPP	NWPGCL	1*278+1*132	410	320	7766208		Gas shortage.
104	Noapara 40 MW PP (Koneshan A)	QRPP	5*8.5	40	40	170250		
105	Noapara 100 MW PP (Bangla Tr)	IPP	70*1.4	100	0	0		Reserve
106	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	53	241140		Low demand
107	Madhumati 100 MW PP	IPP	100 MW	105	17	67824		Low demand
Khulna Area Total				2314	1219	20156267		
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	48	436800		Low demand
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0		Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	26	473900		Engine problem
111	Bhola 225 MW/ CCPP	PDB	2*63+1*68	194	174	3831752		
112	Bhola 95 MW PP (Aggreko)	QRPP	9*6*1.10	95	0	52816		Line over load
Barisal Area Total				462	248	4795268		
113	Baghabari 71 MW GTTP	PDB	1*71	71	0	320000		Gas shortage.
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0		Gas shortage.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0		Reserve
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0		Reserve
116	Annura 50 MW PP(Sinha)	QRPP	7*7.9	50	25	0		Low demand
117	Katakhalai 50 MW PP (Northern)	QRPP	6*8.9	50	0	0		Reserve
11								