

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | Peak Hour | Energy Generated | Remarks |
|------------------------------|---------------------------------------|-------------------------|---------------------|------------------|-------------|------------------|----------------------|
| | | | | MW | Generation | MW | |
| | | | Unit No. X Capacity | MW | MW | MW | |
| 1 | Ghorasal TPP (Unit-1&2) | PDB | 2*55 | 85 | 24 | 522000 | Unit-1 Under maint. |
| | Ghorasal Repowered CCGP Unit-3 | PDB | 1*210 | 170 | 0 | 0 | Under maint. |
| | Ghorasal Repowered CCGP Unit-4 | PDB | 1*210 | 180 | 152 | 3772000 | Gas shortage. |
| | Ghorasal TPP Unit-5 | PDB | 1*210 | 190 | 0 | 0 | Under maint. |
| 2 | Ghorasal 365 MW CCGP Unit-7 | PDB | 1*243+1*122 | 365 | 302 | 7666036 | Gas shortage. |
| 3 | Ghorasal 78.5 MW PP(MAX) | QRPP | 2*40 | 78 | 0 | 0 | Gas shortage. |
| 4 | Ghorasal 108MW PP (Regent) | IPP | 34*3.35 | 108 | 55 | 359636 | Gas shortage. |
| 5 | Haripur GTPP | SBU, PDB | 2*32 | 40 | 0 | 0 | Under maint. |
| 6 | Haripur 412 MW CCGP | EGCB | 1*273+1*139 | 412 | 338 | 8477770 | FGMO |
| 7 | Haripur 360MW CCGP(MPL) | IPP | 1*236+1*125 | 360 | 348 | 7700000 | |
| 8 | Meghnaghat 450 MW CCGP(MPL) | IPP | 2*150+1*150 | 450 | 420 | 8561000 | Frequency control |
| 9 | Meghnaghat 100 MW(IE/L) | QRPP | 1*2*9 | 100 | 100 | 217920 | |
| 10 | Meghnaghat CCRP(Summit) | IPP | 2*110+1*110 | 305 | 135 | 3271185 | Gas shortage. |
| 11 | Madanganj 102 PP(Summit) | QRPP | 6*17 | 100 | 96 | 951144 | |
| 12 | Madanganj-55 MW PP(Summit) | IPP | 3*17.08+1*11.3 | 55 | 0 | 7857 | Reserve |
| 13 | Keraniganj 100 MW PP (Powerpac) | QRPP | 8*13.45 | 100 | 0 | 30882 | Reserve |
| 14 | Narshingdi 22 MW PP (Doreen) | SIPP, REB | 8*2.90 | 22 | 19 | 257112 | |
| 15 | 210 MW Siddhirgonj TPP | PDB | 1*210 | 115 | 0 | 0 | Under maint. |
| 16 | Siddhirgonj 2*120 MW GTPP | EGCB | 2*105 | 210 | 110 | 3411000 | |
| 17 | Siddhirgonj 100 PP(Dutch Bangla) | QRPP | 12*8.9 | 100 | 80 | 298560 | Low demand |
| 18 | Siddhirgonj 335 MW CCGP | EGCB | 1*217+118 | 335 | 0 | 94091 | Under maint. |
| 19 | Gagnagar 102 MW PP (Digital Power) | IPP | 12*8.924 | 102 | 0 | 51984 | Reserve |
| 20 | Katpott 52 MW PP (Sinha) | IPP | 7*7.9 | 51 | 24 | 55680 | Low demand |
| 21 | Kamalaghat 54 MW PP(Banco Energy) | IPP | 3*18 | 54 | 53 | 333360 | |
| 22 | Kodda 150MW PP | BPDB-RPCL | 9*17.06 | 149 | 0 | 0 | Reserve |
| 23 | Maniganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 55 | 92266 | |
| 24 | Nababganj 55 MW PP (Southern power) | IPP | 3*19.3 | 55 | 17 | 247830 | Low demand |
| 25 | Bosila 108MW PP(CLC) | IPP | 12*8.775+1*3.5 | 108 | 0 | 0 | Engine problem |
| 26 | Summit Power (Madhabdi+Ashulia) | SIPP, REB | 3*3.67+4*8.73 | 80 | 36 | 791340 | Engine problem |
| 27 | Maona 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 25 | 632320 | Machine problem |
| 28 | Rupganj 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 16 | 526600 | |
| 29 | Gazipur 52 MW PP | IPP | 6*8.9 | 52 | 0 | 0 | Reserve |
| 30 | Tongi 80 MW GTPP | IPP | 1*105 | 105 | 0 | 0 | Gas shortage. |
| 31 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 18*17.076 | 300 | 130 | 436582 | Low demand |
| 32 | Keraniganj 300 MW PP (APR) | IPP | 25*11.4 | 300 | 0 | 0 | Reserve |
| 33 | Bramanganj 100 MW PP (Aggreko) | IPP | 100 | 100 | 0 | 0 | Reserve |
| 34 | Aurshahi 100MW PP (Aggreko) | IPP | 0.85*23+0.95*91 | 100 | 0 | 0 | Reserve |
| 35 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 149 | 149 | 70 | 210240 | Low demand |
| 36 | Gazipur 100 MW PP | RPCL | 100 MW | 105 | 0 | 0 | Reserve |
| Dhaka area Total | | | | 5811 | 2605 | 49047195 | |
| 37 | Chattogram TPP-1 | PDB | 1*210 | 180 | 95 | 2300000 | Gas shortage. |
| | Chattogram TPP-2 | PDB | 1*210 | 180 | 0 | 0 | Gas shortage. |
| 38 | Razzan 25 MW PP | IPP | 3*8.9 | 25 | 0 | 0 | Reserve |
| 39 | Teknaf 20MW PP (Solartech) | Teknaf Solartech Energy | 20 | 20 | 0 | 135000 | |
| 40 | Patenga 50MW PP (Baraka) | IPP | 8*6.98 | 50 | 50 | 198720 | |
| 41 | Kapali Hydro: Unit-1,2,3,4, 5 | PDB | 2*40+3*50 | 230 | 76 | 1796500 | Low water level |
| 42 | Sikalbaha 225MW | PDB | 1*150+1*175 | 225 | 203 | 4873463 | |
| 43 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 102 | 2940664 | FGMO |
| 44 | Sikalbaha 105 MW PP (Baraka Sikabaha) | IPP | 105 MW | 105 | 0 | 0 | Reserve |
| 45 | Hathazari 100 MW peaking PP | PDB | 11*8.9 | 98 | 0 | 0 | Under maint. |
| 46 | Dohazari -Kalaish 100 MW Peaking | PDB | 6*17 | 102 | 75 | 202220 | |
| 47 | Juidah 100 MW Unit-1 (Acorn) | QRPP | 8*13.45 | 100 | 0 | 0 | Reserve |
| 48 | Juidah 100 MW PP Unit-3 (Acorn) | IPP | 0 | 100 | 50 | 105600 | Low demand |
| 49 | Barabkunda 22 MW PP (Regent) | SIPP, PDB | 8*2.90 | 22 | 22 | 507600 | |
| * | Malancha, Ctg. EPZ (Uniled) | | 5*8.73+3*9.34 | 0 | 42 | 1150560 | |
| 50 | Chattogram 108 MW PP (ECPV) | IPP | 16*7 | 108 | 51 | 77760 | Low demand |
| 51 | Kaptai 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 33240 | |
| 52 | Anwara 300 MW PP (Uniled) | IPP | 300 MW | 300 | 175 | 1221927 | Transformer overload |
| 53 | Jodiak Power | IPP | 3*18.55+1*3.6 | 54 | 0 | 0 | Reserve |
| 54 | Karnaphuli Power Ltd. | IPP | 110 | 110 | 0 | 0 | Reserve |
| | Juidah unit-2 | IPP | 0 | 0 | 100 | 1930560 | On test |
| Chattogram area Total | | | | 2166 | 1041 | 17473814 | |
| 55 | Ashuganj TPP Unit-3 | APSCCL | 1*150 | 135 | 0 | 0 | Gas shortage. |
| | Ashuganj TPP Unit-4 | APSCCL | 1*150 | 129 | 140 | 2661755 | |
| | Ashuganj TPP Unit-5 | APSCCL | 1*150 | 134 | 0 | 0 | Gas shortage. |
| 56 | Ashuganj 225 MW CCGP | APSCCL | 1*142+1*75 | 221 | 180 | 4389000 | FGMO |
| 57 | Ashuganj 450 MW CCGP(North) | APSCCL | 1*360 | 360 | 0 | 3719300 | Under S/D |
| 58 | Ashuganj 450 MW CCGP(South) | APSCCL | 1*360 | 360 | 265 | 6871500 | FGMO |
| 59 | Ashuganj 50 MW PP | APSCCL | 14*3.968 | 45 | 45 | 769752 | |
| 60 | Ashuganj 55 MW PP (Precision) | RPP | 15*4 | 55 | 48 | 1188960 | |
| 62 | Ashuganj 195MW PP (APSCCL-Uniled) | IPP | 20*9.73+1*16 | 195 | 148 | 1656000 | Gas shortage. |
| 63 | Ashuganj 51 MW PP (Midland) | IPP | 6*9.34 | 51 | 51 | 1201632 | |
| 64 | Ashuganj 150MW PP (Midland) | IPP | 23*7.015 | 150 | 140 | 787781 | |
| 66 | Titas 50 MW Peaking PP | PDB | 6*8.92 | 50 | 0 | 0 | Reserve |
| 67 | Chandpur 150 MW CCGP | PDB | 1*106+1*57 | 163 | 0 | 135430 | Under S/D |
| 68 | Chandpur 200MW (Desh energy) | IPP | 0 | 200 | 0 | 0 | Reserve |
| 69 | Feni 22MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 22 | 459036 | |
| 70 | Feni 11 MW PP (Doreen) | SIPP, REB | 4*2.90 | 11 | 11 | 130320 | |
| ** | Impoort (Tripura) | Imported power | 0 | 160 | 130 | 2842560 | |
| 71 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4*8.73 | 33 | 33 | 590600 | |
| 72 | Jangalia 52 MW PP (Lakdanavi) | IPP | 6*8.92 | 52 | 24 | 30965 | Low demand |
| 73 | Cumilla 25 MW PP (Summit) | SIPP, PDB | 3*3.67+2*6.97 | 25 | 21 | 503700 | |
| 74 | Daudkandi 200 MW PP (B.Trac) | IPP | 154*1.4 | 200 | 0 | 0 | Reserve |
| | Feni Lanka Power | IPP | 7*18.415+1*9.78 | 114 | 0 | 0 | Reserve |
| | Chomuhani 113 MW | IPP | 12*9.78+2*3.1 | 113 | 75 | 1028160 | Low demand |
| Cumilla Area Total | | | | 2880 | 1333 | 28946451 | |
| 75 | RPCL 210MW CCGP | IPP | 4*35+1*70 | 202 | 207 | 4804160 | |
| 76 | Tangal 22 MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 22 | 497088 | |
| 77 | Jamalpur 95 MW PP(Powerpac) | IPP | 12*8.924 | 95 | 92 | 1097280 | |
| 78 | Sarishabari 3 MW Solar Plant | IPP | 1*3 | 3 | 0 | 18300 | |
| 79 | Mymensingh 200 MW PP (Uniled) | IPP | 200 | 200 | 113 | 2700000 | Low demand |
| 80 | Jamalpur 115 MW PP (Uniled) | IPP | 115 MW | 115 | 112 | 408000 | |
| Mymensingh Area Total | | | | 637 | 546 | 9524828 | |
| 81 | Fenchugonj CCGP Phase-1 | PDB | 2*32+1*33 | 70 | 42 | 986000 | |
| 82 | Fenchugonj CCGP Phase-2 | PDB | 2*35+1*35 | 90 | 43 | 772680 | |
| 83 | Kushibara 163 MW CCGP (KP) | IPP | 1*109+1*54 | 163 | 163 | 3204736 | |
| 84 | Shajibazar 330 MW CCGP | PDB | 3*110 | 330 | 278 | 5827000 | GT-2 simple cycle |
| 85 | Fenchugonj 51 MW PP (Barakatullah) | RPP | 19*2.90 | 51 | 53 | 703200 | |
| 86 | Fenchugonj 44MW (Energyprima) | RPP | 12*3.3+5*2 | 44 | 50 | 804672 | |
| 87 | Hobiganj 11MW PP Confidence-E | SIPP, REB | 4*2.90 | 11 | 11 | 206000 | |
| 88 | Shajibazar GTTP Unit- 8 & 9 | PDB | 2*35 | 66 | 54 | 1369152 | FGMO |
| 89 | Shajibazar 86MW PP (Shajibazar) | RPP | 32*2.90 | 86 | 78 | 1711680 | Engine problem |
| 90 | Shajibazar 50MW PP (EPL) | RPP | 27*2.0 | 50 | 0 | 0 | Contact expired |
| 91 | Sylhet 150 MW CCGP | PDB | 1*142 | 142 | 100 | 3104720 | |
| 92 | Sylhet 20 MW GTTP | PDB | 1*20 | 20 | 19 | 421000 | |
| 93 | Sylhet 50MW PP (EPL) | RPP | 27*2 | 50 | 0 | 0 | Contract Expired |
| 94 | Shahjanuilla 25 MW PP | SIPP, REB | 3*9.34 | 25 | 16 | 494840 | |
| 95 | Bibiana-II 341 MW CCGP (Summit) | IPP | 1*222+1*119 | 341 | 285 | 7290700 | FGMO |
| 96 | Bibiana-III 400 MW CCGP | PDB | 400 MW | 400 | 0 | 0 | Under maint. |
| 97 | Sylhet 10MW PP (Desh) | RPP | 6*1.95 | 10 | 10 | 196740 | |
| Sylhet Area Total | | | | 1949 | 1202 | 27692920 | |
| 98 | Bheranara GTTP Unit-1,2 & 3 | PDB | 3*20 | 46 | 0 | 0 | Reserve |
| ** | Bheranara (NDC) | Imported power | 2*500 | 1000 | 731 | 10534545 | |
| 100 | Khulna 115 PP MW (KPCL-2) | QRPP | 7*17 | 115 | 115 | 670080 | |
| 101 | Fardpur 50 MW Peaking PP | PDB | 8*6.89 | 54 | 0 | 0 | Reserve |
| 100 | Khulna 225 MW CCGP | NWPGCL | 1*150+1*75 | 230 | 0 | 0 | Reserve |
| 102 | Copalganj 100 MW Peaking PP | PDB | 16*6.98 | 109 | 0 | 0 | Reserve |
| 103 | Bheranara 410 MW CCGP | NWPGCL | 1*278+1*132 | 410 | 365 | 8573184 | FGMO |
| 104 | Noapara 40 MW PP (Kharjahan Ali) | QRPP | 5*8.5 | 40 | 40 | 104250 | |
| 105 | Noapara 100 MW PP (Bangla Trac) | IPP | 70*1.4 | 100 | 50 | 103680 | Low demand |
| 106 | Rupsha 105 MW PP (Orion rupsha) | IPP | 6*18.445 | 105 | 0 | 0 | Reserve |
| 107 | Madhumati 100 MW PP | IPP | 100 MW | 105 | 63 | 186624 | Low demand |
| Khulna Area Total | | | | 2314 | 1364 | 20172363 | |
| 108 | Barisal 110 MW PP (Summit) | IPP | 7*17.076 | 110 | 48 | 160896 | Low demand |
| 109 | Barisal GT PP Unit-1& 2 | PDB | 2*20 | 30 | 0 | 0 | Reserve |
| 110 | Bhola 33 MW PP (Venture) | RPP | 1*34.50 | 33 | 24 | 435400 | Engine problem |
| 111 | Bhola 225 MW CCGP | PDB | 2*63+1*68 | 194 | 175 | 4306878 | |
| 112 | Bhola 95 MW PP (Aggreko) | QRPP | 96*1.10 | 95 | 22 | 377777 | Payra Test. |
| | Payra 1320 MW | NWPGCL | 0 | 0 | 0 | 6208900 | On test |
| Barisal Area Total | | | | 462 | 269 | 11489851 | |
| 113 | Baghabari 71 MW GTTP | PDB | 1*71 | 71 | 50 | 965000 | |
| | Baghabari 100 MW GTTP | PDB | 1*100 | 100 | 0 | 0 | Gas shortage. |
| 114 | Baghabari 50 MW Peaking PP | PDB | 6*8.9 | 52 | 0 | 0 | Reserve |
| 115 | Bera 70 MW Peaking PP | PDB | 9*8.29 | 71 | 0 | 0 | Reserve |
| 116 | Amnara 50 MW PP(Sinha) | QRPP | 7*7.9 | 50 | 0 | 0 | Fuel problem |
| 117 | Katakali 50 MW PP (Northern) | QRPP | 6*8.9 | 50 | 8 | 72090 | Low demand |
| 118 | Katakali 50 MW Peaking PP | PDB | 6*8.7 | 50 | 39 | 329902 | |
| 119 | Sirajgonj Unit-1 225MW | NWPGCL | 1*150+1*75 | 210 | 214 | 4654273 | FGMO |
| 120 | Sirajgonj Unit-2 225MW | NWPGCL | 1*150+1*75 | 220 | 0 | 0 | Gas shortage. |
| 121 | Sirajgonj Unit-3 225MW | NWPGCL | 1*141 | 220 | 195 | 4713773 | FGMO |
| 122 | Sirajgonj 400 MW CCGP Unit-4 | SNWPGCL | 1*282+1*132 | 414 | 335 | 9389854 | FGMO |
| 123 | Santahar 50 MW Peaking PP | PDB | | | | | |