

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
				MW	Generation	MW	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	0	0	Unit-1 & 2 Under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	220	4452000	
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
3	Ghorashal 78.5 MW PP(MAX)	QRPP	2*40	78	71	1469216	
4	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	109	2323000	
5	Haripur GTPP	SBU, PDB	2*32	40	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	326	8203264	FGMO
7	Haripur 360MW CCPP(MPL)	IPP	1*236+1*125	360	300	7614000	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	420	8812750	
9	Meghnaghat 100 MW (EPL)	QRPP	1*27.9	100	100	1103940	
10	Meghnaghat CCRP(Summit)	IPP	2*110+1*110	305	130	3270516	Gas shortage.
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	90	1753080	
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	168619	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	40	84801	Low demand
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	359316	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	140	3235000	Gas shortage.
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	85	161280	Low demand
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+118	335	0	0	Under S/D.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	0	0	Reserve
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Reserve
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	53	722520	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	0	0	Reserve
23	Maniganj 55 MW PP (Northern)	IPP	3*19.3	55	35	641421	Low demand
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	17	196931	Low demand
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	Fuel Shortage
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	50	1102200	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	14	697400	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	29	642700	
29	Gazipur 52 MW PP	IPP	6*8.9	52	0	0	Reserve
30	Tongi 80 MW GTPP	IPP	1*105	105	0	0	Gas shortage.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	3442471	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve
33	Bramanganj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve
34	Aurshahi 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	146	2157120	
36	Gazipur 100 MW PP	RPCL	100 MW	105	0	0	Reserve
Dhaka area Total				5811	2749	52412645	
37	Chattogram TPP-1	PDB	1*210	180	90	2400000	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage.
38	Razzan 25 MW PP	IPP	3*8.9	25	8	36180	Low demand
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	102400	
40	Patenga 50MW PP (Baraka)	IPP	6*8.98	50	26	268320	Low demand
41	Kapali Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	73	1711420	Low water level
42	Sikalbaha 225MW	PDB	1*150+1*175	225	218	5091035	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	138	3272222	FGMO
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	IPP	105 MW	105	0	0	Reserve
45	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under maint.
46	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	68	538358	Low demand
47	Juidah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	20	19680	Low demand
48	Juidah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2176320	
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	488928	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	42	651360	
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	72	268800	Low demand
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	39960	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	216	3823855	Low demand
53	Jodiak Power	IPP	3*18.55+1*3.6	54	0	0	Reserve
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve
	Juidah unit-2	IPP	0	0	100	2415360	
Chattogram area Total				2166	1192	23304198	
55	Ashuganj TPP Unit- 3	APSCL	1*150	135	135	2540702	Gas shortage.
	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	1899840	Reserve
	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0	Gas shortage.
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	180	4589000	FGMO
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	0	5894100	Ashuganj Grid problem
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	150	3287000	Ashuganj Grid problem
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	42	927000	
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	33	577440	
62	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	0	1488727	Ashuganj Grid problem
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	1039168	Ashuganj Grid problem
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	0	1794836	Ashuganj Grid problem
66	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	0	0	Under maint.
68	Chandpur 200MW (Desh energy)	IPP	0	200	0	0	Reserve
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	459396	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	10	235980	
**	Impoort (Tripura)	Imported power	0	160	168	2966400	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	817700	
72	Jangalia 52 MW PP (Lakhdanavi)	IPP	6*8.92	52	0	0	Reserve
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	473980	
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	114	906300	
	Chomuhani 113 MW	IPP	12*9.78+2*3.1	113	113	2114280	
Cumilla Area Total				2880	1079	32011849	
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	154	4172440	
76	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	280404	Machine problem
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	24	80640	Low demand
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12900	
79	Mymensingh 200 MW PP (United)	IPP	200	200	125	2748000	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1299600	#REF!
Mymensingh Area Total				637	418	8593984	
81	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	86	1959000	
82	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	29	696240	
83	Kushlaha 163 MW CCPP (KP)	IPP	1*109+1*54	163	130	3387272	
84	Shajibazar 330 MW CCPP	PDB	3*110	330	193	4488000	FGMO
85	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	53	1106400	
86	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	47	1110384	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	231000	
88	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	60	1396416	FGMO
89	Shajibazar 86MW PP (Shajibazar)	RPP	32*2.90	86	78	1616640	
90	Shajibazar 50MW PP (EPL)	RPP	27*2.0	50	0	0	Contact expired
91	Sylhet 150 MW CCPP	PDB	1*142	142	150	2991900	
92	Sylhet 20 MW GTTP	PDB	1*20	20	18	423000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	Contract Expired
94	Shahjanuilla 25 MW PP	SIPP, REB	3*9.34	25	24	587546	
95	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	270	7162200	FGMO
96	Bibiana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	236340	
Sylhet Area Total				1949	1159	27612338	
98	Bheranara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
**	Bheranara (NDC)	Imported power	2*500	1000	941	17585455	
100	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	83	1243200	Engine problem
101	Fariapur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve
100	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16*9.98	109	0	0	Reserve
103	Bheranara 410 MW CCPP	NWPGCL	1*278+1*132	410	330	8058528	FGMO
104	Noapara 40 MW PP (Kharjahan Ali)	QRPP	5*8.5	40	40	249750	
105	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	87	212160	
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	70	289440	Low demand
107	Madhumati 100 MW PP	IPP	100 MW	105	0	0	Reserve
Khulna Area Total				2314	1551	27638533	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	80	503520	Low demand
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	33	603204	
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	82	1853088	
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	96	2078130	
	Payra 1320 MW	NWPGCL	0	0	657	14554100	On test
Barisal Area Total				462	948	19592042	
113	Baghabari 71 MW GTTP	PDB	1*71	71	70	1530000	Gas shortage.
	Baghabari 100 MW GTTP	PDB	1*100	100	70	1526000	Gas shortage.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0	Reserve
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve
116	Amnura 50 MW PP(Sinha)	QRPP	7*7.9	50	50	769820	
117	Katakali 50 MW PP (Northern)	QRPP	6*8.9	50	0	0	Reserve
118	Katakali 50 MW Peaking PP	PDB	6*8.7	50	0	0	Reserve
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	148	3593600	FGMO
120	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	173	4479073	FGMO
121	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	181	4645736	FGMO
122	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1*282+1*132	414	0	0	Under S/D
123	Santahar 50 MW Peaking PP						