

**POWER GRID COMPANY OF BANGLADESH LTD.  
NATIONAL DAILY DESPATCH CENTER  
DAILY REPORT**

QF-LDC-08  
Page -1

Reporting Date : 6-Nov-20

Till now the maximum generation is :- <b>12893 MW</b>		<b>21:00 Hrs on 29-May-19</b>
<b>The Summary of Yesterday's 5-Nov-20 Generation &amp; Demand</b>		<b>Today's Actual Min Gen. &amp; Probable Gen. &amp; Demand</b>
Day Peak Generation :	8281.0 MW	Hour : 12:00 Min. Gen. at 7:00 5806 MW
Evening Peak Generation :	9602.0 MW	Hour : 19:00 Available Max Generation : 14220 MW
E.P. Demand (at gen end) :	9602.0 MW	Hour : 19:00 Max Demand (Evening) : 10300 MW
Maximum Generation :	9602.0 MW	Hour : 19:00 Reserve(Generation end) : 3920 MW
Total Gen. (MKWH) :	195.1	System Load Factor : 84.64% Load Shed : 0 MW

**EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR**

Export from East grid to West grid :- Maximum	218 MW	at 18:00	Energy	MKWHR.
Import from West grid to East grid :- Maximum	-	at -	Energy	- MKWHR.
Level of Kaptai Lake at 6:00 A.M on 6-Nov-20	Actual : 104.46 Ft.(MSL) ,	Rule curve : 108.50 Ft.( MSL )		

Gas Consumed : Total = 1022.57 MMCFD.	Oil Consumed (PDB) :	HSD : Liter
		FO : Liter
Cost of the Consumed Fuel (PDE) :	Gas : Tk148,513,948	Oil : Tk199,957,992
	Coal : Tk69,348,352	Total : Tk417,820,291

**Load Shedding & Other Information**

Area	Yesterday		Today		Rates of Shedding (On Estimated Demand)
	MW	Estimated Demand (S/S end) MW	Estimated Shedding (S/S end) MW		
Dhaka	0	0:00	3629	0	0%
Chittagong Area	0	0:00	1232	0	0%
Khulna Area	0	0:00	1103	0	0%
Rajshahi Area	0	0:00	997	0	0%
Cumilla Area	0	0:00	901	0	0%
Mymensingh Area	0	0:00	727	0	0%
Sylhet Area	0	0:00	409	0	0%
Barisal Area	0	0:00	187	0	0%
Rangpur Area	0	0:00	561	0	0%
<b>Total</b>	<b>0</b>	<b>0:00</b>	<b>9744</b>	<b>0</b>	<b>0%</b>

Information of the Generating Units under shut down.

**Planned Shut-Down**

**Forced Shut-Down**

- 1) Barapukuria 5 (10) Sirajganj #1 CCPP STG
- 2) Baghabari-10(11) Summit Meghnaaghat GT-2
- 3) Ghorasal Unit-1,2,3
- 4) Ashuganj unit-3,5
- 5) Kaptai-2
- 6) Raozan #2,5
- 7) Siddirganj-335 MW
- 8) Haripur 412 MW
- 9) Chandpur-163 MW STG

**Additional Information of Machines, lines, interruption / Forced Load shed etc.**

Description	Comments on Power Interruption
<p>a) New Tongi 132/33 kV T-1 transformer was under shut down from 09:14 to 15:16 for A/M.</p> <p>b) Haripur-Sonargaon 132 kV Ckt-2 was shut down at 08:54 to 16:21 for A/M.</p> <p>c) Tangail 132/33 kV T-1 transformer was under shut down from 08:30 to 15:01 for A/M.</p> <p>d) Mymensingh-Netrokona 132 kV Ckt-1 was under shut down from 08:42 to 16:26 for A/M.</p> <p>e) Aminbazar-Agargaon 230 kV Ckt-1 was under shut down from 11:19 to 18:05 for A/M.</p> <p>f) Naogaon 132/33 kV T-3 transformer was under shut down from 08:15 to 12:59 for A/M.</p> <p>g) Natore-Bogura 132 kV Ckt-2 was under shut down from 09:21 to 17:20 for A/M.</p> <p>h) Joypurhat 132/33 kV T-3 transformer was under shut down from 08:04 to 15:55 for A/M.</p> <p>i) Barishal 230/132 kV T-2 transformer was under shut down from 08:28 to 17:10 for A/M.</p> <p>j) Khulna(s) 230/132 kV T-2 transformer was shut down from 08:28 to 17:36 for A/M.</p> <p>k) Bheramara Auxiliary 33/04 kV T2 transformer was shut down from 08:04 to 20:30 for oil leakage.</p> <p>l) Bagerhat 132/33 kV T-3 transformer was under shut down from 06:17 to 08:49 for R/H maint.</p> <p>m) Meghnaaghat-Cumilla(N) 230 kV Ckt-1 was under shut down from 08:42 to 17:13 for A/M.</p> <p>n) Siddirganj-Ullon 132 kV Ckt-1 was under shut down from 08:27 to 16:28 for A/M.</p> <p>o) Tongi 132/33 kV T-2 transformer was under shut down from 08:25 to 08:58 for A/M.</p> <p>p) Naogaon 132/33 kV T-1 transformer was under shut down from 13:12 to 16:13 for A/M.</p> <p>q) Sikalbaha 225 MW was under shut down at 15:29 for gas pressure low .</p> <p>r) After maintenance Summit Bibiyana GT, &amp; ST were synchronized at 15:53,19:11 respectively.</p> <p>s) Kabirpur-Kaliakoir 132 kV Ckt-1 is under shut down since 07:06(06-11-2020) for D/W.</p> <p>t) Tangail-Kaliakoir 132 kV Ckt-1 is under shut down since 06:12(06-11-2020) for C/M.</p> <p>u) Kaliakoir 400/132 kV T1 transformer is under shut down since 07:39(06-11-2020) for C/M.</p> <p>v) Goalpara-Bagherhat 132 kV Ckt was under shut down since 06:17(06-11-2020) for D/W.</p> <p>w) Goalpara-Rupsha-Bagherhat 132 kV Ckt was under shut down since 06:19(06-11-2020) for D/W.</p> <p>x) Bagherhat-Mongla 132 kV Ckt was under shut down since 06:07(06-11-2020) for D/W.</p>	<p>About 08 MW power interruption occurred under Mongla S/S are since 06:07(06-11-2020)</p>
Sub Divisional Engineer Network Operation Division	Executive Engineer Network Operation Division
	Superintendent Engineer Load Despatch Circle