

**EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Sl No.	Name of the Power Stations	Producer	Installed Capacity	Present		Peak Generation	Energy Generated	Remarks
				Capacity Y	Hour			
<b>Unit No. X Capacity MW MW MW</b>								
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	0	0	0	Unit-1,2 Under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	1788700	0	Gas shortage
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	115	2803500	0	Gas shortage
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	300	6961145	0	Gas shortage
3	Ghorasal 18.5 MW DR(MAX)	QRPP	2*0	0	0	0	0	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	52	461045	0	Gas shortage
5	Haripur GTPP	SBU, PDB	2*32	20	0	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	339	8644610	0	FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	310	7058000	0	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	360	8561500	0	Gas shortage
9	Meghnaghat 100 MW(IEL)	QRPP	12*8.9	100	100	1779840	0	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	0	Gas shortage
11	Madanganj 102 MW (Summit)	QRPP	6*17	100	15	83976	0	Low demand
12	Madanganj 55 MW PP (Summit)	(IPP)	3*17.08+1*11.3	55	41	404685	0	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	62	1446190	0	Fuel shortage
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	367236	0	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	100	830400	0	
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*18	335	0	0	0	Under maint.
19	Gaganagar 102 MW PP (Digital Power)	IPP	12*9.24	102	0	161568	0	Reserve.
20	Kaptai 52 MW PP (Sinha)	IPP	7*7.9	51	0	12144	0	Reserve.
21	Kamalahat 54 MW PP(Banco Energy)	IPP	3*18	54	54	1073160	0	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	84	404640	0	Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	781470	0	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	17	212705	0	Low demand
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	0	Fuel shortage
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	53	1263840	0	Engine problem
27	Maana 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	582300	0	Engine problem
28	Rugganji 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	783000	0	
29	Gazipur 52 MW PP	IPP	6*8.9	52	43	238488	0	Engine problem
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	2759999	0	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	0	Reserve.
33	Bramhangonj 100 MW PP (Aggreko)	IPP	100	100	0	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	1759420	0	
36	Gazipur 100 MW PP	RPCL	100 MW	105	50	183888	0	Low demand
	Meghnaghat 104 MW PP (QPCL)	IPP	18*5*6	104	90	1682880	0	Engine problem
	Manikganj 162MW PP(MPCL)	IPP	9*18	162	0	0	0	On test
<b>Dhaka area Total</b>				<b>6057</b>	<b>2763</b>	<b>5317329</b>		
37	Chattogram TPP-1	PDB	1*210	180	0	0	0	Gas shortage
	Chattogram TPP-2	PDB	1*210	180	0	0	0	Gas shortage
38	Razzan 25 MW PP	IPP	3*8.9	25	0	0	0	Reserve.
39	Teknaf 20MW PP (Solaritech)	Teknaf Solartech Ener	20	20	0	109890	0	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	486720	0	
41	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	48	1107229	0	Unit-2 under maint
42	Sikalbaha 225MW	PDB	1*150+1*75	225	176	4861704	0	
43	Sikalbaha Peaking GT	PDB	1*150	150	0	0	0	Gas shortage
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	IPP	105 MW	105	0	0	0	Reserve.
45	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	0	Under maint.
46	Dohazari-Kalaish 100 MW Peaking	PDB	6*17	102	68	286771	0	Low demand
47	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	0	0	0	Reserve.
48	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1806720	0	
49	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	17	408096	0	Engine problem
	Metlachna, Ctg. EPZ (United)		5*8.73+3*9.34	0	15	528000	0	
50	Chattogram 108 MW PP (ECPV)	IPP	18*7	108	0	0	0	Reserve.
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	24826	0	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	160	2857855	0	Transformer O/L
53	Jodiac Power	IPP	3*18.55+1*3.6	54	53	1145173	0	
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	0	Reserve.
	Juldah unit-2 (Acorn)	IPP	8*13.6	100	50	773760	0	Low demand
	Anilma Energy Ltd.	IPP	6*21.2	0	0	23836	0	
<b>Chattogram area Total</b>				<b>2266</b>	<b>737</b>	<b>1441860</b>		
55	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	1542216	0	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	80	192925	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	1482664	0	Gas shortage
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	221	4275000	0	
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	0	0	0	Under maint
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	170	1282000	0	Gas shortage
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	10	547416	0	Gas shortage
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	141120	0	Gas shortage
62	Ashuganj 165MW PP (APSC-United)	IPP	20*9.73+1*116	195	8	200727	0	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	51*3.4	51	51	1187008	0	
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	150	2090909	0	
66	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	0	Reserve.
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	0	0	0	Under maint.
	Chandpur 200MW (Desh energy)	IPP	0	200	120	1935840	0	Low demand
68	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	496188	0	
70	Feni 11 MW PP (Doreen)	SIPP	4*2.90	11	8	190088	0	Engine problem
**	Import (Tripura)	Imported power	0	160	106	2078400	0	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	25	615230	0	Engine problem
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	0	167506	0	Reserve.
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	21	457900	0	
74	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	0	Reserve.
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	0	Reserve.
	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	9	312480	0	
<b>Cumilla Area Total</b>				<b>2980</b>	<b>1005</b>	<b>20942179</b>		
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	92	2388960	0	Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	381960	0	
77	Jamalpur 95 MW PP (Powerpac)	IPP	12*8.924	95	95	335040	0	
78	Sariakhal 3 MW Solar Plant	IPP	1*3	3	0	2050	0	
79	Mymensingh 200 MW PP (United)	IPP	200	200	8	13200	0	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1986000	0	#REF!
	Sutiakhal 50 MW Solar PP	IPP	50	50	0	105510	0	
	Tangail Palli Power Gen 22 MW	SIPP	4*6.7	0	26	487200	0	
<b>Mymensingh Area Total</b>				<b>687</b>	<b>356</b>	<b>5702920</b>		
81	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	20	479000	0	Gas shortage
82	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	42	623640	0	
83	Kushnara 163 MW CCPP (KP)	IPP	1*108+1*54	163	110	3236727	0	Frequency control
84	Shahjibazar 330 MW CCPP	PDB	3*110	330	156	3479000	0	Gas shortage & GT-2 under shut down
85	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	53	1063800	0	
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	50	1098864	0	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	122000	0	
88	Shahjibazar GTTP Unit- 6 & 9	PDB	2*35	66	36	748992	0	Unit-9 under maint.
89	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	75	1522560	0	
	Shahjibazar 100 MW GTTP	PDB	1*100	0	0	400000	0	
91	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	120	284990	0	
92	Sylhet 20 MW GTTP	PDB	1*20	20	18	433000	0	
93	Sylhet 50MW PP (EPL)	RPP	2*7.2	50	0	0	0	Contract Expired
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	325272	0	Engine problem
95	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	0	0	0	FGMO
96	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	327	7129000	0	
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	0	0	0	Engine problem
	Bibiyana South 400 MW	PDB	400 MW	0	100	1019500	0	On test
<b>Sylhet Area Total</b>				<b>1988</b>	<b>1134</b>	<b>24530445</b>		
98	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	0	Reserve.
**	Bheramara (HVIC)	Imported power	2*500	1000	782	12771636	0	
99	Khulna 115 MW (KPCL-2)	QRPP	7*17	115	65	136320	0	Low demand
100	Fardpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	0	Reserve.
101	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	0	Reserve.
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	0	Reserve.
103	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	300	7874208	0	Gas shortage
104	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	0	0	0	Reserve.
105	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	0	Reserve.
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	90	1418880	0	Engine problem
107	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	0	Reserve.
<b>Khulna Area Total</b>				<b>2284</b>	<b>1237</b>	<b>22201044</b>		
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	80	381680	0	High Voltage
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	26	508900	0	Engine problem
111	Bhola 225 MW CCPP	PDB	2*63+1					