

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month December, 2020				Day : Wednesday				Date : 30.12.20						
Probable Maximum Demand :		9000 MW		Probable Maximum Generation :				13053 MW						
Water Level of Kaptai Lake at 06:00 AM				Yesterday =		98.32 ft		Today =		98.26 ft		Rule Curve = 103.20 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.12.20 (Yesterday)		30.12.20 (Today)		29.12.20 (Yesterday)		30.12.20 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Power Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)	Description/ Remarks		Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW					
<b>(A) Plants in operation:</b>														
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0				Under maint.	
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	102	101	102	102	69			Gas Shortage	
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	STG Commissioning	
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0			190	Under maint.	
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	330	300	300	300					
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12					
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20			Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	283	255	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225			Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	380	363	412	412					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0			335	Under maint.	
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	30	100	100	100					
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305			Gas Shortage	
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	50	100	100	100					
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	15	64	100	100					
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	20	15	55	55					
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	83	100	100	100					
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	24	100	100					
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	19	19					
21	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	51	58	58	58					
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	17	17	17					
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52					
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	52	105	105					
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	48	150	150					
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50					
28	Kamalaghat 54 MW PP (Banos Energy)	HFO (IPP)	3x18.69	54	54	35	0	54	54					
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	212	300	300	300					
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	31	110	149	149					
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300					
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100					
33	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	60	100					
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	0	36	55	55					
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	55	55					
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	88	90	104	104					
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	162	100	160					
<b>Dhaka Zone Total</b>				<b>6281</b>	<b>6057</b>	<b>2032</b>	<b>2600</b>	<b>3447</b>	<b>3797</b>	<b>1012</b>	<b>905</b>			
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	47	45	45	45	185			Low Water Level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0					
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25					
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0					
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	32	47	50	50					
45	Sikalbaha 105 MW PP (Baraka Sike)	HFO (IPP)	6x18.415	105	105	0	0	100	100					
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150			Gas Shortage	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	163	163	163	163	62			Gas Shortage	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	196	269	300	300					
49	Julda 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	10	100	100					
50	Julda 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100					
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	70	100	100					
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0					
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	2	17	19	19					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	18	10	20					
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	102	102					
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54					
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110					
57	Julda unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	70	100	100	100					
	Anlima Energy Ltd.	HFO (IPP)				41	0	0	0					
<b>Chattogram Zone Total</b>				<b>2326</b>	<b>2266</b>	<b>727</b>	<b>918</b>	<b>1403</b>	<b>1388</b>	<b>577</b>	<b>180</b>			
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	80	110	110	55			Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	80	0	0	0	129			Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	10	26	26					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	40	229	200	200					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	310	300	0	0					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	260	260			360	Under maint.	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	15	5	5	40			Gas Shortage	
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	26	26	187			Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	143	145	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	50	45	50	50					
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	69	100	200	200					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
72	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
73	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	43	43					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	22	20	22					
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x1.4+4x1.515+15x1.05	200	200	0	0	0	200					
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	46	113	113					
**	Impoort (Tiripura)	India		160	160	72	106	110	148					
<b>Cumilla Zone Total</b>				<b>3040</b>	<b>2980</b>	<b>1017</b>	<b>1222</b>	<b>1540</b>	<b>1830</b>	<b>545</b>	<b>360</b>			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	89	92	111	149	110			Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	20	20					
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	16	32	95	95					
81</														

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.12.20 (Yesterday)		30.12.20 (Today)		29.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance		
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
85	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30					
86	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	32	32	30	30					
87	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	31	11	51	51					
88	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	47	30	44	44					
89	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	163	163					
90	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
91	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	33	33	33					
92	Shajibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	152	157	155	155	173		Gas Shortage		
93	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	69	67	86	86					
94	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	182	229	200	200					
95	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	19	19	20	20					
96	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0					
97	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0					
98	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	14	16	16	16					
99	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	280	320	320					
100	Bibiyana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400		Gas Shortage		
		Bibiyana South 400 MW	Gas (PDB)				127	220	280	280					
		Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	100	100					
<b>Sylhet Zone Total</b>					<b>2033</b>	<b>1988</b>	<b>1062</b>	<b>1135</b>	<b>1539</b>	<b>1539</b>	<b>573</b>	<b>0</b>			
101	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16					
102	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	185	150	230	230	260		Gas Shortage		
103	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	35	35					
104	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	70	70					
105	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220					
106	Khulna	115 PP MW (KPLC-2)	HFO (QRPP)	7x17	115	115	0	115	115	115					
107	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100					
108	Noapara	40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	40	40					
109	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	70	90	90	90					
110	Madhumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India			1000	1000	870	806	587	827					
<b>Khulna Zone Total</b>					<b>2288</b>	<b>2284</b>	<b>525</b>	<b>1161</b>	<b>1317</b>	<b>1843</b>	<b>260</b>	<b>0</b>			
111	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
112	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	12	27	25	25					
113	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.		
114	Bhola	95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	34	85	10	10					
115	Payra	1320 MW Unit-1	Coal (BCPCL)	1x622	622	622	380	520	0	0					
		Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				15	15	35	35					
		United Payra Power Ltd.	HFO (IPP)				55	55	55	55					
<b>Barishal Zone Total</b>					<b>1054</b>	<b>1054</b>	<b>496</b>	<b>702</b>	<b>235</b>	<b>235</b>	<b>0</b>	<b>194</b>			
116	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50					
118		Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119		Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40					
120		Amnura 50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	0	0	35	35					
121		Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	35	35	100	100					
122		Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	50					
123		Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	50					
124		Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34					
125		Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
126		Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage		
127		Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	160	139	220	220					
128		Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	399	298	400	400					
129		Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22					
130		Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0					
131		Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
132		Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52					
133		Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	50	70	113	113					
134		Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	110	113	113					
<b>Rajshahi Zone Total</b>					<b>2193</b>	<b>2183</b>	<b>747</b>	<b>685</b>	<b>1366</b>	<b>1490</b>	<b>601</b>	<b>0</b>			
135	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	42	0	68	68					
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
136		Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	149	149	124		Under maint.		
137		Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
138		Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	40	0	113	113					
139		Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
140		Majpara, Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
<b>Rangpur Zone Total</b>					<b>685</b>	<b>605</b>	<b>236</b>	<b>150</b>	<b>338</b>	<b>330</b>	<b>85</b>	<b>124</b>			
<b>Sub-total: Plants in operation</b>					<b>20595</b>	<b>20104</b>	<b>7434.0</b>	<b>8945</b>	<b>11800</b>	<b>13053</b>	<b>3763</b>	<b>1763</b>			
<b>Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss</b>							<b>6968</b>	<b>8384</b>	<b>11060</b>	<b>12234</b>					
<b>(B) Contract expired power plants</b>															
Sub-Total: Plants under long term maintenance					0	0	0	0	0	0					
<b>Gross Total</b>					<b>20595</b>	<b>20104</b>	<b>7434</b>	<b>8945</b>	<b>11800</b>	<b>13053</b>	<b>3763</b>	<b>1763</b>			
<b>(C) Actual data of 29.12.20 (Yesterday) Tuesday :</b>															
01.	Max. Demand (Generation end) :				8945.00	MW,	at =	19:30 hrs							
02.	Max. Demand (Sub-station end) :				8384.00	MW,	at =	19:30 hrs							
03.	Highest Generation (Generation end) :				8945.00	MW,	at =	19:30 hrs							
04.	Minimum Generation (Generation end) :				5419.00	MW,	at =	5:00 hrs							
05.	Day-peak Generation (Generation end) :				7434.00	MW,	at =	12:00 hrs							
06.	Evening-peak Generation (Generation end) :				8945.00	MW,	at =	19:30 hrs							
07.	Evening Peak Load-shed (Sub-station end) :				0.00	MW,	at =	19:30 hrs							
08.	Actual Minimum Generation up to 8:00 hrs. :				5616.00	MW,	at =	7:00 hrs							
09.	Generation shortfall at evening peak due to :														
	a)	Gas limitation		3493	MW										
	d)	Coal supply Limitation		85	MW										
	b)	Low water level in Kaptai lake		185	MW										
	c)	Plants under shut down/ maintenance		1763	MW										
10.	Total Energy (Generation + India Import) :				172.04	MKWh									
	By Gas =		103.840	MKWh	By Hydro =		37.740	MKWh							
	By Coal =		13.482	MKWh	By Solar =		0.403	MKWh							
11.	Total Gas Supplied :				817.47	MMCFD									
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :														
	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed							
		MW	MW	MW		MW	MW	MW							
	Dhaka	2981	2981	0	Mymensingh	700	700	0							
	Chattogram	885	885	0	Sylhet	314	314	0							
	Khulna	1070	1070	0	Barishal	248	248	0							
	Rajshahi	872	872	0	Rangpur	575	575	0							
	Cumilla	739	739	0											
					<b>Total</b>	<b>8384</b>	<b>8384</b>	<b>0</b>							
13.	Fuel cost :		(a) Gas =	115353354	Taka	(c) Coal =	84222363	Taka							
			(b) Oil =	275303920	Taka	<b>Total =</b>	<b>454879637</b>	Taka							
14.	Maximum Temperature in Dhaka was :				25.8° C										
15.	Export through East-West interconnections :														
	At evening peak-hour :				-237	MW,	at	19:30 hrs							
	Maximum :				-425	MW,	at	24:00							
	Energy :				0.619	MKWh									
<b>(D) Forecast of 30.12.20 (Today) Wednesday :</b>															
01.	Maximum Demand :				9000	MW	(Generation end)								
02.	Maximum Generation :				13053	MW	(Generation end)								
03.	Maximum Shortage :				-4053	MW	(Generation end)								
04.															