

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 7-Feb-21

Page -2

Sl No.	Name of the Power Stations	Producer	Installed Capacity	Capacity	Hour	Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	190	4567500	
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
3	Ghorasal 78.5 MW PPI(MAX)	QRPP	2*40	78	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	3*4*35	108	102	2406636	
5	Hanpur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
6	Hanpur 412 MW CCPP	EGCB	1*273+1*139	412	337	8582140	FGMO
7	Hanpur 360MW CCPP(HPL)	IPP	1*235+1*125	360	294	7454000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	0	0	Under maint.
9	Meghnaghat 100 MW(IEI)	QRPP	12*8.9	100	50	192960	High Voltage.
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	240	6565120	FGMO
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	100	1182360	
12	Madanganj 55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	55	562536	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	100	1289583	
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	326088	Engine problem
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	60	586560	Low demand
18	Siddhirganj 335 MW CCPP	EGCB	1*217+118	335	0	0	Under maint.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	40	85536	High Voltage.
20	Kalpat 52 MW PP (Sinha)	IPP	7*7.5	51	6	16560	High Voltage.
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	17	200880	High Voltage.
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	32	120000	Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	403927	Engine problem
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	35	328988	Engine problem
25	Bosila 108MW PP(ICC)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	57	1313700	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	17	418100	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	829000	
29	Gazipur 52 MW PP	IPP	6*8.9	52	0	0	Reserve.
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	268	4576580	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve.
33	Bramhangon 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	140	1710720	
36	Gazipur 100 MW PP	RPCL	100 MW	105	52	168036	Low demand
37	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.6	104	104	1245120	
38	Manikganj 162MW PP(MFGL)	IPP	9*18	162	144	3015360	Engine problem
Dhaka area Total				5972	2524	48148590	
39	Chattoagram TPP-1	PDB	1*210	180	0	0	Gas shortage.
	Chattoagram TPP-2	PDB	1*210	180	0	0	Gas shortage.
40	Raczan 25 MW PP	IPP	3*8.9	25	8	28911	Low demand
41	Teknaf 20MW PP (Solartech)	Teknaf Solartech Ene	20	20	0	82485	
42	Palanga 50MW PP (Baraka)	IPP	8*6.98	50	19	305760	Engine problem
43	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	70	1688000	Unit-2 under maint
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Gas shortage
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Gas shortage
46	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	0	0	Reserve.
47	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under maint.
48	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	85	268818	
49	Juldah 100 MW Unit-1 (Accorn)	QRPP	8*13.45	100	0	0	High Voltage.
50	Juldah 100 MW PP Unit-3 (Accorn)	IPP	0	100	100	1665600	
51	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	473952	
	Milarancha, Cig, EPZ (United)		5*8.73+3*9.34	0	25	558940	
52	Chattoagram 108 MW PP (ECPV)	IPP	6*18	108	0	0	Low demand
53	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	25154	
54	Anwara 300 MW PP (United)	IPP	300 MW	300	307	6250145	
55	Jodioc Power	IPP	3*18.55+1*3.6	54	54	358013	
56	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
57	Juldah unit-2 (Accorn)	IPP	8*13.6	100	100	1848000	
	Anilma Energy Ltd.	IPP	6*21.2	116	0	0	on test
Chattoagram area Total				2382	794	13579478	
58	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
59	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	165	4515000	Gas shortage
60	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	280	6728000	Gas shortage
61	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	225	5525000	Gas shortage
62	Ashuganj 50 MW PP	APSCL	14*3.968	45	0	0	Gas shortage
63	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	0	0	Gas shortage
64	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	133818	Gas shortage
65	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	400883	Engine problem
66	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	0	257600	Engine problem
67	Tilas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
68	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	45	1691290	Machine problem
69	Chandpur 200MW (Desh energy)	IPP	0	200	34	679200	High Voltage.
70	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	415116	
71	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	247140	
**	Import (Tripura)	Imported power	0	160	104	2096640	
72	Janglata 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	821300	
73	Janglata 52 MW PP (Lakshmi)	IPP	6*8.92	52	0	0	Reserve.
74	Sumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	22	548350	
75	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
76	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Reserve.
77	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	55	511560	High Voltage.
	Bhairab 54.5 MW	IPP	3*18.2	0	0	0	
Cumilla Area Total				2980	1003	24570897	
78	RPCL 210MW CCPP	IPP	4*35+1*70	202	105	2906080	Gas shortage
79	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	438624	
80	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	40	684480	Engine problem
81	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	11300	
82	Mymensingh 200 MW PP (United)	IPP	200	200	200	3679200	High Voltage.
83	Jamalpur 115 MW PP (United)	IPP	115 MW	115	55	144000	#REF!
84	Suitakhal 50 MW Solar PP	IPP	50	50	0	207880	
85	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	24	308640	
Mymensingh Area Total				709	446	8380204	
86	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	30	716000	Gas shortage & GT-2 under maint.
87	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	22	494040	Under maint.
88	Kushnara 163 MW CCPP (KP)	IPP	1*108+1*54	163	163	347760	
89	Shahjibazar 330 MW CCPP	PDB	3*110	330	99	2287000	Gas shortage
90	Fenchugonj 51 MW PP (Barkatullah)	RPP	19*2.90	51	51	1186800	
91	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	50	1193256	
92	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	180000	
93	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	0	0	GT-8,9 Under maint.
94	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	57	1274880	Engine problem
	Shahjibazar 100 MW GTTP	PDB	1*100	0	0	0	On test.
95	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	150	3783090	Gas shortage
96	Sylhet 20 MW GTTP	PDB	1*20	20	18	440000	
97	Sylhet 50MW PP (EPL)	RPP	2*7*2	50	0	0	Contract Expired
98	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	376848	Engine problem
99	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	270	7264000	FGMO
100	Bibiana-III 400 MW CCPP	PDB	400 MW	400	423	9845000	Testing purpose
101	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	199980	
	Bibiana South 400 MW	PDB	400 MW	0	0	0	
Sylhet Area Total				1988	1369	32718494	
**	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVC)	Imported power	2*500	1000	913	1721636	
103	Khulna 115 MW (KPCL-2)	QRPP	7*17	115	49	161440	High Voltage.
104	Fardipur 50 MW Peaking PP	PDB	8*6.89	54	4	67680	Reserve.
105	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
106	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Low demand
107	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	285	7011072	Gas shortage
108	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	24	30000	Line over load.
109	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Reserve.
110	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	95	1078560	Engine problem
111	Madhumati 100 MW PP	SWPGCL	100 MW	100	0	0	Reserve.
Khulna Area Total				2284	1370	25560388	
112	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	16	97632	High Voltage.
113	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	21	379400	Engine problem
114	Bhola 225 MW CCPP	PDB	2*63+1*68	194	0	0	Under maint.
115	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	83	1277320	High Voltage.
116	Payra 1320 MW	BCPCL	2*622	1244	550	12225800	
	Bhola Nutan Bidat BD LTD	IPP	220	0	0	0	
	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	High Voltage.
Barisal Area Total				1826	670	13980152	
117	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage.
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.
118	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	125920	
119	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
120	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50	12	74000	Engine problem
121	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	0	0	Fuel shortage
122	Katak						