

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2021		Day : Thursday					Date : 18.02.21					
Probable Maximum Demand :		9700	MW	Yesterday = 93.39		ft	Probable Maximum Generation : 14125		MW			
Water Level of Kaptai Lake at 06:00 AM				Today = 93.15		ft.	Rule Curve = 94.62		ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.02.21 (Yesterday)		18.02.21 (Today)		17.02.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW			Machines shut down (MW)
					Day	Evening	Day	Evening	Description/ Remarks			
(A) Plants in operation:												
1	a) Ghorasal Repowered CAPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.	
	b) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190			
2	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	0	0	180	180	365	Under maint.	
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	52	52	52	52			
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Under maint. 7/3/2021	
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Under maint.	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	341	341	412	412			
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	130	150	130	150	60	Gas Shortage	
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.	
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	45	60	100	100			
14	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	305	305	290	250	300	300			
15	Meghnaghat 100 MW(HEL)	HFO (QRPP)	12x8.9	100	100	5	50	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	60	97	100	100			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	60	62	60	60			
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	40	100	102			
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22			
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x167+7x8.73	80	80	53	57	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	23	23			
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52			
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	17	105	105			
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	48	115	149	149			
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	12	50	50			
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	195	286	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	32	117	149	149			
31	Keraniganj 300 MW PP (APRI)	HSD (IPP)	25x6.14	300	300	0	0	100	300			
32	Bramhargan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
33	Aurabahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	17	50	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	55	55			
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	90	104	104			
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	138	144	144	144			
	Spectra Solar Plant Ltd.	Solar				12	0	30	0			
Dhaka Zone Total			6171	5972	2080	2602	3639	3881	410	1525		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low Water Level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0	0			
42	Raazari 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	41	46	46			
45	Sikalbaha 105 MW PP (Baraka Sika)	HFO (IPP)	6x18.415	105	105	0	0	50	100			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Gas Shortage	
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Gas Shortage	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	306	306	300	300			
49	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	0	0	100	100			
50	Juldah 100 MW Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
51	Dohazari Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	85	85			
52	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	23	12	25			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	25	102	102			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	54	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
58	Chattogram 116 MW PP (Anima Er)	HFO (IPP)	6x21.06	116	116	0	0	116	116			
Chattogram Zone Total			2442	2382	650	849	1317	1355	715	180		
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	20	20	19	Gas Shortage	
61	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	187	227	225	225			
62	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	220	220	280	280			
63	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	260	275	280	280			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	40	40	40	40	15	Gas Shortage	
65	Ashuganj 185MW PP (APSCL United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0	50		
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	51	74	80	80			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	19	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	17	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11			
73	Jangala 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33			
74	Jangala 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	8	52	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	20	19	19			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+4x1.515+1x1.026	200	200	0	0	0	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	46	113	113			
**	Imoport (Tripura)	India		160	160	102	110	135	147			
	Bhairab 54.5 MW	HFO (IPP)				9	0	0	0			
Cumilla Zone Total			3040	2980	976	1187	1632	1894	820	0		
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	106	109	145	145	93	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	74	80	80			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	22	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	194	200	200	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	24	0	50	0			
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	18	23	22	22			
Mymensing Zone Total			717	709	374	450	636	584	93	0		

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.02.21 (Yesterday)		18.02.21 (Today)		17.02.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0				
88	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	42	32	32				
89	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	8	52	51	51				
90	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021	
91	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163				
92	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
93	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Under maint.	
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	120	112	135	135	218		Gas Shortage	
95	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	75	72	72				
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	136	120	136	136	111		Gas Shortage	
97	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	20	20				
98	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020	
99	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	5	5	10	10				
100	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	16	16				
101	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	341	341				
102	Bibiyana-II	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	340	340	350	350				
		Bibiyana South 400 MW	Gas (PDB)				419	215	400	400				
		Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	0	0			On Test	
Sylhet Zone Total					2033	1988	1559	1443	1737	1737	329	66		
103	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
104	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	215	205	250	250				
105	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25				
106	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	6	60	60				
107	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna	115 PP MW (KPL-2)	HFO (QRPP)	7x17	115	115	0	49	115	115				
109	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
110	Noapara	40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	40	40				
111	Rupsha	105 MW PP (Onion rupsha)	HFO (IPP)	6x18.445	105	105	17	94	90	90				
112	Madhumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000		821	841	839	935				
Khulna Zone Total					2288	2284	1053	1195	1569	1951	0	0		
113	Barsal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110				
114	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	25	26	26				
115	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.	
116	Bhola	95 MW PP (Agreko)	Gas (QRPP)	1.1x96	95	95	62	87	95	95				
117	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	390	450	620	620				
118	Potuaekhali	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
		Bhola Nutan Biddut BD LTD	Gas/HSD				37	0	38	38				
Barishal Zone Total					1826	1826	506	610	1039	1039	0	194		
119	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	50				
121	Baghabari	200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera	70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
123	Ammura	50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	0	12	12	12				
124	Chapanawabganj	100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	102	104	104				
125	Katakhal	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50				
126	Katakhal	50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
127	Santahar	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	20	0	34				
128	Sirajgonj	225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
129	Sirajgonj	225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj	225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	150	162	220	220				
131	Sirajgonj	400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	353	334	400	400				
132	Bogra	22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	22	22	22				
133	Bogra	20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020	
134	Ullapara	11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
135	Natore	52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	25	52	52				
136	Bagura	113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	113	90	113	113				
137	Bagura	113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	95	105	113	113				
Rajshahi Zone Total					2193	2183	742	933	1297	1421	601	0		
138	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
139		Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150				
140		Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0	20		Under Overhauling	
141		Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	107	100	113	113				
142		Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143		Majpara, Talulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
Rangpur Zone Total					685	605	261	250	271	263	170	20		
Sub-total: Plants in operation					21395	20929	8201.0	9519	13137	14125	3138	1985		
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss							7818	9074	12522	13465				
(B) Contract expired power plants														
Sub-Total: Plants under long term maintenance					0	0	0	0	0	0				
Gross Total					21395	20929	8201	9519	13137	14125	3138	1985		
(C) Actual data of 17.02.21 (Yesterday) Wednesday :														
01.	Max. Demand (Generation end)	: 9519.00 MW, at = 19:00 hrs		12.		Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand (Sub-station end)	: 9074.00 MW, at = 19:00 hrs		Zone		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	: 9519.00 MW, at = 19:00 hrs		Dhaka		3343	3343	0	Mymensingh	813	813	0		
04.	Minimum Generation (Generation end)	: 6195.00 MW, at = 5:00 hrs		Chattogram		863	863	0	Sylhet	341	341	0		
05.	Day-peak Generation (Generation end)	: 8201.00 MW, at = 12:00 hrs		Khulna		1114	1114	0	Barishal	235	235	0		
06.	Evening-peak Generation (Generation end)	: 9519.00 MW, at = 19:00 hrs		Rajshahi		939	939	0	Rangpur	656	656	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs		Cumilla		770	770	0	Total	9074	9074	0		
08.	Actual Minimum Generation up to 8:00 hrs.	: 6093.00 MW, at = 7:00 hrs		13.		Fuel cost : (a) Gas = 11174886 Taka (c) Coal = 67882276 Taka								
09.	Generation shortfall at evening peak due to :					(b) Oil = 261146579 Taka Total = 440777741 Taka								
	a) Gas limitation	: 2808 MW												
	d) Coal supply Limitation	: 170 MW												
	b) Low water level in Kaptai lake	: 160 MW												
	c) Plants under shut down/ maintenance	: 1985 MW												
10.	Total Energy (Generation + India Import)	: 195.87 MKWh				14. Maximum Temperature in Dhaka was : 29.4° C								
	By Gas = 115.571 MKWh	42.849 MKWh				15. Export through East-West interconnections :								
	By Coal = 14.599 MKWh	By Hydro = 1.696 MKWh				At evening peak-hour : -98 MW, at 19:00 hrs								
	By Solar= 0.459 MKWh					Maximum : -203 MW, at 8:00 hrs								
						Energy : 0.219 MKWh								
11.	Total Gas Supplied	: 895.09 MMCFD												
(D) Forecast of 18.02.21 (Today) Thursday :														
01.	Maximum Demand	: 9700 MW (Generation end)		04.		Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 14125 MW (Generation end)		05.		Total Generation : 199.59 MKWh								
03.	Maximum Shortage	: -4425 MW (Generation end)		06.		Probable Max. Temperature in Dhaka : 31.9° C								

* Captive Power ** Imported Power
#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation